Energy Research and Development Division

INTERIM PROJECT REPORT

Improving Short-Term Load Forecasts by Incorporating Solar PV Generation

California Energy Commission

Edmund G. Brown Jr., Governor

September 2017 | CEC-500-2017-031

PREPARED BY:

Primary Authors:
Dr. Frank A. Monforte, Itron, Inc.
Ms. Christine Fordham, Itron, Inc.
Ms. Jennifer Blanco, Itron, Inc.
Mr. Stephan Barsun, Itron, Inc.
Adam Kankiewicz, Clean Power Research
Ben Norris, Clean Power Research

Itron, Inc. doing business in California as IBS
12348 High Bluff Drive, Suite 210
San Diego, CA 92130
Phone: 858-724-2620 | Fax: 858-724-2690
http://www.itron.com/na/services/energy-and-water-consulting

Contract Number: EPC-14-001

Prepared for:

California Energy Commission

Silvia Palma-Rojas
Contract Manager

Aleecia Gutierrez
Office Manager
Energy Research and Development Division

Laurie ten Hope
Deputy Director
ENERGY RESEARCH AND DEVELOPMENT DIVISION

Robert P. Oglesby
Executive Director

ACKNOWLEDGEMENTS

The project team would like to thank the following Forecasting Staff at the California Independent system Operator (California ISO) for their invaluable contribution to this effort.

Jim Blatchford, the California ISO

Gary Klein, the California ISO

Amber Motley, the California ISO

Rebecca Webb, the California ISO

PREFACE

The California Energy Commission's Energy Research and Development Division supports energy research and development programs to spur innovation in energy efficiency, renewable energy and advanced clean generation, energy-related environmental protection, energy transmission and distribution and transportation.

In 2012, the Electric Program Investment Charge (EPIC) was established by the California Public Utilities Commission to fund public investments in research to create and advance new energy solution, foster regional innovation and bring ideas from the lab to the marketplace. The California Energy Commission and the state's three largest investor-owned utilities – Pacific Gas and Electric Company, San Diego Gas and Electric Company and Southern California Edison Company – were selected to administer the EPIC funds and advance novel technologies, tools and strategies that provide benefits to their electric ratepayers.

The Energy Commission is committed to ensuring public participation in its research and development programs which promote greater reliability, lower costs and increase safety for the California electric ratepayer and include:

- Providing societal benefits.
- Reducing greenhouse gas emission in the electricity sector at the lowest possible cost.
- Supporting California's loading order to meet energy needs first with energy efficiency and demand response, next with renewable energy (distributed generation and utility scale), and finally with clean conventional electricity supply.
- Supporting low-emission vehicles and transportation.
- Providing economic development.
- Using ratepayer funds efficiently.

Improving Short-Term Load Forecasts by Incorporating Solar PV Generation is the interim report for the grant number CEC-EPC-14-001 conducted by Itron, Inc. (doing business in California as IBS). The information from this project contributes to Energy Research and Development Division's EPIC Program.

All figures and tables are the work of the author(s) for this project unless otherwise cited or credited.

For more information about the Energy Research and Development Division, please visit the Energy Commission's website at www.energy.ca.gov/research/ or contact the Energy Commission at 916-327-1551.

ABSTRACT

This interim report investigates three different methods to integrate behind-the-meter solar photovoltaic (PV) forecasts with an operational net load forecast are investigated. This work determined how to best integrate rapidly growing behind-the-meter PV into net load forecasts for the California Independent System Operator. The different methods are run from 2012 through mid-2015. Analysis of the improvements during 2014-2015 over a baseline net load forecast (that does not account for behind-the-meter PV) are analyzed to identify which method is best when and how much the forecasts are improved. The methods analyzed are being evaluated by the California Independent System Operator and could be used by other system operators experiencing rapid penetration of behind-the-meter PV. The final project report will include details about solar forecasting improvements and quantify potential savings that result from improved net load forecasts.

Keywords: Solar Photovoltaics (PV), load forecasting, solar forecasting

Monforte, Frank A.; Christine Fordham; Jennifer Blanco; Stephan Barsun (Itron, Inc.) Adam Kankiewicz; Ben Norris (Clean Power Research). 2016. ***Improving Short-Term Load Forecasts by Incorporating Solar PV Generation.*** California Energy Commission. Publication number: CEC-500-2017-031.

TABLE OF CONTENTS

LIST OF FIGURES

LIST OF TABLES

EXECUTIVE SUMMARY

Introduction

California is a clean energy leader with an aggressive Renewables Portfolio Standard requiring 33 percent of electricity generation to come from renewable energy by 2020 and 50 percent by 2030. More solar systems, specifically photovoltaics (PV), are being installed each year spurred by financial incentives and cost declines in PVs. California has more than 3.8 gigawatts (GW) of installed on-site solar PV generation connected on the customer side of the meter. This behind-the-meter generation is expected to increase three- to five-fold by 2020.

To manage California's huge electricity system reliably and efficiently, the California Independent System Operator (California ISO) depends on consistent and dependable electricity generation. Every five minutes, the California ISO forecasts electrical demand and directs the lowest cost generator to meet this demand. As the amount of intermittent or fluctuating solar generation increases, so do its impacts on operating California's electric generation and transmission system. The California ISO finds the electrical demand forecasts are becoming less reliable as large amounts of behind-the-meter solar generation are added to the grid. This is especially true in the morning hours when loads can appear to be driven more by clouds such as a marine layer rather than temperatures. In contrast, afternoon loads still are dominated by temperature changes driving air conditioning loads.

Study Purpose and Process

Solar power only generates electricity during the day, producing more electricity the more the sun shines. Accurately predicting when and how this fluctuating resource can be used is essential for grid operators. The California ISO uses a Baseline Load Forecast Model to calculate measured electricity loads of 15 minutes ahead to 10 days ahead. This baseline framework consists of 193 individual forecast models. Since the California ISO does not measure, either in real time or after the fact, any behind-the-meter solar PV generation, this means measured load does not equal actual end-user (for example, residential, commercial, industrial or agriculture) consumption of electricity. At the time of this study, none of the California ISO load forecast models include the impact of behind-the-meter solar PV on measured loads so the existing load forecast models must be modified to capture the influence of behind-the-meter solar PV. This interim report describes a study that evaluates three alternative model approaches for extending the California ISO electricity load forecast framework.

- **Error Correction Model**. Most system operators initially make adjustments to the load forecasts afterwards to account for solar PV generation. On sunny days, they lower the load forecast and on cloudy days adjust the load upward. The key advantage of the Error Correction Approach is the existing load forecast model can continue to be used without any changes. All that is required is a method to forecast solar PV generation.
- **Reconstituted Loads Model**. Under the Reconstituted Loads approach the past measured load is reconstructed by adding back estimates of solar PV generation. The load forecast model is then re-estimated against the revised loads. The new load forecasts are then adjusted by subtracting the forecasts of solar PV generation. The

advantage of this approach is that the estimated load forecast model coefficients are not adversely impacted by the penetration of solar PV generation. The disadvantage is a historical time series of solar PV generation must be developed and maintained to estimate the load forecast model coefficients. Further, this approach assumes the historical solar PV generation time series is accurate. If this is not true, this approach places too high of a weight on the solar PV generation values.

- **Model Direct.** Under the Model Direct approach, estimates of historical solar PV generation are added as influencing factors in the load forecast models; like the way other data such as day of the week and weather are included in the load forecast models. The estimated coefficient on the solar PV generation variable is the weight placed on this influencing factor. Also by including solar PV generation as an explanatory variable, the estimated coefficients on the remaining influencing or explanatory variables should not be biased. This approach also provides a direct forecast of measured loads that accounts for solar PV generation, thus avoiding any after the fact processing of the load forecast. Like the Reconstituted Load Approach, this approach requires developing and maintaining a historical time series of solar PV generation.

To evaluate the forecast performance of the alternative model approaches a series of 24-hour-ahead load forecasts are simulated. The 15-minute-ahead up to 24-hour-ahead alternative model load forecasts errors are compared to the corresponding baseline model load forecast errors. This study's goal is to demonstrate that one or more of the alternative approaches outperforms the baseline load forecast by reducing the average absolute forecast error and the associated forecast error variance. In other words, the load forecast errors are on average smaller and the width of the forecast error distribution is tighter when using one or more of the alternative approaches.

To conduct the simulations a historical time series of behind-the-meter solar PV generation is required. Unfortunately, direct metering of the generation output of behind-the-meter PV installed in California is not available. To address this lack of historical generation data, the study relies on two sources of behind-the-meter solar PV generation estimates:

- **Clean Power Research Solar Generation Estimates**. Itron's partner, Clean Power Research, is refining a forecast model that simulates each individual PV system in the California ISO. This forecast is based on an ensemble of models to estimate the amount of power each system will produce in any given hour, combining numerous techniques to perform this service. This micro focus is most useful when the exact locations of the solar installations are known. For the California ISO, Clean Power Research has combined this micro level approach with a detailed database of solar PV installations to construct a time series of non-utility scale solar generation estimates by load zone.
- **Cloud Cover Driven Solar Generation Estimates**. Not all system operators have access to the detailed installation data that Clean Power Research has gathered for California. In many cases, a system operator will have at best good estimates of the total installed capacity by the transmission zone and/or possibly by postal code. Further, most system

operators only have access to hourly cloud cover data for the weather stations they use to forecast loads. To provide a basis for comparison to the Clean Power Research results, behind-the-meter solar PV generation estimates are derived by combining hourly cloud cover data collected by weather station with collective estimates of installed capacity by load zone.

When combined with the three alternative load forecast approaches there are a total of six alternative load forecasts: (1) Error Correction with Clean Power Research solar PV generation estimates, (2) Error Correction with cloud-cover based solar PV generation estimates, (3) Reconstituted Load with Clean Power Research solar PV generation, (4) Reconstituted Load with cloud-cover based solar PV generation estimates, (5) Model Direct with Clean Power Research solar PV generation and (6) Model Direct with cloud-cover based solar PV generation.

Study Results

Each of these six forecasting methods were compared to the baseline forecast and were done for the California ISO, each of the three investor-owned utilities and each of the five California ISO zones (Pacific Gas and Electric Company [PG&E] Bay Area, PG&E Non-Bay Area, Southern California Edison [SCE] Coastal, SCE Inland, and San Diego Gas and Electric [SDG&E]). In general:

- Not adjusting the California ISO baseline forecast models will lead only to further erosion of forecast accuracy and a wider distribution of forecast errors.
- Direct modeling performed better than the baseline and other methods in the near term (15 minutes to four hours in advance). The reconstituted load approach performed better for longer time horizons from four hours through to day-ahead horizons. This suggests a hybrid or ensemble approach that combines these two methods is optimal.
- SDG&E showed better improvements from forecasts that integrated behind-the-meter PV forecasts than the California ISO as a whole or any of the other California ISO zones. This outcome could be the result of a smaller geographic area combined with a higher penetration of behind-the-meter PV.
- Hourly cloud cover driven estimates of solar generation can provide benefit over doing nothing, however, the detailed bottom-up approach implemented by Clean Power Research yields superior results.
- The findings also indicate that 1 megawatt (MW) of solar PV generation may not reduce what the California ISO measures as a 1 MW load. A possible explanation for this counter intuitive finding is the California ISO measures only what happens in front of the meter not behind-the-meter. If the installed solar PV leads to fundamental behind-the-meter behavioral changes in how consumers use end-use equipment, then the impact of solar PV generation on load will be muted. One possible behavioral change that will lead to offsetting load impacts is when consumers with solar PV keep their heating or cooling equipment running during the day. Most likely consumers do this because the PV electricity is considered "free." This type of behavioral change can cause

a net increase in load levels and load weather sensitivity if the majority of these consumers turned off their heating or cooling equipment during the day before installing a PV system.

- The model direct approach investigates how much of the solar PV generation actually results in net load increases associated with this type of behavioral change. The estimated impact from solar PV generation is less than 1 MW of load reduction for 1 MW of solar PV generation. The trend in solar PV installations also captures a net load increase in the shoulder periods (early morning and later afternoon) potentially because of behavioral changes after PV is installed. Further research is required to determine the extent more solar PV is leading to behavioral changes. If the research validates that behavioral changes are occurring, then the load forecasting problem will become only more complicated as more solar PV installations lead to more weather-sensitive loads. Similarly, developing a strong understanding of how consumer behavior can change as more electric vehicle charging and on-site storage are adopted which will ultimately be required to maintain acceptable load forecast performance.

Project Benefits

This improved net load forecasts offers several benefits to California. The quickest benefit is reducing the cost of grid regulation required to cover increasing load forecast errors. By reducing the percentage error by just 0.1 percent (for example, from 1.7 percent to 1.6 percent), the California ISO and California ratepayers can save more than $2 million per year. As the installed capacity of behind-the-meter PV increases, the annual savings will likely increase. Further financial savings from more accurate forecasts may also be possible and will be investigated.

In addition to financial savings, emission savings from reducing the need for spinning reserves should be realized. Finally, by reducing the demand for resources required to balance intermittent renewables, better renewable energy forecasting should make possible a higher proportion of solar generation for California's grid.

The final project report will include details about solar forecasting improvements and quantify potential savings that result from improved net load forecasts in more detail.

CHAPTER 1: Introduction

Renewable Portfolio Standard requirements and decreasing cost of photovoltaics (PV) are resulting in significant amounts of behind-the-meter (BTM) solar PV systems being installed in California. Currently, more than 3.8 gigawatts (GW) of BTM PV capacity are installed in California.[1] This capacity is expected to increase three- to five-fold by 2020. Uncertainty in BTM solar PV output and its associated measured load impacts lead to overly conservative scheduling or regulation services and spinning reserves. To reduce the reliance on regulation services and spinning reserves, the California Independent System Operator (CAISO) requires improved measured load forecasts.

The load forecasts that the California ISO relies on for real-time system operations are developed using statistical models of five minute measured loads. These data are collected in real time based on measurement points at each grid-connected generation resource, as well as, inter-region tie lines. It is important to note that at the time of this study, the California ISO does not measure either in real time or *ex post* BTM solar PV generation. This means measured load does not equal actual end-user (i.e., residential, commercial, industrial, agriculture, and other customer segments) consumption of electricity, since some portion of the consumption is sourced by BTM solar PV generation.

Why does this matter? It matters because the statistical load forecast models are designed to capture the factors that impact end-user electricity consumption. With deeper penetration of BTM solar PV, load forecast models must be extended to predict when end users will lean on the grid to meet their electricity requirements versus relying on their own generation. Prior to BTM solar PV, reliance on the grid was driven by traditional end-user consumption patterns—patterns that are well-studied and predictable. With BTM solar PV, reliance on the grid is driven both by end-user consumption patterns and the availability of BTM solar PV generation. The latter is driven by meteorological events not easily predicted.

The net effect of a deep penetration of BTM solar PV is that forecasts of measured load are becoming less reliable. This is especially true in the morning hours when loads appear to be driven more by the presence of clouds (e.g., marine layer) rather than temperatures. In contrast, afternoon loads still appear to be dominated by temperature changes that drive air conditioning loads. This may change over time when BTM solar PV penetration reaches a critical mass, where the variation in BTM solar PV generation is sufficiently large to outweigh the load variation due to variation in air conditioning loads.

To better predict an increasing volatile load, the California ISO existing load forecast models need to be extended to capture the influence of BTM solar PV. This study evaluates three alternative model approaches for extending the California ISO load forecast framework. This interim report presents the alternative load forecast frameworks for incorporating BTM solar PV

[1] Go Solar California website https:’//www.californiasolarstatistics.gov

forecasts and the forecast simulations that were implemented to evaluate the performance of these approaches.

To put these approaches into context, below is a description of the existing California ISO load forecast model.

1.1 The California ISO Short-Term Load Forecast Model

The Baseline Load Forecast Model is used to provide forecasts of measured loads for forecast horizons of 15 minutes ahead out to ten days ahead. The California ISO load forecasting system produces 15-minute level load forecasts for forecast horizons of 15-minutes ahead out ten (10) days ahead. The load forecasts are updated automatically every 15-minutes to support generation scheduling and dispatching. A separate set of load forecast models are used for each of the three major California ISO load zones: Pacific Gas and Electric (PG&E), Southern California Edison (SCE) and San Diego Gas & Electric (SDG&E). In addition, the California ISO develops sub-region forecasts for five climatic zones: PGE& Bay Area, PG&E Non-Bay Area, SCE Coastal, and SCE Inland load zones and SDG&E. The load forecasts are driven by hourly weather forecasts of temperature and humidity for approximately 24 weather stations located throughout California. The weather forecasts are updated hourly and are available from multiple weather forecast service providers. This allows the California ISO to quantify the load forecast uncertainty due to weather forecast uncertainty. An ensemble of load forecasts are generated by driving the separate weather forecasts through the load forecast models. An optimal load forecast is then computed as a weighted average across the load forecast ensemble. The weighting scheme is based on the most recent forecast performance of each weather service provider.

For each load zone (PG&E, PG&E Bay Area, PG&E Non-Bay Area, SCE, SCE Inland, SCE Coastal, and SDG&E), the baseline 15-minute load forecast modeling framework is composed of 193 individual forecast models. Each forecast model is designed to optimize the load forecast performance for specific forecast horizon. The 193 individual forecast models that define the California ISO baseline 15-minute load forecast modeling framework are:

1. **Daily Energy Model**: A Neural Network Model of Daily Energy is used to capture daily swings in electricity demand as driven by changes in calendar and weather conditions.

2. **Day-Ahead Models**: Designed for forecast horizons of four hours ahead and longer. Is composed of 96, 15-Minute Regression Models that are driven by the forecasts from the Daily Energy Model, as well as by forecasted calendar and weather conditions. Because the Day-Ahead models do not contain autoregressive terms, they are quick to react to changing weather conditions.

3. **Hour-Ahead Models**: Designed for forecast horizons of up to four to six hours ahead. Is composed of a second set of 96, 15-Minute Regression Models that launch off the most recent meter data through inclusion of autoregressive terms in addition to forecasted calendar and weather conditions.

The operational forecast that the California ISO utilizes is updated every 15 minutes and has a forecast horizon of the balance-of-the-day out ten days ahead. The operational forecast is generated with the following steps:

1. Generate a balance-of-the-day out ten days ahead forecast of Daily Energy using the Daily Energy model.
2. Generate a balance-of-the-day out ten days ahead forecast of quarter hour loads using the Day-Ahead models.
3. Generate a balance-of-the-day out ten days ahead forecast of quarter hour loads using the Hour-Ahead models.
4. Create a single quarter hour load forecast by taking a weighted average of the Day-Ahead and Hour-Ahead forecasts. For forecast horizons of up to two hours ahead, 100% weight is placed on the Hour-Ahead forecasts. Between two and four hours ahead, the weight cascades away from the Hour-Ahead forecast and towards the Day-Ahead forecast. For forecast horizons of four hours ahead and longer, 100% weight is placed on the Day-Ahead forecast.

This framework offers the following advantages over the use of a single set of 96, quarter hour models.

- Forecasts of Daily Energy capture the influence of a full day of weather conditions on loads. This influence is then channeled through to the Day-Ahead model forecasts via predicted Daily Energy values with day-of-the-week interaction terms.
- The Day-ahead model forecasts are free to respond quickly to forecasted changes in weather conditions.
- The Hour-Ahead models exploit the information contained in the most recent metered loads.
- The blended forecast balances the value of autoregressive terms over near-term forecast horizons with the value of forecasted weather conditions over longer-term forecast horizons in a single forecast.

Daily Energy Model Specification: The Daily Energy Model is used to forecast total measured load for forecast horizons of balance-of-the-day to ten days ahead. The forecast values from the Daily Energy model are included as explanatory variables in the 96, 15-minute level Day-Ahead models. The reason for this is that the time series of Daily Energy tends to be smoother than the individual 15-minute load streams. This allows the development of very powerful Daily Energy models. Accurate forecasts of Daily Energy in turn are strong forecast drivers for the 15-minute Day-Ahead models.

The Daily Energy model utilizes Neural Network Techniques. Because Neural Network Techniques describe a broad range of model specifications it is useful to describe the specific adaptation that is implemented at the California ISO. The specific Neural Network Model that is used for the California ISO is a five (5) Node Neural Network Model with a single Hidden layer pointing to a single output. Translated to the language of a multivariate regression, the single output is the dependent variable of the model, namely Daily Energy which is computed as the sum of the 15-minute loads.[2] A single layer means the predicted value is the weighted sum of the predicted value from each of the five nodes. The weights can be considered the estimated parameters by the dependent variable (Daily Energy) being regressed on the predicted values from the five (5) nodes. Further, the predicted values from the nodes do not interact with the values from the other nodes. The nodes themselves have specific functional forms. The first node utilizes a linear activation function which means the predicted value from this node is a weighted sum of the explanatory variables included on this node. Further, there are no interactions between the explanatory variables included on this node. The weights or coefficients are estimated as part of the model estimation process. The second through fifth nodes use a logistic or sigmoid activation function. This function form has proven to be extremely useful in applying Neural Network Techniques to the problem of load forecasting because it provides a continuous nonlinear approximation of the nonlinear response between loads and weather. This approximation is very similar to what regressing loads against a third order polynomial in weather would derive. Unlike a polynomial regression, where key interaction terms like weekend weather slope offsets would need to be constructed outside of the regression model and then added as additional explanatory variables, the mathematical properties of the sigmoid function allows for these interactions to be estimated directly as part of the model estimation process. Although, the explanatory variables (like weather and weekend binary variables) need to be included in the list of explanatory variables included on a Node for the interactions to be estimated. Like the linear node, the weights or coefficients of the nonlinear nodes (Node 2 through Node 5) are estimated as part of the model estimation process.

The model can be written generally as follows:

Equation 1: Daily Energy Neural Network Model

$$\mathrm{E}_{\mathrm{d}}^{\mathrm{Z}} = \sum_{\mathrm{n}=1}^{\mathrm{N}} \emptyset_{\mathrm{n}}^{\mathrm{Z}} \mathrm{H}_{\mathrm{d}}^{\mathrm{Z,n}}\left(\mathrm{A}_{\mathrm{d}}^{\mathrm{Z,n}} \alpha^{\mathrm{Z,n}}\right) + \varepsilon_{\mathrm{d}}^{\mathrm{Z}}$$

Where,

$\mathrm{E}_{\mathrm{d}}^{\mathrm{Z}}$ is the daily sum of the 96 15-minute load values for Load Zone (Z) on Day (d)

N is the number of Nodes in the Hidden Layer of the Neural Network Model. Node 1 (n=1) utilizes a Linear Activation Function. Nodes (2 through 5) utilize a Sigmoid Activation Function.

$\emptyset_{\mathrm{n}}^{\mathrm{Z}}$ is the weight placed on Node (n)

[2] See J. S. McMenamin and Frank A. Monforte, *Short Term Energy Forecasting with Neural Networks,* The Energy Journal, Volume 19, Number 4 (1998) pages 43-61 for a comparison of regression and Neural Network modeling techniques for short term energy forecasting.

$H_d^{Z,n}(A_d^{Z,n}\alpha^{Z,n})$ is the nth Node in the Hidden Layer

$A_d^{Z,n}$ is a vector of explanatory variables included on the nth Node in the Hidden Layer

$\alpha^{Z,n}$ is a vector of weights placed on the explanatory variables included on the nth Node in the Hidden Layer

ε_d^Z is the Neural Network model error for Load Zone (Z) on Day (d)

The Neural Network weights ($\emptyset_n^Z$ and $\alpha^{Z,n}$) are estimated using Non-Linear Least Squares.

The explanatory variables included on the Nodes in the Hidden Layer are as follows.

Node 1: Linear Activation Function

- A set of Day Type Variables: (Sunday, Monday, Tuesday-Wednesday-Thursday (TWT), Friday, Saturday) by Month
- Day of the Week Variables
- Holiday Variables
- Linear Time Trend
- Hours of Light Variable

Node 2 and 3: Sigmoid Activation Function

- Night, Morning, Afternoon, and Evening Heating Degree Day Variables
- Night, Morning, Afternoon, and Evening Latent Heat Variables
- Night, Morning, Afternoon, and Evening Wind Speed Variables
- Prior Day Maximum and Minimum Temperature Variables
- Day-of-the-Week Variables
- Non-Winter Months, Monthly Binary Variables

Node 4 and 5: Sigmoid Activation Function

- Night, Morning, Afternoon, and Evening Cooling Degree Day Variables
- Night, Morning, Afternoon, and Evening Latent Heat Variables
- Night, Morning, Afternoon, and Evening Wind Speed Variables
- Prior Day Maximum and Minimum Temperature Variables
- Day-of-the-Week Variables
- Non-Summer Months, Monthly Binary Variables

The load forecasts generated from the Daily Energy Models can be written as follows.

Equation 2: Predicted Daily Energy

$$\widehat{E}_d^{Z,T+h} = \sum_{n=1}^{N} \widehat{\emptyset}_n^Z H_d^{Z,n,T+h}\left(A_d^{Z,n,T+h}\hat{\alpha}^{Z,n}\right)$$

Where,

> $\widehat{E}_{d,}^{Z,T+h}$ is the h-step ahead forecast of Daily Measured Load for Zone (Z) made at time (T) for forecast day (d)
>
> T + h measures the number of time intervals in the forecast horizon for a forecast generated at time (T)
>
> $A_{d,}^{Z,n.T+h}$ contains the h-step ahead forecasted values of the explanatory variables made at time (T)
>
> $H_d^{Z,n,T+h}$ is the h-step ahead forecasted value for node (n) for Zone (Z) made at time (T),
>
> $\widehat{\emptyset}_n^Z$ is the vector of estimated Node weights
>
> $\hat{\alpha}^{Z,n}$ is the vector of estimated Neural Network coefficients for Node (n)

Day-Ahead Model Specification: The 96 ,15-minute level Day-Ahead models can be described generically as:

Equation 3: 96, 15-Minute Level Day-Ahead Models

$$L_{d,i}^Z = F\left(X_{d,i}^Z \beta_i^Z\right) + u_{d,i}^Z$$

Where,

> $L_{d,i}^{Z}$ is the measured load for load zone (Z), on day (d), and 15-minute time interval (i). Load zones include PGE Total, PG&E Bay Area, PG&E Non-Bay Area, SCE Total, SCE Inland, SCE Coastal, and SDG&E
>
> $F\left(X_{d,i}^Z \beta_i^Z\right)$ is a generic representation of a regression model where $X_{d,i}^Z$ is a set of explanatory variables - excluding explicit treatment of Behind-the-Meter Solar Generation
>
> β_i^Z is a vector of model coefficients.
>
> $u_{d,i}^Z$ is the forecast model error

The vector of mode coefficients (β_i^Z) are estimated using Multivariate Least Squares.

The explanatory variables included in the models are as follows.

- A set of Day Type Variables: (Sunday, Monday, TWT, Friday, Saturday) by Month
- Day of the Week Variables
- Holiday Variables

- Linear Time Trend
- Variables that Measure the Fraction of the Morning/Evening Hours that are dark
- Coincident Heating Degree Day Variables
- Coincident Heating Degree Day Variables with Sunday and Saturday interactions
- Coincident Cooling Degree Day Variables
- Coincident Cooling Degree Day Variables with Sunday & Saturday interactions
- Prior Day Maximum and Minimum Temperature Variables
- Predicted Values from the Daily Energy Model interacted with Day-of-the-Week

The load forecasts generated from the Day-Ahead Models can be written as follows:

Equation 4: 96, 15-Minute level Day Ahead Predicted Values

$$\mathrm{DayAhead\_}\hat{L}_{d,i}^{Z,T+h} = F\left(X_{d,i}^{Z,T+h}\hat{\beta}_i^Z\right)$$

Where,

$\mathrm{DayAhead\_}\hat{L}_{d,i}^{Z,T+h}$ is the h-step ahead forecast of Measured Load for Zone (Z), forecast day (d) and time interval (i) made at time (T)

h measures the number of forecast intervals ahead

$X_{d,i}^{Z,T+h}$ contains the h-step ahead forecasted values of the explanatory variables

$\hat{\beta}_i^Z$ is the vector of estimated model coefficients

Hour-Ahead Model Specification: The 96, Hour-ahead models can be described generically as:

Equation 5: 96, 15-Minute level Hour Ahead Models

$$L_{d,i}^Z = G\left(X_{d,i}^Z\delta_i^Z\right) + \sum_{k=1}^{K} L_{d,i-k}^Z\gamma_k^Z + w_{d,i}^Z$$

Where,

$L_{d,i}^Z$ is the measured load for load zone (Z), on day (d), and 15-minute time interval (i).

$G\left(X_{d,i}^Z\delta_i^Z\right)$ is a generic representation of a regression model where $X_{d,i}^Z$ is a set of explanatory variables - excluding explicit treatment of Behind-the-Meter Solar Generation (BTMSG)

δ_i^Z is the vector of model coefficients

$L_{d,i-k}^Z$ is an autoregressive term of lag (i-k), where the maximum length of the autoregressive structure is (K)

γ_k^Z is the coefficients for the autoregressive terms

$w_{d,i}^Z$ is the forecast model error

The explanatory variables included in the models:

- A set of Day Type Variables: (Sunday, Monday, TWT, Friday, Saturday) by Month
- Day of the Week Variables
- Holiday Variables
- Linear Time Trend
- Variables that Measure the Fraction of the Morning/Evening Hours that are dark
- Coincident Heating Degree Day Variables
- Coincident Heating Degree Day Variables with Sunday and Saturday interactions
- Coincident Cooling Degree Day Variables
- Coincident Cooling Degree Day Variables with Sunday and Saturday interactions
- Prior Day Maximum and Minimum Temperature Variables
- A set of the prior five (K), 15-minute load values

In this case, the autoregressive terms replace the predicted value from the Daily Energy model.

The load forecasts generated from the Hour-Ahead Models can be expressed as follows:

Equation 6: 96, 15-Minute level Hour Ahead Predicted Values

$$\mathrm{HourAhead\_}\hat{L}_{d,i}^{Z,T+h} = G\left(X_{d,i}^{Z,T+h}\hat{\delta}_i^Z\right) + \sum_{k=1,T+h-k<T}^{K} L_{d,i-k}^{Z,T+h-k}\hat{\gamma}_k^Z + \sum_{k=1,T+h-k>T}^{K} \mathrm{HourAhead\_}\hat{L}_{d,i-k}^{Z,T+h-k}\hat{\gamma}_k^Z$$

Where,

$\mathrm{HourAhead\_}\hat{L}_{d,i}^{Z,T+h}$ is the h-step ahead forecast of Measured Load for Zone (Z), forecast day (d) and time interval (i) made at time (T)

h measures 15-minute time intervals - if a forecast is generated at 08:00 then T equals 08:00 of day (d=0), the two hour-ahead Load forecast would then be indexed as T=08:00, d = 0, h = 8

$X_{d,i}^{Z,T+h}$ contains the h-step ahead forecasted values of the explanatory variables

$\hat{\delta}_i^Z$ is the vector of estimated model coefficients

$L_{d,i-k}^{Z,T+h-k}$ is observed Measured Load for Zone (Z), forecast day (d) and time interval (i) available at time (T)

$\hat{\gamma}_k^Z$ is the estimated coefficients for the autoregressive terms

$\text{HourAhead\_}\hat{L}_{d,i-k}^{Z,T+h-k}$ is the Hour Ahead forecasted Measured Load for Zone (Z), forecast day (d) and time interval (i-k) available at time (T+h)

Blended Load Forecast: The blended forecast balances the value of autoregressive terms over near-term forecast horizons with the value of forecasted weather conditions over longer-term forecast horizons in a single forecast. The blended forecast is constructed in steps.

Step 1: A 10-day-ahead load forecast is generated using the Daily Energy Model. This ten day ahead forecast then feeds into the Day-Ahead Models.

Step 2: The Day-Ahead Models are then used to generate a 10-day-ahead load forecast at the 15-minute level of load resolution.

Step 3: The Hour Ahead Models are then used to construct a separate 15-minute level load forecast.

Step 4: A single blended load forecast is then constructed as follows:

Equation 7: 15-Minute level Blended Forecast

$$\text{Blended\_}\hat{L}_{d,i}^{Z,T+h} = \omega_h^Z \text{HourAhead\_}\hat{L}_{d,i}^{Z,T+h} + \left(1 - \omega_h^Z\right)\text{DayAhead\_}\hat{L}_{d,i}^{Z,T+h}$$

Where,

$\text{Blended\_}\hat{L}_{d,i}^{Z,T+h}$ is the blended forecast of Measured Load for Zone (Z) made at time (T) for the fifteen minute time interval (T+h)

$\text{HourAhead\_}\hat{L}_{d,i}^{Z,T+h}$ is the Hour-Ahead forecast of Measured Load for Zone (Z) made at time (T) for the fifteen minute time interval (T+h)

$\text{DayAhead\_}\hat{L}_{d,i}^{Z,T+h}$ is the Day-Ahead forecast of Measured Load for Zone (Z) made at time (T) for the fifteen minute time interval (T+h)

ω_h^Z is the weight placed on the Hour-Ahead forecast for forecast period (T+h)

Load Forecast Errors: The Load Forecast errors are then computed as:

Equation 8: 15-Minute Level Load Forecast Errors

$$e_{d,i}^{Z,T+h} = L_{d,i}^Z - \text{Blended\_}\hat{L}_{d,i}^{Z,T+h}$$

Where,

$e_{d,i}^{Z,T+h}$ is the forecast error for Zone (Z) for day (d) and 15-minute time interval (i) from a h-step-ahead forecast made at time (T)

1.2 The Impact of Solar PV on the California ISO Short-Term Load Forecast

The statistical models described above use linear least squares to estimate the model coefficients.[3] At a very high level, the process of estimating the model coefficients is an averaging of the historical load data, where the explanatory variables segment the load data over which the averages are taken. While this is not an exact description of the least squares approach, it is a useful metaphor when describing how solar PV impacts the estimated coefficients of the California ISO short-term load forecast models. Over time, an increased penetration of solar PV has the net effect of reducing on average measured load. This implies that the estimated model coefficients embody this reduction in measured loads. That is, the model coefficients are tuned to measured load under average solar PV production that occurred over the model estimation period. As a result, the short-term load forecasts produce a forecast under average solar PV production conditions. The challenge is on any given day actual solar PV production will not necessarily align with the average solar PV production. On cloudy days when solar PV production is smaller than average, the load forecast will under forecast loads because the model fails to reflect the bump up in loads due to lower solar PV production. On sunny days when solar PV production is greater than average, the load forecast will over forecast loads because the model fails to reflect the drop in loads due to higher solar PV production.

To help fix ideas, the following examples illustrate how solar PV generation can impact a load forecast. In these examples, assume the demand for electricity at noon, regardless of how it is sourced, is 1,300 MW.

No Solar PV Generation: Under this first example, there is no solar PV generation. As a result, Measured Load, which is the load that a system operator sees, equals actual Demand for electricity services. That is,

Equation 9: Measured Load at Noon vs. Actual Demand with no BTM Solar PV

$$\mathrm{L}_{\mathrm{d}}^{\mathrm{Noon}} = \mathrm{D}_{\mathrm{d}}^{\mathrm{Noon}}$$

Where,

$\mathrm{L}_{\mathrm{d}}^{\mathrm{Noon}}$ is the telemetry measured load that the control room sees at Noon at day (d)

$\mathrm{D}_{\mathrm{d}}^{\mathrm{Noon}}$ is the Demand for electrical services at Noon on day (d)

Now consider developing a forecasting model of measured load. If there is a year's worth of measured load, the following regression model can be used.

Equation 10: Regression Model to Predict Load at Noon with no BTM Solar PV.

$$\mathrm{L}_{\mathrm{d}}^{\mathrm{Noon}} = \beta_1 \mathrm{Intercept}_{\mathrm{d}} + \mathrm{e}_{\mathrm{d}}^{\mathrm{Noon}}$$

[3] The Neural Network model coefficients are estimated using the Levenberg-Marquardt algorithm, which is a specific application of Nonlinear Least Squares.

Where,

$\text{Intercept}_{\text{d}}$ is an explanatory variable that takes on the value 1.0 for every day (d)

$\text{e}_{\text{d}}^{\text{Noon}}$ is a random error with expected value of 0.0

β_1 is the regression coefficient on the Intercept variable

In this case, the estimated coefficient on the Intercept variable will be equal to the average measured load, or 1,300 MW. As a result, the forecast from the estimated model will provide an accurate forecast of both measured load and actual demand.

That is,

Equation 11: Predicted Load at Noon with no BTM Solar PV.

$$\hat{\text{L}}_{\text{d}}^{\text{Noon}} = 1300 \text{ x Intercept}_{\text{d}} = 1300 = \text{D}_{\text{d}}^{\text{Noon}}$$

Where,

$\hat{\text{L}}_{\text{d}}^{\text{Noon}}$ is the forecast of measured load for day (d) at Noon

With Constant Solar PV Generation: Now, assume that 100 MW of solar PV generation is produced every day at noon. The measured load can be re-written as follows:

Equation 12: Measured Load with Constant BTM Solar PV.

$$\text{L}_{\text{d}}^{\text{Noon}} = \text{D}_{\text{d}}^{\text{Noon}} - \text{SG}_{\text{d}}^{\text{Noon}}$$

Because measured load will be 100 MW lower, the estimated coefficient from the regressed new lower measured load on the Intercept variable will lead to an estimated coefficient of 1,200 MW. In this case, the resulting model forecast will accurately forecast measured load, but will under predict demand by 100 MW.

Equation 13: Regression Model to Predict Load with Constant BTM Solar PV.

$$\hat{\text{L}}_{\text{d}}^{\text{Noon}} = 1200 \text{ x Intercept}_{\text{d}} = 1200 < \text{D}_{\text{d}}^{\text{Noon}}$$

From the perspective of system operations, the fact that the forecast model under predicts demand for electricity is not a concern, since in this unrealistic example, they can rely on the 100 MW of solar generation being there all the time.

With Volatile Solar PV Generation: In reality, solar PV generation is not as reliable as the above example suggests. One can introduce uncertainty into the amount of solar generation that is available by assuming that half the time cloud cover is thick enough to drive the solar generation to 0 MW. The other days are perfectly clear and the solar generation is 100 MW. This means that half the time measured load equals 1,200 MW and the other half of the time measured load equals 1,300 MW. If the cloudy and sunny days are equal in number, the average measured load over the year of data will be 1,250 MW. This implies the estimated coefficient on the Intercept variable will be equal to 1,250 MW. That is,

Equation 14: Regression Model to Predict Load with Variable BTM Solar PV.

$$L_d^{Noon} = 1250 \text{ x } \text{Intercept}_d$$

Now consider using this model on two types of days: a Cloudy Day and a Sunny Day. On a Cloudy Day, solar PV generation is 0 MW and measured load will be equal to 1,300 MW, computed as $(D_d^{Noon} - 0)$. In this case, the model forecast of 1,250 MW under predicts measured load. On a Sunny Day, solar PV generation is 100 MW giving a measured load of 1,200 MW, computed as $(D_d^{Noon} - 100)$. In this case, the model forecast will over predict measured load.

The variability in solar generation means that the statistical model that was fitted to measured load will under predict measured loads on cloudy days and over predict measured loads on sunny days. From the perspective of system operations, this means they will need additional spinning reserves available to cover the load variability and subsequent load forecast error introduced by the volatile solar PV generation. The inherent bias that arises from fitting statistical models to measured load implies that a growing penetration of solar PV generation will lead to an erosion of the forecast accuracy of load forecast models that do not account for this impact.

Accounting for Average Solar Generation: Is it possible to improve the accuracy of the load forecast? Assuming a perfect forecast of cloud over can be obtained, it is possible to accurately predict how much solar generation is going to be available tomorrow. It seems reasonable to adjust the baseline load forecast with the forecast of solar generation. Specifically, the adjusted forecast of measured load can be constructed as:

Equation 15: Predicted Load with Perfectly Forecasted BTM Solar PV.

$$\bar{\bar{L}}_d^{Noon} = \hat{L}_d^{Noon} + (\overline{SG}^{Noon} - \widehat{SG}_d^{Noon})$$

Where,

$\bar{\bar{L}}_d^{Noon}$ is the adjusted forecast of measure load

$\overline{SG}^{Noon}$ is the average solar PV generation over the model estimation period

$\widehat{SG}_d^{Noon}$ is the forecast of solar PV generation at Noon on day (d)

Following the example from above, the average solar PV generation over the model estimation period is equal to 50 MW, computed as (50% of the days at 0 MW + 50% of the days at 100 MW). On a sunny day, the forecast of measured load will be equal to the predicted value of 1,250 MW from the model of measured load plus (50 MW – 100 MW), or 1,200 MW. On a cloudy day, the forecast of measured load will be equal to the predicted value of 1,250 MW from the model of measured load plus (50 MW – 0 MW), or 1,300 MW. On a sunny day, this approach lowers the forecast of measured load by 50 MW which is the additional solar generation that occurs on a sunny day versus an average day. Conversely, on a cloudy day, this approach raises the forecast of measured load by an additional 50 MW to account for no solar generation taking place on that day.

These examples illustrate that a statistical model of measured load will capture in the estimated model coefficients the average impact of solar generation. Accordingly, with volatile solar PV generation, the model-based forecast of measured load needs to be adjusted to account for the solar PV generation not already accounted for by the estimated model coefficients. A key objective of this study is to develop a means for improving the short-term load forecast by incorporating forecasts of solar PV generation into the forecast framework. The next section describes three alternative frameworks for incorporating the impact of solar PV generation into a forecast of measured loads. This is followed by a discussion of the simulation framework that was developed to evaluate the potential to improve forecast accuracy by utilizing forecasts of solar PV generation. Findings based on a summary of the simulation results are then presented.

CHAPTER 2: Incorporating the Impact of Solar PV Generation in a Load Forecast

The existing California ISO short-term load forecast models do not include explicit treatment of solar PV generation. As such, the forecasts are subject to the type of forecast bias described above. In particular, the existing California ISO mid-day forecasts tend to be high on sunny days and low on cloudy days. This study developed alternative forecast frameworks that account for the load impact of solar PV generation. The study utilizes forecast simulations to compare the forecast accuracy of the existing California ISO forecast framework against the following three alternative modeling approaches.

- **Error Correction**: The Error Correction approach implements what many System Operators do initially when faced with the problem of solar PV generation. Namely, they make *ex post* adjustments of the load forecast to account for forecasted values of solar PV generation. On sunny days, the adjustment is to lower the load forecast and on cloudy days, the load forecast is adjusted upward. The key advantage of the Error Correction Approach is the existing load forecast model can continue to be used without any changes. All that is needed is a means of forecasting solar PV generation.
- **Reconstituted Loads**: Under the Reconstituted Loads approach the historical time series of measured load is *reconstituted* by adding back estimates of solar PV generation. The load forecast model is then re-estimated against the reconstituted loads. The subsequent reconstituted load forecasts are then adjusted *ex post* by subtracting away forecasts of solar PV generation to form a forecast of measured loads. The advantage of this approach is any inherent bias that might be imposed on the estimated coefficients of a model of measured loads is controlled for by estimating the model coefficients against a time series of demand for power regardless of how it is sourced. The disadvantage is a historical time series of solar PV generation needs to be developed and maintained to estimate the load forecast model coefficients. Further, this approach assumes that the historical solar PV generation time series is accurate. This may not necessarily be true, in which case this approach places too high of a weight on the solar PV generation values.
- **Model Direct:** Under this approach, the weight placed on the solar PV generation data is estimated directly by including these data as an explanatory variable in the load forecast models. The estimated coefficient on the solar PV generation variable is the weight. Also, in principle, by including solar PV generation as an explanatory variable, the coefficients on the remaining explanatory variables should not be biased. This approach also provides a direct forecast of measured loads that accounts for solar PV generation, thus avoiding any *ex post* processing of the load forecast. Like the Reconstituted Load Approach, this approach requires developing and maintaining an historical time series of solar PV generation.

What follows is a description of these three frameworks.

2.1 Error Correction

As described above, the Error Correction approach provides an *ex post* (or after the event) adjustment to an existing load forecast. This framework is described below.

Day-Ahead Error Correction Forecast: The Day-Ahead Error Corrections recognize that the Day-Ahead model coefficients capture the average amount of solar PV generation that existed over the model estimation period. Since the load forecast already reflects a certain level of solar PV generation the *ex post* error correction makes an adjustment based on how much the current solar PV generation differs from the historical average solar PV generation. That is:

Equation 16: Day-Ahead Error Correction Forecast

$$\mathrm{DayAhead\_}\bar{\bar{\mathrm{L}}}_{\mathrm{d,i}}^{\mathrm{Z,T+h}} = \mathrm{DayAhead\_}\hat{\mathrm{L}}_{\mathrm{d,i}}^{\mathrm{Z,T+h}} + \vartheta_{\mathrm{i}}^{\mathrm{Z}}\left[\overline{\mathrm{BTMSG}}_{\mathrm{i}}^{\mathrm{Z}} - \widehat{\mathrm{BTMSG}}_{\mathrm{d,i}}^{\mathrm{Z,T+h}}\right]$$

Where,

> $\mathrm{DayAhead\_}\bar{\bar{\mathrm{L}}}_{\mathrm{d,i}}^{\mathrm{Z,T+h}}$ is the h-step ahead Error Corrected Day-Ahead Measured Load forecast made at time (T)
>
> $\mathrm{DayAhead\_}\hat{\mathrm{L}}_{\mathrm{d,i}}^{\mathrm{Z,T+h}}$ is the h-step-ahead Day-Ahead Model forecast of Measured Load made at time (T)
>
> $\overline{\mathrm{BTMSG}}_{\mathrm{i}}^{\mathrm{Z}}$ is the historical average of Behind-the-Meter Solar Generation for time interval (i)
>
> $\widehat{\mathrm{BTMSG}}_{\mathrm{d,i}}^{\mathrm{Z,T+h}}$ is the h-step ahead forecast of Behind-the-Meter Solar Generation for Zone (Z) time interval (i) made at Time (T)
>
> $\vartheta_{\mathrm{i}}^{\mathrm{Z}}$ is a subjective adjustment weight which has a default value of 1.0 for all Load Zones (Z) and time intervals (i)

In this case, if the forecast of solar PV generation is higher than the historical average, then the Day-Ahead Load Forecast will be adjusted downward. For example, on a clear sunny day, the Day-Ahead Load Forecast will be adjusted downward to account for greater than average solar PV generation. On the other hand, on cloudy days when solar PV generation forecasts are lower than the historical average, the Day-Ahead Load Forecast will be adjusted upwards.

Hour-Ahead Error Correction Forecast: The Hour-Ahead Forecast models are highly autoregressive. In principle, this means a certain amount of solar PV generation is reflected in the Measure Load values that are passed into the models as autoregressive terms. For example, the load forecast made at 11:00 for 11:15 launches off measured loads at 11:00, 10:45, 10:30, 10:15, and 10:00. If it is a sunny day, these measured loads are lower than average due to the higher than average solar PV generation. Conversely, on a cloud day these measured loads are higher than average due to a lower than average solar PV generation. If at 11:15 one expects that the solar PV generation is going to be higher than what it was at 11:00, then one would want to adjust down the Hour-Ahead Forecast. On the other hand, the Hour-Ahead Forecast should be lifted if it is expected that there will be a drop in solar PV generation between 11:00 and 11:15. This suggests the following Error Correction:

Equation 17: Hour-Ahead Error Correction Forecast

$$\mathrm{HourAhead\_}\bar{\bar{\mathrm{L}}}_{\mathrm{d,i}}^{\mathrm{Z,T+h}} = \mathrm{HourAhead\_}\hat{\mathrm{L}}_{\mathrm{d,i}}^{\mathrm{Z,T+h}} + \nabla_{\mathrm{i}}^{\mathrm{Z}}\left[\mathrm{B}\widehat{\mathrm{TMS}}\mathrm{G}_{\mathrm{d,i-1}}^{\mathrm{Z,T+h-1}} - \mathrm{B}\widehat{\mathrm{TMS}}\mathrm{G}_{\mathrm{d,i}}^{\mathrm{Z,T+h}}\right]$$

Where,

$\mathrm{HourAhead\_}\bar{\bar{\mathrm{L}}}_{\mathrm{d,i}}^{\mathrm{Z,T+h}}$ is the h-step-ahead Error Corrected Hour-Ahead Measured Load forecast for Zone (Z) made at time (T)

$\mathrm{HourAhead\_}\hat{\mathrm{L}}_{\mathrm{d,i}}^{\mathrm{Z,T+h}}$ is the h-step-ahead Hour-Ahead Model forecast of Measured Load for Zone (Z) made at time (T)

$\mathrm{B}\widehat{\mathrm{TMS}}\mathrm{G}_{\mathrm{d,i-1}}^{\mathrm{Z,T+h-1}}$ the (h-1) step-ahead forecast of Behind-the-Meter Solar Generation for Zone (Z) made at Time (T)

$\mathrm{B}\widehat{\mathrm{TMS}}\mathrm{G}_{\mathrm{d,i}}^{\mathrm{Z,T+h}}$ is the h-step-ahead forecast of Behind-the-Meter Solar Generation for Zone (Z) made at Time (T)

$\nabla_{\mathrm{i}}^{\mathrm{Z}}$is a subjective adjustment weight that has a default value of 1.0 for all Load Zones (Z) and time intervals (i)

This approach uses the difference of forecasts of solar PV generation to make the error correction because real-time measurement of solar PV generation does not exist. If real-time measurement data become available, then the forecast value $\mathrm{B}\widehat{\mathrm{TMS}}\mathrm{G}_{\mathrm{d,i-1}}^{\mathrm{Z,T+h-1}}$ would be replaced with the measurement value.

For this study, the adjustment weights ($\vartheta_{\mathrm{i}}^{\mathrm{Z}}, \nabla_{\mathrm{i}}^{\mathrm{Z}}$) are assumed fixed at a default value of 1.0. In practice, as forecasters build experience, it is expected that the adjustments weights would be modified to account for the forecaster's confidence in the solar PV generation forecasts, as well as the forecast performance of the adjustments.

Error Corrected Measured Load Forecast: The Error Corrected Measured Load Forecast is then constructed as a weighted average of the Error Corrected Hour-Ahead and Day-Ahead forecasts. Formally,

Equation 18: Error Corrected Load Forecast

$$\mathrm{ErrorCorrection\_Blended\_}\bar{\bar{\mathrm{L}}}_{\mathrm{d,i}}^{\mathrm{Z,T+h}} = \omega_{\mathrm{h}}^{\mathrm{Z}}\mathrm{HourAhead\_}\bar{\bar{\mathrm{L}}}_{\mathrm{d,i}}^{\mathrm{Z,T+h}} + \left(1-\omega_{\mathrm{h}}^{\mathrm{Z}}\right)\mathrm{DayAhead\_}\bar{\bar{\mathrm{L}}}_{\mathrm{d,i}}^{\mathrm{Z,T+h}}$$

The load forecast errors from the Error Correction Model are then computed as:

Equation 19: Error Corrected Load Forecast Errors

$$\mathrm{ErrorCorrection\_e}_{\mathrm{d,i}}^{\mathrm{Z,T+h}} = \mathrm{L}_{\mathrm{d,i}}^{\mathrm{Z}} - \mathrm{ErrorCorrection\_Blended\_}\bar{\bar{\mathrm{L}}}_{\mathrm{d,i}}^{\mathrm{Z,T+h}}$$

Where,

$\text{ErrorCorrection\_e}_{d,i}^{Z,T+h}$ is the Load Forecast Error for Zone (Z) for day (d) and 15-minute time interval (i) from a h-step-ahead forecast made at time (T)

2.2 Reconstituted Loads

Under the Reconstituted Loads approach, the historical time series of measured load is *reconstituted* by adding back estimates of solar PV generation. The load forecast model is then re-estimated against the reconstituted loads. The resulting reconstituted load forecast is then reduced by a forecast of solar PV generation to provide a forecast of measured load. This framework is described below.

Estimates of demand for power regardless of how it is sourced are created by adding estimates of solar PV generation to measured loads. Specifically,

Equation 20: Reconstituted Loads

$$\text{Reconstituted\_L}_{d,i}^{Z} = L_{d,i}^{Z} + \text{BTMSG}_{d,i}^{Z}$$

Where,

$\text{BTMSG}_{d,i}^{Z}$ is the estimated BTM Solar Generation for load zone (Z), on day (d) and time interval (i)

The original California ISO baseline load forecast model is then re-estimated using the Reconstituted Loads as the dependent variable. That is,

Equation 21: Reconstituted Loads Daily Energy Model

$$\text{Reconstituted\_E}_{d}^{Z} = \sum_{n=1}^{N} \emptyset_{n}^{Z} H_{d}^{Z,n} \left(A_{d}^{Z,n} \alpha^{Z,n} \right) + \varepsilon_{d}^{Z}$$

Where,

$\text{Reconstituted\_E}_{d}^{Z}$ is the daily sum of the 96 15-minute reconstituted load values for Load Zo

The load forecasts generated from the Daily Energy Model can be written as follows:

Equation 22: Forecast of Daily Reconstituted Energy

$$\text{Reconstituted\_}\widehat{E}_{d}^{Z} = \sum_{n=1}^{N} \widehat{\emptyset}_{n}^{Z} H_{d}^{Z,n} \left(A_{d}^{Z,n} \widehat{\alpha}^{Z,n} \right)$$

Where,

$\text{Reconstituted\_}\widehat{E}_{d,}^{Z}$ is the forecast of Daily Reconstituted Load for Zone (Z) made at time (T) for forecast day (d)

Day-Ahead Model Specification: The 96, 15-minute level Day-Ahead models can be described generically as:

Equation 23: 96, 15-Minute Level Reconstituted Load Day-Ahead Models

$$\text{Reconstituted\_L}_{d,i}^{Z} = F\left(X_{d,i}^{Z}\beta_{i}^{Z}\right) + u_{d,i}^{Z}$$

Where,

$\text{Reconstituted\_L}_{d,i}^{Z}$ is the reconstituted load for load zone (Z), on day (d), and 15-minute time interval (i).

The load forecasts generated from the Day-Ahead Models can be written as follows:

Equation 24: 96, 15-Minute Level Day-Ahead Reconstituted Load Forecasts

$$\text{DayAhead\_Reconstituted\_}\hat{L}_{d,i}^{Z,T+h} = F\left(X_{d,i}^{Z,T+h}\hat{\beta}_{i}^{Z}\right)$$

Where,

$\text{DayAhead\_Reconstituted\_}\hat{L}_{d,i}^{Z,T+h}$ is the h-step ahead forecast of Reconstituted Load for Zone (Z), forecast day (d) and time interval (i) made at time (T)

Day-Ahead Measured Load Forecast: To recast the forecasts of Reconstituted Loads into forecasts of Measured Loads, the following *ex post* adjustment is made to the Day-Ahead Reconstituted Load forecasts.

Equation 25: 96, 15-Minute Level Day-Ahead Measured Load Forecasts

$$\text{DayAhead\_MeasuredLoad\_}\bar{\bar{L}}_{d,i}^{Z,T+h} = \text{DayAhead\_Reconstituted\_}\hat{L}_{d,i}^{Z,T+h} - \widehat{\text{BTMSG}}_{d,i}^{Z,T+h}$$

Where,

$\text{DayAhead\_MeasuredLoad\_}\bar{\bar{L}}_{d,i}^{Z,T+h}$ is the h-step ahead forecast of Measured Load from the Day Ahead models

$\text{DayAhead\_Reconstituted\_}\hat{L}_{d,i}^{Z,T+h}$ is the h-step-ahead Day-Ahead Model forecast of Reconstituted Load

$\widehat{\text{BTMSG}}_{d,i}^{Z,T+h}$ is the h-step ahead forecast of Behind-the-Meter Solar Generation for Zone (Z) time interval (i) made at Time (T)

Hour-Ahead Model Specification: The 96, Hour-ahead models can be described generically as:

Equation 26: 96, 15-Minute Level Reconstituted Load Hour-Ahead Models

$$\text{Reconstituted\_L}_{d,i}^{Z} = G\left(X_{d,i}^{Z}\delta_{i}^{Z}\right) + \sum_{k=1}^{K}\text{Reconstituted\_L}_{d,i-k}^{Z}\gamma_{k}^{Z} + w_{d,i}^{Z}$$

Where,

$\text{Reconstituted\_L}_{d,i}^{Z}$ is the reconstituted load for load zone (Z), on day (d), and 15-minute time interval (i).

The load forecasts generated from the Hour-Ahead Models can be expressed as follows:

Equation 27: 96, 15-Minute Level Hour-Ahead Reconstituted Load Forecasts

$$\begin{aligned}\mathrm{HourAhead\_Reconstituted\_}\hat{L}_{d,i}^{Z,T+h} &= G\left(X_{d,i}^{Z,T+h}\hat{\delta}_i^Z\right) + \sum_{k=1,T+h-k<T}^{K} \mathrm{Reconstituted\_}L_{d,i-k}^{Z,T+h-k}\hat{\gamma}_k^Z \\ &+ \sum_{k=1,T+h-k>T}^{K} \mathrm{HourAhead\_Reconstituted\_}\hat{L}_{d,i-k}^{Z,T+h-k}\hat{\gamma}_k^Z\end{aligned}$$

Where,

$\mathrm{HourAhead\_Reconstituted\_}\hat{L}_{d,i}^{Z,T+h}$ is the h-step ahead forecast of Reconstituted Load for Zone (Z), forecast day (d) and time interval (i) made at time (T)

$\mathrm{HourAhead\_Reconstituted\_}\hat{L}_{d,i-k}^{Z,T+h-k}$ is the Hour Ahead forecasted Measured Load for Zone (Z), forecast day (d) and time interval (i-k) available at time (T+h)

Hour-Ahead Measured Load Forecast: To recast the forecasts of Reconstituted Loads into forecasts of Measured Loads the following *ex post* adjustment is made to the Hour-Ahead Reconstituted Load forecasts.

Equation 28: 96, 15-Minute Level Hour-Ahead Measured Load Forecasts

$$\mathrm{HourAhead\_MesasuredLoad\_}\bar{\bar{L}}_{d,i}^{Z,T+h} = \mathrm{HourAhead\_Reconstituted\_}\hat{L}_{d,i}^{Z,T+h} - \mathrm{B}\widehat{\mathrm{TMS}}\mathrm{G}_{d,i}^{Z,T+h}$$

Where,

$\mathrm{HourAhead\_MeasuredLoad\_}\bar{\bar{L}}_{d,i}^{Z,T+h}$ is the h-step ahead forecast of Measured Load

$\mathrm{HourAhead\_Reconstituted\_}\hat{L}_{d,i}^{Z,T+h}$ is the h-step-ahead Hour-Ahead Model forecast of Reconstituted Load

$\mathrm{B}\widehat{\mathrm{TMS}}\mathrm{G}_{d,i}^{Z,T+h}$ is the h-step ahead forecast of Behind-the-Meter Solar Generation for Zone (Z) made at Time (T)

Measured Load Forecast from the Reconstituted Load Approach: The Measured Load Forecast is then constructed as a weighted average of the Adjusted Hour-Ahead and Day-Ahead forecasts. Formally,

Equation 29: 96, 15-Minute Level Blended Measured Load Forecasts

$$\begin{aligned}&\mathrm{Reconstituted\_Blended\_}\bar{\bar{L}}_{d,i}^{Z,T+h} \\ &\quad = \omega_h^Z \mathrm{HourAhead\_MeasuredLoad\_}\bar{\bar{L}}_{d,i}^{Z,T+h} + \left(1-\omega_h^Z\right)\mathrm{DayAhead\_MeasuredLoad\_}\bar{\bar{L}}_{d,i}^{Z,T+h}\end{aligned}$$

The load forecast errors from the Reconstituted Load Approach are then computed as:

Equation 30: 96, 15-Minute Level Load Forecast Errors

$$\text{Reconstituted\_}e_{d,i}^{Z,T+h} = L_{d,i}^{Z} - \text{Reconstituted\_Blended\_}\bar{\bar{L}}_{d,i}^{Z,T+h}$$

Where,

$\text{Reconstituted\_}e_{d,i}^{Z,T+h}$ is the Measured Load Forecast Error for Zone (Z) for day (d) and fifteen-minute time interval (i) from a h-step-ahead forecast made at time (T)

2.3 Model Direct

Under this approach, the existing California ISO Baseline Load Forecast models are extended to include explanatory variables that are designed to capture the impact of solar PV generation on measured loads. The model framework is described below.

The revised load forecast model are:

Equation 31: Model Direct Daily Energy Model

$$E_d^Z = \sum_{n=1}^{N} \emptyset_n^Z H_d^{Z,n}\left(S_d^{Z,n} \alpha_?^{Z,n}\right) + \varepsilon_d^Z$$

Where,

E_d^Z is the daily sum of the 96 15-minute measured load values for Load Zone (Z) on Day (d)

N is the number of Nodes in the Hidden Layer of the Neural Network Model. Node 1 (n=1) utilizes a Linear Activation Function. Nodes (2 through 5) utilize a Sigmoid Activation Function.

$\emptyset_n^Z$ is the weight placed on Node (n)

$H_d^{Z,n}\left(S_d^{Z,n} \alpha_?^{Z,n}\right)$ is the nth Node in the Hidden Layer

$S_d^{Z,n}$ is a vector of explanatory variables included on the nth Node in the Hidden Layer which equals the original vector of explanatory variables plus the time series of Behind-the-Meter Solar Generation ($S_d^{Z,n} = A_d^{Z,n}$augmented with $BTMSG_d^Z$)

$\alpha^{Z,n}$ is a vector weights placed on the explanatory variables included on the nth Node in the Hidden Layer

ε_d^Z is the Neural Network model error for Load Zone (Z) on Day (d)

The load forecasts generated from the Daily Energy Model can be written as follows:

Equation 32: Model Direct Daily Energy Forecast

$$\text{ModelDirect\_}\hat{E}_d^Z = \sum_{n=1}^{N} \hat{\emptyset}_n^Z H_d^{Z,n}\left(S_d^{Z,n} \hat{\alpha}^{Z,n}\right)$$

Where,

$ModelDirect\_\hat{E}_{d,}^{Z}$ is the forecast of Daily Measured Load for Zone (Z) made at time (T) for forecast day (d)

Day-Ahead Model Specification: The 96 15-minute level Day-Ahead models can be described generically as:

Equation 33: 96, 15-Minute Level Model Direct Day-Ahead Models

$$L_{d,i}^{Z} = F\left(X_{d,i}^{Z}\beta_{i}^{Z}\right) + \vartheta_{i}^{Z}BTMSG_{d,i}^{Z} + u_{d,i}^{Z}$$

Where,

$L_{d,i}^{Z}$ is the measured load for load zone (Z), on day (d), and 15-minute time interval (i)

$BTMSG_{d,i}^{Z}$ is the estimated Behind-the-Meter Solar Generation for load zone (Z), on day (d) and time interval (i)

ϑ_{i}^{Z} is the model coefficient for the Behind-the-Meter Solar Generation time series

The load forecasts generated from the Day-Ahead Models can be written as follows:

Equation 34: 96, 15-Minute Level Model Direct Day-Ahead Load Forecasts

$$DayAhead\_ModelDirect\_\hat{L}_{d,i}^{Z,T+h} = F\left(X_{d,i}^{Z,T+h}\hat{\beta}_{i}^{Z}\right) + \hat{\vartheta}_{i}^{Z}B\widehat{TMS}G_{d,i}^{Z,T+h}$$

Where,

$DayAhead\_ModelDirect\_\hat{L}_{d,i}^{Z,T+h}$ is the h-step ahead forecast of Measured Load for Zone (Z), forecast day (d) and time interval (i) made at time (T)

$B\widehat{TMS}G_{d,i}^{Z,T+h}$ is the h-step ahead forecast of Behind-the-Meter Solar Generation for Zone (Z), forecast day (d) and time interval (i) made at time (T)

Hour-Ahead Model Specification: The 96 Hour-Ahead models can be described generically as:

Equation 35: 96, 15-Minute Level Model Direct Hour-Ahead Models

$$L_{d,i}^{Z} = G\left(X_{d,i}^{Z}\delta_{i}^{Z}\right) + \nabla_{i}^{Z}\left(BTMSG_{d,i-1}^{Z} - BTMSG_{d,i}^{Z}\right) + \sum_{k=1}^{K} L_{d,i-k}^{Z}\gamma_{k}^{Z} + w_{d,i}^{Z}$$

Where,

$L_{d,i}^{Z}$ is the measured load for load zone (Z), on day (d), and 15-minute time interval (i).

$BTMSG_{d,i}^{Z}$is the estimated Behind-the-Meter Solar Generation for load zone (Z), on day (d) and time interval (i)

$BTMSG_{d,i-1}^{Z}$is the estimated Behind-the-Meter Solar Generation for load zone (Z), on day (d) and time interval (i-1)

∇_{i}^{Z} is the estimated coefficient or weight placed on the 15-minute ramp in Behind-the-Meter Solar Generation

The Hour-Ahead Model mimics the approach utilized in the Error Correction Approach in that the solar PV generation enters into the model as the difference between the current interval and the prior fifteen minute interval value. When cast in this fashion, the revised Hour-Ahead Model provides a means for statistically estimating the weight that should be placed on this difference. That is, the adjustment weight that is judgmentally imposed under the Error Correction Approach is estimated directly under this approach.

The load forecasts generated from the Hour-Ahead Models can be expressed as follows:

Equation 36: 96, 15-Minute Level Model Direct Hour-Ahead Forecasts

$$\begin{aligned}\mathrm{HourAhead\_ModelDirect\_}\hat{L}_{d,i}^{Z,T+h} &= G\left(X_{d,i}^{Z,T+h}\hat{\delta}_i^Z\right) + \nabla_i^Z\left(\widehat{BTMSG}_{d,i-1}^Z - \widehat{BTMSG}_{d,i}^Z\right) + \sum_{k=1,T+h-k<T}^{K} L_{d,i-k}^{Z,T+h-k}\hat{\gamma}_k^Z \\ &+ \sum_{k=1,T+h-k>T}^{K} \mathrm{HourAhead\_ModelDirect\_}\hat{L}_{d,i-k}^{Z,T+h-k}\hat{\gamma}_k^Z\end{aligned}$$

Where,

$\mathrm{HourAhead\_ModelDirect\_}\hat{L}_{d,i}^{Z,T+h}$ is the h-step ahead forecast of Measured Load for Zone (Z), forecast day (d) and time interval (i) made at time (T)

$\mathrm{HourAhead\_ModelDirect\_}\hat{L}_{d,i-k}^{Z,T+h-k}$ is the Hour Ahead forecasted Measured Load for Zone (Z), forecast day (d) and time interval (i-k) available at time (T+h)

Measured Load Forecast from the Direct Model Approach: The Measured Load Forecast is then constructed as a weighted average of the Hour-Ahead and Day-Ahead forecasts.

Formally,

Equation 37: Model Direct Blended Measured Load Forecast

$$\begin{aligned}\mathrm{ModelDirect\_Blended\_}\bar{\bar{L}}_{d,i}^{Z,T+h} &= \omega_h^Z \mathrm{HourAhead\_ModelDirect\_}\bar{\bar{L}}_{d,i}^{Z,T+h} + \left(1-\omega_h^Z\right)\mathrm{DayAhead\_ModelDirect\_}\bar{\bar{L}}_{d,i}^{Z,T+h}\end{aligned}$$

The load forecast errors from the Model Direct are then computed as:

Equation 38: Model Direct Measured Load Forecast Errors

$$\mathrm{ModelDirect\_}e_{d,i}^{Z,T+h} = L_{d,i}^Z - \mathrm{ModelDirect\_Blended\_}\bar{\bar{L}}_{d,i}^{Z,T+h}$$

Where,

$\mathrm{ModelDirect\_}e_{d,i}^{Z,T+h}$ is the Load Forecast Error for Zone (Z) for day (d) and 15-minute time interval (i) from a h-step-ahead forecast made at time (T)

CHAPTER 3:
Solar PV Generation Estimates

This chapter presents the two alternative sources for solar generation that are used to evaluate the forecast performance of the Error Correction, Reconstituted Loads, and Direct Modeling approaches described above. The first source of solar generation data is developed by Clean Power Research (CPR), which has a detailed database of solar installations in the PG&E, SCE, and SDG&E service territories. These detailed data are combined with satellite imagery to construct bottom-up estimates of solar generation by the PG&E Bay Area, PG&E Non-Bay Area, SCE Coastal, SCE Inland and SDG&E load zones. The second source of solar generation mimics what a number of system operators have used as starting point for addressing the impact of solar generation on their loads, which is to leverage the cloud cover data they already collect. Under this approach, the hourly cloud cover data collected by weather stations are combined with estimates of installed capacity to estimate solar generation by load zone. The purpose of developing this second source is to provide a basis for comparison to the forecast improvements that can be expected when the solar generation estimates/forecasts are sourced from a commercial vendor like CPR.

3.1 CPR Solar Generation Estimates

Much of the focus in the area of solar generation forecasting is on developing accurate forecasts of panel-level solar irradiance. The techniques range from vector decomposition of satellite imagery to vector decomposition of location specific cloud cover observations. This analysis is geared for forecasting generation at utility solar installations and/or solar generation over a small geographic footprint. This micro focus is most useful when the exact locations of the solar installations are known. For the case of the California ISO, CPR has combined this micro level approach with a detailed database of solar PV installations to construct a rich time series of non-utility scale solar generation estimates by load zone. These estimates are used to evaluate the forecast performance of the alternative load forecast approaches described above.

The solar capacity and generation data compiled by CPR for this study are summarized in Table 1 and Table 2 below.

- Total solar capacity is estimated to have grown from 653.0 MW at the beginning of 2010 to 4,081.5 MW by June 2015. Maximum solar generation output in June has grown by over a factor of seven, from 369 MWh in 2010 to 2,665 MWh in 2016.

- PG&E accounts for 2,050.7 MW, or about half of the installed capacity in June 2015. Approximately 70% of the PG&E installations have been the Non-Bay Area portion of the service territory. The 2,050.7 MW of installed capacity generated at its maximum an estimated 1,320.8 MWh of electricity.

- SCE accounts for about 38% of the total installed capacity, or 1,556.2 MW. Approximately 57% of this capacity has been installed in the Inland portion of SCE’s service territory. The 1,556.2 MW of installed capacity led to a maximum of 1,028.5 MWh of solar generation.

- SDG&E accounts for 474.6 MW of installed capacity, which is approximately 12% of the total. Maximum solar generation in June has grown from an estimated value of 44.2 MWh in 2010 to 316.0 MWh in 2015, which is a growth of over seven times.

Table 1: Estimated Installed BTM Solar Capacity (MW)

CAISO Total

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2010	653.0	660.4	669.9	681.9	695.9	712.0	729.9	749.9	771.2	794.2	818.6	844.4
2011	872.0	899.5	928.1	958.8	990.6	1,023.4	1,057.2	1,092.6	1,128.3	1,164.8	1,202.2	1,240.5
2012	1,280.2	1,319.5	1,359.5	1,401.0	1,443.3	1,486.4	1,530.4	1,576.0	1,621.7	1,668.4	1,716.0	1,764.6
2013	1,815.0	1,864.1	1,914.2	1,967.3	2,021.6	2,077.2	2,134.3	2,193.8	2,254.0	2,315.8	2,379.4	2,445.0
2014	2,513.6	2,580.9	2,650.3	2,724.3	2,800.8	2,879.9	2,961.7	3,047.7	3,135.5	3,226.4	3,320.6	3,418.3
2015	3,521.4	3,623.1	3,728.6	3,841.8	3,959.4	4,081.5						

PG&E Total

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2010	383.9	389.7	396.5	404.5	413.4	423.1	433.7	445.2	457.3	470.1	483.5	497.6
2011	512.6	527.4	542.7	559.0	575.8	593.1	610.9	629.4	648.0	667.1	686.6	706.4
2012	727.0	747.3	767.9	789.2	811.0	833.1	855.5	878.8	902.0	925.7	949.8	974.3
2013	999.6	1,024.2	1,049.2	1,075.6	1,102.5	1,129.9	1,158.0	1,187.1	1,216.3	1,246.3	1,276.9	1,308.3
2014	1,341.1	1,373.0	1,405.7	1,440.5	1,476.2	1,512.9	1,550.7	1,590.2	1,630.3	1,671.5	1,714.1	1,758.0
2015	1,804.1	1,849.3	1,896.0	1,945.9	1,997.4	2,050.7						

PG&E Bay Area

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2010	130.5	131.4	132.7	134.4	136.6	139.1	142.1	145.4	149.0	152.9	157.2	161.7
2011	166.6	171.5	176.7	182.3	188.1	194.2	200.4	207.0	213.7	220.5	227.6	234.7
2012	242.2	249.6	257.1	264.9	272.8	280.8	288.9	297.3	305.7	314.1	322.7	331.3
2013	340.2	348.7	357.4	366.3	375.4	384.6	393.8	403.2	412.6	422.1	431.6	441.2
2014	451.1	460.6	470.1	480.0	490.1	500.2	510.4	520.9	531.4	541.9	552.6	563.4
2015	574.5	585.2	596.0	607.3	618.8	630.5						

PG&E Non Bay Area

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2010	253.4	258.4	263.9	270.1	276.8	284.0	291.6	299.8	308.3	317.1	326.4	335.9
2011	346.0	355.8	365.9	376.7	387.7	398.9	410.4	422.4	434.4	446.6	459.0	471.7
2012	484.8	497.7	510.8	524.4	538.2	552.3	566.6	581.5	596.4	611.6	627.1	643.0
2013	659.4	675.5	691.9	709.3	727.1	745.4	764.2	783.8	803.7	824.2	845.3	867.1
2014	890.0	912.4	935.6	960.4	986.1	1,012.7	1,040.2	1,069.3	1,098.9	1,129.6	1,161.5	1,194.6
2015	1,229.6	1,264.2	1,300.0	1,338.5	1,378.6	1,420.2						

SCE Total

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2010	195.9	196.2	197.4	199.6	202.7	206.8	211.6	217.4	223.8	230.9	238.7	247.1
2011	256.3	265.6	275.4	286.1	297.3	308.9	321.1	333.8	346.8	360.2	374.0	388.2
2012	403.1	417.8	432.9	448.7	464.8	481.4	498.3	516.0	533.7	552.0	570.6	589.8
2013	609.7	629.2	649.2	670.4	692.2	714.6	737.7	761.9	786.4	811.7	837.8	864.8
2014	893.1	921.0	949.8	980.6	1,012.6	1,045.7	1,080.0	1,116.2	1,153.2	1,191.7	1,231.6	1,273.1
2015	1,316.9	1,360.2	1,405.2	1,453.6	1,503.9	1,556.2						

SCE Coastal

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2010	87.0	86.1	85.9	86.5	87.8	89.7	92.3	95.5	99.1	103.3	107.9	113.0
2011	118.6	124.2	130.2	136.7	143.4	150.5	157.7	165.4	173.1	180.9	189.0	197.2
2012	205.6	213.9	222.3	231.0	239.7	248.5	257.4	266.5	275.5	284.6	293.8	303.0
2013	312.4	321.5	330.6	340.2	349.8	359.5	369.4	379.5	389.7	400.0	410.4	421.1
2014	432.2	442.9	453.9	465.6	477.5	489.8	502.5	515.8	529.3	543.2	557.7	572.6
2015	588.5	604.1	620.3	637.8	656.0	674.9						

SCE Inland

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2010	109.0	110.1	111.4	113.1	114.9	117.0	119.3	121.9	124.6	127.6	130.7	134.1
2011	137.8	141.4	145.3	149.5	153.9	158.5	163.3	168.5	173.8	179.3	185.1	191.1
2012	197.5	203.9	210.6	217.7	225.2	232.9	240.9	249.5	258.2	267.4	276.9	286.8
2013	297.3	307.7	318.5	330.2	342.4	355.1	368.3	382.3	396.7	411.7	427.4	443.7
2014	461.0	478.1	495.9	515.1	535.1	555.9	577.5	600.5	624.0	648.5	673.9	700.4
2015	728.4	756.1	784.9	815.8	847.9	881.3						

SDGE

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2010	73.2	74.5	76.0	77.8	79.8	82.1	84.6	87.3	90.2	93.2	96.4	99.7
2011	103.1	106.5	110.0	113.7	117.5	121.4	125.3	129.3	133.4	137.5	141.6	145.8
2012	150.2	154.4	158.6	163.0	167.5	172.0	176.5	181.2	185.9	190.7	195.6	200.5
2013	205.7	210.7	215.8	221.3	226.9	232.6	238.6	244.8	251.2	257.8	264.7	271.8
2014	279.4	286.9	294.7	303.2	312.0	321.3	331.0	341.3	352.0	363.1	374.9	387.2
2015	400.4	413.6	427.4	442.3	458.1	474.6						

Source: Clean Power Research

Table 2: Estimated Maximum BTM Solar Generation (MWh)

CAISO Total

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2010	273.7	307.6	341.9	363.6	367.7	369.0	376.5	382.4	386.1	381.9	366.4	370.6
2011	394.5	467.3	508.5	551.3	559.0	570.2	584.7	596.7	605.8	605.2	577.7	561.2
2012	620.8	723.8	793.7	858.2	888.7	902.0	907.8	915.6	924.1	907.5	853.8	837.8
2013	943.4	1,077.6	1,190.6	1,273.4	1,306.9	1,315.7	1,323.7	1,350.0	1,341.3	1,341.3	1,240.5	1,190.9
2014	1,303.3	1,513.5	1,693.4	1,831.4	1,860.0	1,891.2	1,895.2	1,915.1	1,911.2	1,904.2	1,774.2	1,712.4
2015	1,844.2	2,181.2	2,442.7	2,606.1	2,646.6	2,665.4						

PG&E Total

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2010	160.4	185.3	208.3	223.6	227.2	227.2	231.5	234.3	234.6	229.3	217.6	216.2
2011	229.7	275.0	303.6	330.7	331.2	335.4	345.8	351.8	353.4	348.7	328.4	313.1
2012	346.0	409.1	442.2	487.4	504.1	511.5	510.7	515.7	518.5	500.7	459.4	448.2
2013	508.9	587.0	646.5	696.2	718.6	719.6	714.8	731.1	723.5	720.0	651.4	621.0
2014	673.3	785.4	872.4	960.9	971.8	980.5	985.0	985.2	977.4	954.2	880.8	844.3
2015	932.5	1,080.0	1,229.6	1,298.9	1,310.9	1,320.8						

PG&E Bay Area

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2010	56.9	66.1	71.7	77.1	78.1	77.3	79.3	79.5	79.0	76.4	71.8	71.3
2011	76.9	89.4	101.9	110.2	112.7	113.6	117.2	120.3	119.7	117.8	108.3	104.5
2012	118.6	139.4	154.5	169.6	177.4	181.0	181.6	181.0	182.8	173.2	161.0	154.8
2013	173.5	203.0	224.8	243.0	252.4	253.7	253.7	256.6	251.1	246.7	223.0	209.5
2014	237.1	266.7	296.7	329.7	331.4	334.1	334.3	334.2	327.5	313.2	287.9	273.7
2015	299.0	343.5	393.3	416.1	421.8	420.9						

PG&E Non Bay Area

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2010	103.5	119.2	136.5	146.4	149.1	149.8	152.2	154.8	155.6	152.9	145.9	144.9
2011	152.8	185.7	201.7	220.5	218.5	221.8	228.5	231.5	233.7	230.9	220.1	208.6
2012	227.3	269.7	287.7	317.8	326.6	330.5	329.1	334.7	335.8	327.4	298.5	293.4
2013	335.4	384.0	421.7	453.2	466.2	466.0	461.2	474.5	472.4	473.4	428.4	411.5
2014	436.1	518.7	575.7	631.2	640.4	646.4	650.7	651.0	649.8	641.0	593.0	570.6
2015	633.5	736.6	836.3	882.8	889.1	900.0						

SCE Total

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2010	80.3	85.9	92.5	97.0	96.9	97.7	99.7	101.6	104.2	104.9	103.1	106.9
2011	114.1	133.5	142.2	154.5	159.8	164.6	168.5	173.0	178.4	181.5	177.6	177.5
2012	195.7	225.5	253.5	269.4	280.4	285.7	290.8	292.7	298.2	300.3	289.8	286.4
2013	322.3	365.1	404.9	431.9	441.4	447.9	457.2	466.2	466.5	466.8	443.5	429.4
2014	475.1	552.1	623.0	665.8	681.1	700.0	697.6	713.6	715.1	730.8	683.1	661.6
2015	687.6	842.5	927.5	1,004.7	1,022.9	1,028.5						

SCE Coastal

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2010	35.7	38.8	40.8	43.3	43.0	43.5	44.9	45.8	47.2	47.9	47.3	50.0
2011	55.2	63.9	69.5	76.2	80.5	84.6	87.1	89.7	93.3	94.9	92.8	92.6
2012	101.7	119.3	137.5	145.7	151.4	155.1	157.9	159.0	160.4	160.8	152.2	149.1
2013	167.9	190.2	213.1	224.6	229.1	232.5	235.5	239.5	237.6	233.4	219.0	209.8
2014	232.3	270.3	306.3	320.5	326.7	333.7	332.1	337.9	336.0	349.4	310.7	296.9
2015	319.8	375.3	414.9	445.3	452.3	454.3						

SCE Inland

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2010	44.6	47.1	51.7	53.7	54.0	54.1	54.8	55.8	56.9	57.0	55.8	56.9
2011	58.9	69.6	72.7	78.3	79.2	79.9	81.4	83.3	85.1	86.7	84.8	84.9
2012	94.0	106.2	116.0	123.7	128.9	130.6	132.9	133.8	137.8	139.5	137.6	137.3
2013	154.4	174.9	191.8	207.2	212.3	215.4	221.7	226.7	229.0	233.4	224.6	219.6
2014	242.7	281.8	316.7	345.3	354.4	366.2	365.5	375.7	379.1	381.4	372.5	364.7
2015	367.8	467.2	512.6	559.4	570.6	574.2						

SDGE

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2010	32.9	36.5	41.1	43.0	43.6	44.2	45.4	46.5	47.3	47.7	45.7	47.5
2011	50.7	58.7	62.8	66.1	68.0	70.3	70.4	71.9	74.0	75.0	71.7	70.6
2012	79.1	89.2	98.0	101.4	104.3	104.8	106.3	107.2	107.4	106.4	104.6	103.2
2013	112.1	125.4	139.1	145.3	147.0	148.2	151.6	152.7	151.3	154.4	145.5	140.5
2014	155.0	176.0	198.1	204.7	207.1	210.8	212.6	216.3	218.8	219.2	210.2	206.5
2015	224.1	258.6	285.7	302.4	312.7	316.0						

Source: Clean Power Research

As illustrated above, increased penetration of solar PV can lead to growing load volatility that in turn will lead to eroding load forecast performance. To put the solar generation data derived by CPR into a load forecasting context, it is useful to consider what fraction of load volatility could be associated with solar generation volatility. Figure 1 presents the ratio of solar generation volatility to load volatility for the total PG&E service territory. Here, solar generation volatility is measured by the standard deviation (stdkwh) of the estimated solar generation output (solargenkwh), gold area in the chart, by time interval. Load volatility is measured by the standard deviation of loads (red area in the chart) by time interval. The ratio of these two volatility measures is given by the green line in the chart. For the case of PG&E. the ratio of solar generation volatility to PG&E load volatility peaks around 10 am at a value of 0.22. This is in stark contrast to SCE (shown in Figure 2), which also peaks mid-morning but at a much lower value of 0.13. As shown in Figure 3, SDG&E has a similar volatility profile as PG&E, with the ratio of solar generation volatility to SDG&E load volatility peaking mid-morning with a value of 0.20. A comparison the ratios for PG&E, SCE, and SDG&E are presented in Figure 4.

From a model perspective, the greater the proportion of load volatility that can be associated with or explained by the volatility of solar generation, the more improvement in model fit that can be expected when adding solar generation as an explanatory variable in a model. To help fix ideas, consider a simple analogy of trying to measure (predict) the height of a lake. If the lake is relatively shallow, accurately predicting the height of the waves is relatively important. In contrast, wave height is noise when considering trying to measure the height of a lake as deep as, say, Lake Tahoe. In load forecasting, the waves are the measured by the volatility of solar generation. The depth of the lake is measured by the load volatility. The smaller the ratio of solar volatility (i.e., the waves) to load volatility (i.e., depth of the lake) the less weight a statistical model will place on the solar generation variables. As a result, it is less likely that adding forecasts of solar generation will improve the load forecast. Conversely, the higher the ratio the more likely there will be forecast performance gains from adding forecasts of solar generation to the model.

The data in Figure 4 suggest that the forecast performance improvements will be less for SCE than for PG&E and SDG&E because of the lower ratio. Further, it is anticipated that there will be bigger performance gains in the mid-morning hours than the afternoon hours. Finally, the forecast gains are expected to be little to none for the dawn and dusk hours when solar generation output is at its lowest values.

Figure 1: Ratio of Solar Generation Volatility to Load Volatility: PG&E Total



In this and subsequent figures,

Stdkwh is the estimated load variability (using the Standard Deviation of Measured Loads in MW)

solargenkwh is the estimated solar PV generation variability (using Standard Deviation of BTM solar PV generation in MW)

Ratio is the ratio of solargenkwh to stdkwh

Figure 2: Ratio of Solar Generation Volatility to Load Volatility: SCE Total



Figure 3: Ratio of Solar Generation Volatility to Load Volatility: SDG&E



Figure 4: Ratio of Solar Generation Volatility to Load Volatility: IOU Comparison



3.2 Cloud Cover Driven Solar Generation Estimates

Unfortunately, not all system operators have access to the detailed installation data that CPR has gathered for the state of California. In many cases, a system operator will have at best good estimates of the total installed capacity by transmission zone and/or possibly by postal code. Further, most system operators only have access to hourly cloud cover data for the weather stations they use to forecast loads. For years, load forecasters have lived by the assumption that hourly weather data for a handful of weather stations was sufficient to produce accurate short-term load forecasts. This begs the question, *is having an estimate of total installed capacity by transmission zone coupled with hourly cloud cover data for a handful of weather stations that span the load zone sufficient to capture the overall impact of solar PV generation on loads?*

To answer this question, an alternative time series of solar PV generation is developed by combining the total installed solar PV capacity estimates by load zone developed by CPR with the hourly cloud cover observations for the weather stations that the California ISO uses to drive their load forecasts. The result is a time series of solar PV generation for the load zones: PG&E, PG&E Bay Area, PG&E Non-Bay Area, SCE, SCE Coastal, SCE Inland, and SDG&E. By comparing the forecast performance of the short-term load forecasts with and without cloud cover driven solar PV generation, the benefit of doing “something” over doing “nothing” can be quantified. Further, a baseline of short-term load forecast performance is established, against which the short-term load forecast using CPR’s detail bottom-up solar PV generation estimates can be evaluated. The remainder of this section describes how hourly cloud cover is combined with solar PV capacity estimates to develop forecasts (estimates) of solar PV generation by load zone.

The approach used to develop cloud cover solar PV generation estimates is necessarily simple given the information available is limited to:

- Total Installed solar PV capacity (MW) by day and load zone, and
- Hourly Cloud Cover in percentage terms by hour, day and weather station.

Given this limited set of data, begin with the following simplified engineering relationship.

Equation 39: Simplified Solar Generation Forecast Model

$$\text{SolarGeneration}_{d,i} = \text{SolarInsolation}_{d,i} \times \text{SolarPanelCapacity}_{d} \times \text{SolarPanelEfficiency}_{d,i}$$

Where,

$\text{SolarGeneration}_{d,i}$ is the electricity generated on day (d) time interval (i) in Watts Out

$\text{SolarInsolation}_{d,i}$ is the solar energy delivered to the panel in $\text{Watts In}/\text{m}^2$

$\text{SolarPanelCapacity}_{d}$ is the installed capacity in m^2

$\text{SolarPanelEfficiency}_{d,i}$ is the solar panel efficiency in $\text{Watts Out}/\text{Watts In}$

To help fix ideas, assume solar insolation at noon of June 12 is 1,000 Watts/m^2, installed BTM solar PV capacity is 2.5 kW, and the BTM solar PV system efficiency (Sunlight to AC) is 15%. If one assumes 150 Watts/m^2 for the average panel size, the solar panel area would be approximately 16.66 m^2 (computed as 2500 Watts over 150 Watts/m^2). With these numbers you have:

Equation 40: Solar Generation Forecast Example

$$\text{SolarGeneration} = 2500 \text{ Watts} = 1000 \,\text{Watts}/\text{m}^2 \times 16.667\text{m}^2 \times 0.15$$

Factoring in Temperature Impacts: The hotter a solar panel becomes, the less efficient it is in converting sun energy into useful electricity. This leads to the following adjustment to the solar panel efficiency.

Equation 41: Temperature Driven Solar Panel Efficiency Equation

$$\text{SolarPanelEfficiency}_{d,i} = \text{RatedEfficiency} \times \left(1 - \left[\text{MAX}\left(\text{Temp}_{d,i} - \text{ThresholdTemp}, 0\right) \times \nabla\right]\right)$$

Where,

$\text{SolarPanelEfficiency}_{d,i}$ is the solar panel operating efficiency for day (d) and time interval (i)

RatedEfficiency is the peak output efficiency

$\text{Temp}_{d,i}$ is the temperature of the panel

ThresholdTemp is the temperature above which the efficiency of the panel degrades

∇ is the rate of efficiency degradation per degree (-0.48% Per °C or $-$ 0.27% Per °F).

Factoring in Cloud Cover: Cloud cover lowers the output of a solar panel by reducing the amount of solar energy (for example solar insolation) reaching the panel. While the exact impact of cloud cover on a particular location is difficult to measure, one can assume that at 100% cloud cover, only about 20% of the solar flux reaches Earth's surface. That is, the cloud albedo is 80% at 100% cloud cover. This information can be used to adjust the engineering estimate of solar insolation by incorporating the following relationship.

Equation 42: Cloud Driven Solar Insolation

$$\text{CloudAlbedo}_{d,i} = \text{CloudCoverPercentage}_{d,i} \times 80\%$$

$$\text{SolarInsolation}_{d,i} = \text{SolarFlux}_{d} \times \text{COS}(\emptyset_d^i) \times (1 - \text{CloudAlbedo}_{d,i})$$

Where,

SolarFlux_d is the amount of solar radiation hitting the Earth's *atmosphere* on any day of the year and is measured in Watts/m^2. Solar Flux equals the Solar Constant Output of 1367 Watts/m^2 adjusted for seasonal variation due to the annual cycle in the distance between Earth and Sun.

$\text{COS}(\emptyset_d^i)$ is the solar zenith angle which is used to adjust the amount of solar energy striking a horizontal plane on Earth's *surface* for any location and time of day

The final engineering model of solar generation can then be written as follows:

Equation 43: Solar Generation Output

$$\text{SolarGeneration}_{d,i} = \text{SolarFlux}_{d,i} \times \text{COS}(\emptyset_d^i) \times (1 - \text{CloudAlbedo}_{d,i}) \times \text{SolarCapacity}_{d,i} \times \\ (1 - [\text{MAX}(\text{Temp}_{d,i} - \text{ThresholdTemp}, 0) \times \nabla])$$

Listed below are the practical steps used to develop the historical time series of solar PV generation by load zone.

Step 1: Construct an Historical Time Series of Solar Insolation. Given the above engineering relationship, how does one predict the amount of solar energy that will reach the surface of a solar panel for any location and time? For this study, the National Oceanic & Atmospheric Administration (NOAA) solar calculation spreadsheet[4] is used to derive estimates of solar

[4] http://www.esrl.noaa.gov/gmd/grad/solcalc/calcdetails.html

insolation by location and day of year for roughly the geographic midpoint (measured as latitude/longitude) for the following load zones: PG&E Bay Area, PG&E Non-Bay Area, SCE Coastal, SCE Inland and SDG&E. This step provides daily estimates of solar insolation at Solar Noon for the period January 1, 2010 through December 31, 2015.

To compute a value of solar insolation for a specific time-of-the-day, one needs to know the Solar Altitude Angle for that time point. Again, information available on the NOAA spreadsheet is used, which gives an estimate of the time of Solar Noon that corresponds to a Solar Altitude Angle of 90 degrees. Estimated sunrise and sunset times are also provided. Since the Solar Altitude Angle at the time of sunrise and sunset is 0 degrees, one can back into the average decay per minute in the Solar Altitude Angle. Specifically:

Equation 44: Computing Solar Altitude Angle

$$\text{Angle Lost Per Minute}_{\text{d}} = {90^{\circ}}/{(\text{Time of Solar Noon}_{\text{d}} - \text{Time of Sun Rise}_{\text{d}})}$$

Typically, the value for the Angle Lost Per Minute will range between 0.2 and 0.31 degrees per minute, with the average value of approximately 0.25 degrees per minute; or about 4 minutes for every degree.

Given this value, the Solar Altitude Angle for any period can be computed as:

Equation 45: Solar Altitude Angle

$$\text{SolarAltitudeAngle}_{\text{d,i}} = \\ 90^{\circ} - (\text{Angle Lost Per Minute}_{\text{d}} \times |\text{Time of Solar Noon}_{\text{d}} - \text{Time of Interval of the day}_{\text{d}}|)$$

Where, the absolute value function returns the number of minutes between the time of Solar Noon and the time of the time interval (i) under study.

Given the Solar Insolation at Solar Noon, the Solar Insolation for time interval (i) can be computed as follows:

Equation 46: Computing Solar Insolation by day and time interval

$$\text{SolarInsolation}_{\text{d,i}} = \text{SolarInsolation}_{\text{d}}^{\text{SolarNoon}} \times \text{COS}(\text{SolarAltitudeAngle}_{\text{d,i}} - 90^{\circ})$$

Applying these equations to the solar insolation data for PG&E Bay Area, PG&E Non-Bay Area, SCE Coastal, SCE Inland, and SDG&E results in 15-minute level solar insolation values for each 15-minute interval from January 1, 2010 through December 31, 2015.

Step 2: Constructing Estimates of Solar PV generation Capacity. For this study, the CPR-developed historical time series of solar installations by load zone are used here to develop the solar PV generation estimates.

Step 3: Cloud Cover Driven Solar PV Generation. Next, hourly cloud cover and temperature values from the weather stations assigned to each load zone are used to derive estimates of solar PV generation that will be used in the load forecasting models. The list of weather stations used by the California ISO and their mapping to the five California ISO load zones are presented in Table 3. A comparison of the Cloud Cover solar generation estimates to the CPR estimates for the week of May 24, 2015 are presented in Figure 5 through Figure 9. In general, the CPR estimates are smoother than the Cloud Cover driven estimates. This reflects the data smoothing inherent in the bottom-up approach implemented by CPR versus the hourly choppiness that comes with hourly cloud cover observations for a small number of weather stations. It is anticipated that the smoother CPR estimates will lead to less volatile measured load forecasts than the cloud-cover driven estimates. If this observation is proven true, then that is a distinct advantage of the CPR approach because adding load forecast uncertainty is not desirable.

Table 3: Mapping of Weather Stations to California ISO Load Zones

Load Zone	Sub Load Zone	Weather Station
PG&E	PG&E Bay Area	Concord
PG&E	PG&E Bay Area	Livermore
PG&E	PG&E Bay Area	Oakland
PG&E	PG&E Bay Area	San Francisco
PG&E	PG&E Bay Area	San Jose
PG&E	PG&E Non Bay Area	Bakersfield
PG&E	PG&E Non Bay Area	Marysville
PG&E	PG&E Non Bay Area	Merced
PG&E	PG&E Non Bay Area	Paso Robles
PG&E	PG&E Non Bay Area	Redding
PG&E	PG&E Non Bay Area	Santa Rosa
SCE	SCE Coast	Fullerton
SCE	SCE Coast	Los Angeles Civic Center
SCE	SCE Coast	March AFB
SCE	SCE Coast	Ontario
SCE	SCE Coast	Van Nuys
SCE	SCE Inland	Daggett
SCE	SCE Inland	Lancaster
SCE	SCE Inland	Palm Springs
SCE	SCE Inland	Riverside Municipal
SDG&E	SDG&E Coast	Lindberg
SDG&E	SDG&E Coast	Oceanside
SDG&E	SDG&E Inland	Miramar
SDG&E	SDG&E Inland	Ramona

Figure 5: CPR versus Cloud Cover (CC) Solar Generation (MWh): PG&E Bay Area



Figure 6: CPR versus Cloud Cover (CC) Solar Generation (MWh): PG&E Non-Bay Area



Figure 7: CPR versus Cloud Cover (CC) Solar Generation (MWh): SCE Coastal



Figure 8: CPR versus Cloud Cover (CC) Solar Generation (MWh): SCE Inland



Figure 9: CPR versus Cloud Cover (CC) Solar Generation (MWh): SDG&E



CHAPTER 4: Forecast Simulations

A key objective of this study is to evaluate the load forecast accuracy improvements that can be expected by incorporating forecasts of solar PV generation into the load forecast framework. To meet this study objective, a series of h-step ahead forecast simulations are computed for each of the four modeling approaches: (a) California ISO Baseline Model, (b) Error Correction, (c) Reconstituted Loads, and (d) Model Direct. The simulation date range is from January 1, 2012 through June 8, 2015.

The process steps in the simulation are:

1. Start at midnight of January 1, 2012,
2. Import Metered Load data through the top of the simulation hour,
3. Import weather data for the forecast horizon,
4. Import solar PV generation estimates for the forecast horizon,
5. Generate a 48-hour ahead forecast of measured loads by Load Zone (PG&E, PG&E Bay Area, PG&E Non-Bay Area, SCE, SCE Coastal, SCE Inland, SDG&E) and Forecast Method (Baseline, Error Correction, Reconstituted, Model Direct),
6. Store to an analysis database the: 15, 30, 45, 60, 90, 120, 180, 240, 300, 360 minute ahead and 24-hour ahead measured load forecasts by Load Zone and Forecast Approach, and
7. Increment to the next hour in the simulation horizon and repeat steps 2 through 7.

The data available to the models at the time of the forecast are:

- Actual 15-Minute level measured loads through the end of the prior hour,
- Hourly observed weather data by weather station for all weather concepts, including: Temperature, Dew Point, Cloud Cover, Wind Speed, and Wind Direction, and
- Estimated (Forecasted) 15-Minute level solar PV generation.

Observed weather conditions are used to eliminate load forecast error driven by weather forecast errors.

Solar PV Generation Forecasts: Two sets of estimated solar PV generation are used in the simulations: (a) cloud cover driven and (b) CPR detailed bottom-up estimates. The use of cloud cover based solar generation estimates mimic the initial approach many system operators have implemented as a first pass at trying to improve their eroding load forecasts. A comparison of the results from the different estimates should demonstrate the benefit of the more detailed approach implemented by CPR.

The list of simulations that were run are presented in Table 4 below.

Table 4: List of Forecast Simulations

Method/Load Zone	Description
Method_1_PGE	Baseline No Behind-the-Meter Solar Generation
Method_1_SCE	Baseline No Behind-the-Meter Solar Generation
Method_1_SDGE	Baseline No Behind-the-Meter Solar Generation
Method_2_PGE	Error Correction: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_2_PGEBayArea	Error Correction: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_2_PGENonBayArea	Error Correction: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_2_SCE	Error Correction: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_2_SCECoastal	Error Correction: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_2_SCEInland	Error Correction: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_2_SDGE	Error Correction: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_3_PGE	Model Direct: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_3_PGEBayArea	Model Direct: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_3_PGENonBayArea	Model Direct: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_3_SCE	Model Direct: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_3_SCECoastal	Model Direct: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_3_SCEInland	Model Direct: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_3_SDGE	Model Direct: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_4_PGE	Reconstituted Loads: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_4_PGEBayArea	Reconstituted Loads: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_4_PGENonBayArea	Reconstituted Loads: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_4_SCE	Reconstituted Loads: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_4_SCECoastal	Reconstituted Loads: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_4_SCEInland	Reconstituted Loads: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_4_SDGE	Reconstituted Loads: Cloud Cover Based Behind-the-Meter Solar Generation Estimates
Method_5_PGE	Error Correction: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_5_PGEBayArea	Error Correction: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_5_PGENonBayArea	Error Correction: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_5_SCE	Error Correction: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_5_SCECoastal	Error Correction: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_5_SCEInland	Error Correction: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_5_SDGE	Error Correction: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_6_PGE	Model Direct: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_6_PGEBayArea	Model Direct: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_6_PGENonBayArea	Model Direct: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_6_SCE	Model Direct: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_6_SCECoastal	Model Direct: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_6_SCEInland	Model Direct: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_6_SDGE	Model Direct: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_7_PGE	Reconstituted Loads: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_7_PGEBayArea	Reconstituted Loads: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_7_PGENonBayArea	Reconstituted Loads: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_7_SCE	Reconstituted Loads: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_7_SCECoastal	Reconstituted Loads: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_7_SCEInland	Reconstituted Loads: Clean Power Research Based Behind-the-Meter Solar Generation Estimates
Method_7_SDGE	Reconstituted Loads: Clean Power Research Based Behind-the-Meter Solar Generation Estimates

4.1 Forecast Performance Measurements

A common metric used to evaluate load forecast performance is the Mean Absolute Percentage Error (MAPE). This metric can be interpreted as the average percentage error in absolute terms that can be expected from a load forecast model. In general, load forecast MAPEs become bigger the longer the forecast horizon. Formally, the MAPE is computed as:

Equation 47: Mean Absolute Percentage Error

$$\mathrm{MAPE}_{h}^{Z,A} = \frac{\sum_{d=1}^{D}\sum_{i=1}^{I}\frac{\left|L_{d,i}^{Z} - F_{h,d,i}^{Z,A}\right|}{L_{d,i}^{Z}} \times 100}{D \times I}$$

Where,

$\mathrm{MAPE}_{h}^{Z,A}$ is the Mean Absolute Percentage Error for Load Zone (Z) for the h-step-ahead load forecast (h) using forecast approach (A)

$L_{d,i}^{Z}$ is measured load for Load Zone (Z), day (d), and time interval (i)

$F_{d,i}^{Z,h,A}$ is the h step ahead forecast of measured load for Load Zone (Z), day (d) and interval (i) use forecast approach (A)

I is the number of non-dark time intervals (i) over which the forecast MAPE is computed

D is the number of days in forecast simulation

To facilitate identifying improvements in forecast performance relative to the baseline forecast the forecast MAPE values are presented as a percentage change relative to the baseline MAPE. Specifically,

Equation 48: Percentage Change in MAPE Relative to the Baseline MAPE

$$\mathrm{PercentMAPEChange}_{h}^{Z,A} = \frac{\left(\mathrm{MAPE}_{h}^{Z,A} - \mathrm{MAPE}_{h}^{Z,\mathrm{Baseline}}\right)}{\mathrm{MAPE}_{h}^{Z,\mathrm{Baseline}}} \times 100$$

In this case, a negative percent change in the forecast MAPE of the alternative approach represents an improvement in forecast performance over the baseline forecast.

A second metric for evaluating forecast accuracy improvements is Forecast Skill. This is a commonly used statistic in renewable energy forecasting studies, which tend to compare the performance of an alternative approach relative to a baseline approach such as a persistence forecast. Forecast Skill metrics also avoid a problem inherent in the use of MAPE for evaluating the forecast performance of solar and wind generation that occurs when the observed generation value run close to zero. Small generation values tend to be associated with large percentage forecast errors not necessarily because there are large absolute forecast errors, but rather the error is divided by a small number.

For this study, Forecast Skill measures the percentage of forecast simulations that the candidate forecast approach produced, a smaller in absolute terms load forecast error than the baseline load forecast. In this case, a forecast approach can be said to lead to an improvement on average in load forecast accuracy if the Forecast Skill is greater than 50% of the time. Formally, Forecast Skill is computed as:

Equation 49: Forecast Skill

$$\text{Skill}_{\text{h}}^{\text{Z,A}} = \frac{\sum_{d=1}^{D}\sum_{\text{i}=1}^{\text{I}}\left(\left|\text{ForecastErrorBaseline}_{\text{d,i}}^{\text{Z,h}}\right| > \left|\text{ForecastErrorApproach}_{\text{d,i}}^{\text{Z,h,A}}\right|\right)}{\text{D} \times \text{I}} \times 100$$

Where,

$\text{Skill}_{\text{h}}^{\text{Z,A}}$ is the percentage of time that the h-step ahead forecast for Load Zone (Z) from the alternative approach (A) was more accurate than the baseline forecast

$\left(\left|\text{ForecastErrorBaseline}_{\text{d,i}}^{\text{Z,h}}\right| > \left|\text{ForecastErrorApproach}_{\text{d,i}}^{\text{Z,h,A}}\right|\right)$ returns a value of 1.0 if the baseline forecast error is greater in absolute value than the forecast error of the alternative model approach, otherwise returns 0.0

These first two metrics focus on the first moment of the forecast error distribution. In addition to reducing forecast errors on average, it is of interest to test whether or not the alternative forecast approaches reduce the overall dispersion of forecast errors. In this case, forecast error dispersion is measured by the Forecast Standard Deviation. Formally, the Forecast Standard Deviation is computed as:

Equation 50: Forecast Standard Deviation

$$\sigma_{\text{h}}^{\text{Z,A}} = \sqrt{\frac{1}{\text{D} \times \text{I}}\sum_{d=1}^{D}\sum_{\text{i}=1}^{\text{I}}\left(\text{L}_{\text{d,i}}^{\text{Z}} - \text{F}_{\text{d,i}}^{\text{Z,h,A}}\right)^2}$$

Where,

$\sigma_{\text{h}}^{\text{Z,A}}$ is the Standard Deviation of the forecast errors for the h-step-ahead load forecast for Load Zone (Z) using load forecast approach (A)

To ease comparisons the change in the Standard Deviation of the forecast errors of each approach relative to the baseline Standard Deviation is constructed as follows:

Equation 51: Percent Change in Forecast Error Volatility

$$\text{PercentStandardDeviationChange}_{\text{h}}^{\text{Z,A}} = \frac{\left(\sigma_{\text{h}}^{\text{Z,A}} - \sigma_{\text{h}}^{\text{Z,Baseline}}\right)}{\sigma_{\text{h}}^{\text{Z,Baseline}}} \times 100$$

In this case, a negative percent change in the forecast Standard Deviation of the alternative approach represents an improvement in forecast performance over the baseline forecast.

Collectively, the team is looking to evaluate whether or not the alternative approaches reduce not only the mean or average forecast error, but also the dispersion of forecast errors.

CHAPTER 5:
Simulation Results Summary

The results of forecast simulations for January 1, 2015 through June 30, 2015 are presented below. This period was selected since it represents the most recent data and the period over which PV installations were at their highest. The results from earlier periods are less applicable to the forecast problem currently faced by the California ISO because the earlier periods had significantly lower penetration of PV relative to 2016 values.

The exhibits present the forecast MAPE, Skill, and Error Standard Deviation by:

- Forecast Horizon
  - 15 Minutes Ahead
  - 30 Minutes Ahead
  - 45 Minutes Ahead
  - 60 Minutes Ahead
  - 90 Minutes Ahead
  - 120 Minutes Ahead (2 Hours Ahead)
  - 180 Minutes Ahead (3 Hours Ahead)
  - 240 Minutes Ahead (4 Hours Ahead)
  - 300 Minutes Ahead (5 Hours Ahead)
  - 360 Minutes Ahead (6 Hours Ahead)
  - 720 Minutes Ahead (12 Hours Ahead)
  - 1440 Minutes Ahead (24 Hours Ahead)
- Forecast Approach
  - Baseline Load Forecast Model with no Behind-the-Meter Solar Generation
  - Error Correction Approach using Cloud Cover driven Solar Generation estimates
  - Model Direct Approach using Cloud Cover driven Solar Generation estimates
  - Reconstituted Loads Approach using Cloud Cover driven Solar Generation estimates
  - Error Correction Approach using CPR’s Solar Generation estimates
  - Model Direct Approach using CPR’s Solar Generation estimates
  - Reconstituted Loads Approach using CPR’s Solar Generation estimates

The results are presented for the following segmentations:

- Load Zones:
    - CAISO Total
    - PG&E Total
    - PG&E Bay Area
    - PG&E Non-Bay Area
    - SCE Total
    - SCE Coastal
    - SCE Inland
    - SDG&E Total
- Seasons:
    - Winter (October through March)
    - Summer (April through September)
- Cloud Cover Conditions
    - Clear: average cloud cover percentage less than 75%
    - Cloudy: average daily cloud cover percentage greater than or equal to 75%

The results are summarized in Figure 10 through Figure 49. On each figure, values that represent an improvement over the baseline load forecast are highlighted in green.

5.1 CAISO Total Simulation Results

Figure 10 through Figure 14 presents the results for the California ISO total (i.e., the sum of the PG&E, SCE, and SDG&E zone loads) across all seasons, and cloud cover conditions.

- **Improvement over Baseline:** A mix or 'ensemble' of the different approaches can result in a reduction in forecast accuracy. Although these improvements are largely in the single (relative) percentage points, the improvements still have measurable potential savings to California of approximately $2 Million per year. [5]
- **Forecast Horizons of 15 Minutes Ahead to Four Hours Ahead**: For forecast horizons of up to four hours ahead, the Model Direct approach consistently outperformed the baseline load forecast model with both a reduced MAPE and smaller dispersion of

[5] Based on an average annual California ISO load of 26 GW and an average regulation cost of $9/MWh per MacDonald e. al 'Demand Response Providing Ancillary Services A Comparison of Opportunities and Challenges in the US Wholesale Markets', Grid-Interop Forum 2012

forecast errors. Further, the Model Direct approach performed better than the baseline forecast when using both Cloud Cover driven and CPR computed solar generation estimates. However, the Model Direct approach when combined with the CPR solar generation estimates outperformed the same approach combined with the Cloud Cover driven solar generation estimates.

- **Forecast Horizons of Five Hours Ahead to Six Hours Ahead**: For forecast horizons of five hours ahead to six hours ahead, the results are mixed between the Model Direct combined with CPR solar generation estimates and the Reconstituted Loads approach combined with CPR solar generation estimates. Using Forecast Skill as a metric, the Reconstituted Loads approach outperformed the baseline forecast. However, the forecast error dispersion grew with this approach.
- **Forecast Horizons of 12 Hours Ahead to 24 Hours Ahead**: For longer-term forecast horizons of 12 hours ahead to 24 hours ahead, the Reconstituted Load approach combined with CPR solar generation estimates significantly reduced both the forecast MAPE and error dispersion. Over this same forecast horizon, the Error Correction approach combined with either Cloud Cover driven or the CPR solar generations estimates outperformed the baseline load forecast. This suggests that imposing an *a priori* weight of -1.0 on the solar generation estimates works well for these longer forecast horizons.
- **Seasonal Differences:** The conclusions do not change substantially when the forecast results are segmented between winter and summer seasons. The Model Direct approach utilizing the CPR solar generation estimates improves the load forecast performance for forecast horizons of 15 minutes ahead to five hours ahead. For longer forecast horizons, the Reconstituted Load approach out performs the baseline load forecast. The main difference between the seasonal results and the overall results is the Model Direct approach using Cloud Cover driven solar generation estimates only perform well during the summer season while this approach performed will for forecast horizons from 15 minutes ahead to four hours ahead over the winter season.
- **Cloud Cover:** The alternative approaches appear to work best under varying cloud conditions. Most notably, the forecast error dispersion is reduced across most forecast horizons under the Model Direct and Reconstituted Load approach when combined with the CPR solar generation estimates.

Figure 10: California ISO Total, All Seasons, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	12.91%	-0.55%	28.94%	9.56%	-1.23%	1.94%
30	7.71%	-0.57%	22.15%	5.30%	-1.79%	1.22%
45	15.08%	-0.43%	19.28%	17.15%	-2.47%	1.33%
60	16.06%	-0.48%	21.89%	2.31%	-2.93%	1.17%
90	2.17%	-0.40%	15.85%	1.96%	-3.41%	-0.34%
120	7.71%	-0.26%	15.78%	1.73%	-3.89%	-0.29%
180	4.81%	-0.42%	12.14%	1.76%	-4.55%	-1.11%
240	3.20%	-0.38%	9.07%	1.40%	-4.03%	-2.02%
300	1.07%	1.04%	13.44%	-0.48%	-1.51%	2.40%
360	-0.18%	2.83%	13.40%	-2.16%	0.99%	2.08%
720	-0.08%	5.39%	4.80%	-3.65%	4.56%	-6.44%
1440	-0.36%	4.93%	4.05%	-3.89%	4.07%	-5.92%

Forecast Skill (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	36.6%	51.3%	40.3%	37.8%	52.0%	48.5%
30	38.9%	51.4%	40.9%	40.1%	52.6%	49.2%
45	39.7%	51.6%	41.2%	40.3%	53.4%	49.4%
60	39.7%	51.5%	41.4%	43.3%	53.8%	49.6%
90	42.5%	51.2%	42.4%	42.6%	53.7%	50.4%
120	42.1%	50.6%	42.6%	43.4%	54.0%	50.4%
180	43.4%	50.8%	43.9%	43.7%	54.7%	50.8%
240	46.0%	50.2%	44.7%	46.1%	53.3%	51.3%
300	47.8%	48.6%	44.3%	48.9%	50.7%	51.0%
360	47.7%	47.2%	44.1%	49.7%	48.8%	50.9%
720	44.5%	46.0%	47.6%	47.5%	46.6%	54.3%
1440	44.6%	46.4%	48.0%	47.5%	47.1%	54.4%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	7.2%	-0.3%	19.6%	4.5%	-0.7%	0.1%
30	5.1%	-0.3%	14.6%	3.2%	-0.9%	0.2%
45	15.5%	-0.2%	12.9%	16.9%	-1.2%	0.6%
60	12.1%	-0.2%	16.0%	1.4%	-1.6%	0.7%
90	1.6%	-0.2%	10.9%	1.2%	-1.8%	-0.2%
120	5.6%	-0.1%	11.7%	0.8%	-2.2%	0.0%
180	3.4%	-0.2%	9.2%	0.9%	-2.5%	-0.2%
240	2.6%	-0.1%	6.7%	1.0%	-2.0%	-1.0%
300	1.1%	0.9%	9.2%	-0.3%	-0.3%	2.0%
360	-0.5%	1.8%	8.1%	-2.1%	1.1%	1.0%
720	-3.1%	3.1%	-0.6%	-5.1%	2.8%	-7.6%
1440	-3.3%	2.9%	-0.7%	-5.3%	2.7%	-7.1%

Figure 11: California ISO Total, Winter, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	12.86%	-0.88%	22.71%	10.41%	-1.60%	2.28%
30	8.57%	-1.13%	17.36%	6.78%	-2.42%	1.04%
45	7.56%	-1.30%	15.44%	6.44%	-3.12%	0.98%
60	13.17%	-1.07%	16.37%	3.25%	-3.87%	0.51%
90	3.35%	-1.05%	11.88%	2.91%	-4.22%	-0.94%
120	6.57%	-0.91%	11.33%	2.27%	-4.91%	-1.16%
180	4.73%	-1.15%	8.40%	2.09%	-5.69%	-1.97%
240	2.96%	-1.04%	7.12%	1.31%	-5.39%	-2.83%
300	0.71%	0.53%	14.94%	-0.48%	-2.77%	3.17%
360	-0.03%	2.45%	16.62%	-1.48%	0.05%	3.86%
720	1.40%	4.89%	8.54%	-1.62%	4.03%	-3.72%
1440	0.94%	4.32%	7.67%	-1.84%	3.45%	-3.47%

Forecast Skill (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	33.6%	52.2%	41.6%	35.1%	52.4%	48.4%
30	35.1%	52.4%	42.3%	36.5%	52.9%	49.8%
45	36.6%	53.0%	42.3%	37.9%	53.8%	50.2%
60	36.7%	52.9%	43.1%	39.8%	54.9%	50.8%
90	38.4%	52.4%	43.9%	39.0%	54.3%	51.1%
120	39.3%	51.6%	44.8%	40.0%	54.3%	51.1%
180	40.8%	52.4%	45.9%	40.9%	55.2%	51.5%
240	44.4%	51.7%	45.8%	44.9%	54.4%	51.8%
300	46.2%	50.2%	43.7%	47.3%	52.2%	50.4%
360	46.3%	48.9%	42.1%	47.4%	50.4%	49.4%
720	42.1%	47.7%	44.7%	43.5%	48.0%	53.0%
1440	42.2%	48.2%	45.2%	43.4%	48.5%	53.1%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	8.0%	-0.7%	17.7%	5.7%	-1.1%	0.9%
30	6.3%	-0.9%	13.0%	4.7%	-1.5%	0.3%
45	5.6%	-1.0%	11.2%	4.3%	-1.9%	0.6%
60	10.3%	-0.7%	12.3%	2.5%	-2.2%	0.7%
90	2.7%	-0.6%	9.1%	2.1%	-2.6%	-0.4%
120	5.6%	-0.5%	9.1%	1.8%	-3.2%	-0.1%
180	4.2%	-0.7%	6.9%	1.7%	-3.8%	-0.8%
240	3.0%	-0.9%	5.6%	1.3%	-3.7%	-1.9%
300	1.2%	-0.1%	12.4%	-0.1%	-2.0%	2.9%
360	-0.1%	0.8%	12.4%	-1.4%	-0.5%	2.2%
720	-1.3%	2.0%	2.8%	-3.1%	1.5%	-7.3%
1440	-1.6%	1.8%	2.6%	-3.2%	1.3%	-6.9%

Figure 12: California ISO Total, Summer, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon Minutes Ahead	Behind-the-Meter Solar Generation Source: Cloud Cover Error Correction	Model Direct	Reconstituted Loads	Behind-the-Meter Solar Generation Source: Clean Power Research Error Correction	Model Direct	Reconstituted Loads
15	12.96%	-0.21%	35.28%	8.70%	-0.85%	1.58%
30	6.84%	0.00%	27.03%	3.78%	-1.15%	1.42%
45	22.86%	0.48%	23.27%	28.25%	-1.79%	1.70%
60	19.09%	0.13%	27.66%	1.32%	-1.94%	1.87%
90	0.97%	0.25%	19.86%	0.99%	-2.60%	0.26%
120	8.87%	0.39%	20.28%	1.19%	-2.87%	0.59%
180	4.90%	0.31%	15.83%	1.43%	-3.42%	-0.27%
240	3.43%	0.26%	10.96%	1.48%	-2.71%	-1.23%
300	1.44%	1.54%	11.95%	-0.49%	-0.26%	1.64%
360	-0.32%	3.22%	10.14%	-2.85%	1.94%	0.29%
720	-1.63%	5.91%	0.86%	-5.81%	5.11%	-9.30%
1440	-1.71%	5.58%	0.28%	-6.03%	4.72%	-8.47%

Forecast Skill (%)

Forecast Horizon Minutes Ahead	Behind-the-Meter Solar Generation Source: Cloud Cover Error Correction	Model Direct	Reconstituted Loads	Behind-the-Meter Solar Generation Source: Clean Power Research Error Correction	Model Direct	Reconstituted Loads
15	39.5%	50.3%	39.0%	40.5%	51.5%	48.6%
30	42.7%	50.3%	39.5%	43.6%	52.4%	48.6%
45	42.8%	50.3%	40.2%	42.7%	53.0%	48.6%
60	42.5%	50.2%	39.8%	46.7%	52.8%	48.5%
90	46.6%	50.1%	41.1%	46.2%	53.0%	49.8%
120	44.8%	49.7%	40.5%	46.8%	53.7%	49.7%
180	46.0%	49.2%	42.0%	46.5%	54.1%	50.1%
240	47.5%	48.8%	43.6%	47.2%	52.1%	50.7%
300	49.3%	47.1%	44.9%	50.4%	49.2%	51.5%
360	49.1%	45.5%	46.1%	51.9%	47.2%	52.3%
720	46.8%	44.4%	50.4%	51.5%	45.2%	55.7%
1440	46.9%	44.7%	50.8%	51.4%	45.7%	55.7%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon Minutes Ahead	Behind-the-Meter Solar Generation Source: Cloud Cover Error Correction	Model Direct	Reconstituted Loads	Behind-the-Meter Solar Generation Source: Clean Power Research Error Correction	Model Direct	Reconstituted Loads
15	6.6%	-0.1%	20.9%	3.6%	-0.5%	-0.5%
30	4.2%	0.1%	15.6%	2.1%	-0.4%	0.2%
45	22.7%	0.3%	14.2%	25.8%	-0.7%	0.6%
60	13.4%	0.1%	18.8%	0.4%	-1.0%	0.6%
90	0.8%	0.1%	12.2%	0.5%	-1.2%	-0.1%
120	5.4%	0.1%	13.2%	0.1%	-1.5%	0.1%
180	2.8%	0.0%	10.2%	0.4%	-1.6%	0.1%
240	2.3%	0.3%	6.9%	0.8%	-0.9%	-0.6%
300	1.1%	1.4%	6.7%	-0.4%	0.8%	1.1%
360	-0.8%	2.4%	4.7%	-2.5%	2.2%	-0.1%
720	-4.7%	3.9%	-3.6%	-6.9%	3.9%	-8.1%
1440	-4.8%	3.9%	-3.6%	-7.1%	3.8%	-7.4%

Figure 13: California ISO Total, All Seasons, Clear

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	15.39%	-0.64%	24.02%	10.27%	-1.05%	1.71%
30	8.90%	-0.63%	18.93%	5.40%	-1.37%	1.24%
45	17.28%	-0.45%	16.74%	18.54%	-1.84%	1.31%
60	14.15%	-0.48%	20.02%	1.73%	-2.17%	1.53%
90	1.76%	-0.25%	14.63%	1.32%	-2.66%	0.38%
120	6.29%	-0.11%	15.16%	1.04%	-3.01%	0.71%
180	3.55%	-0.16%	11.84%	1.14%	-3.65%	0.28%
240	2.12%	-0.21%	9.02%	1.07%	-3.26%	-0.55%
300	0.27%	1.15%	13.32%	-0.54%	-0.98%	3.39%
360	-1.00%	2.91%	12.90%	-2.09%	1.42%	2.35%
720	-1.16%	5.54%	3.94%	-3.86%	4.92%	-7.03%
1440	-1.52%	5.02%	3.09%	-4.08%	4.39%	-6.54%

Forecast Skill (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	36.1%	51.2%	41.1%	38.0%	51.6%	48.7%
30	39.1%	50.9%	41.6%	40.8%	52.2%	49.2%
45	40.1%	51.4%	41.8%	41.2%	52.7%	49.4%
60	41.0%	51.3%	41.9%	44.7%	53.1%	49.4%
90	44.1%	50.3%	42.8%	44.5%	52.9%	50.0%
120	43.7%	49.9%	42.6%	45.2%	53.4%	49.8%
180	45.2%	50.2%	43.9%	45.6%	54.1%	50.1%
240	47.1%	49.7%	44.4%	47.2%	52.8%	50.4%
300	48.4%	48.6%	44.5%	49.3%	50.4%	50.5%
360	48.0%	47.3%	44.8%	49.7%	48.6%	51.0%
720	44.4%	46.4%	48.4%	47.3%	46.6%	54.7%
1440	44.5%	46.7%	48.9%	47.2%	47.1%	54.8%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	8.3%	-0.3%	15.3%	4.8%	-0.7%	0.1%
30	5.8%	-0.4%	11.9%	3.3%	-0.7%	0.4%
45	18.2%	-0.2%	10.8%	19.2%	-0.9%	0.8%
60	10.1%	-0.2%	14.3%	1.2%	-1.1%	1.1%
90	1.4%	-0.1%	9.9%	0.8%	-1.3%	0.5%
120	3.9%	0.0%	10.5%	0.3%	-1.7%	1.0%
180	2.0%	-0.1%	8.3%	0.4%	-2.0%	0.9%
240	1.5%	0.1%	6.4%	0.7%	-1.4%	0.2%
300	0.3%	1.3%	9.2%	-0.4%	0.4%	2.9%
360	-1.1%	2.5%	8.1%	-2.1%	1.9%	1.8%
720	-3.6%	4.1%	-0.9%	-5.3%	3.9%	-7.0%
1440	-3.9%	3.9%	-1.0%	-5.4%	3.7%	-6.6%

Figure 14: California ISO Total, All Seasons, Cloudy

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	6.74%	-0.31%	41.19%	7.80%	-1.67%	2.50%
30	4.82%	-0.43%	29.97%	5.07%	-2.81%	1.19%
45	9.68%	-0.37%	25.51%	13.74%	-4.01%	1.40%
60	20.75%	-0.48%	26.46%	3.72%	-4.78%	0.31%
90	3.17%	-0.77%	18.84%	3.52%	-5.26%	-2.12%
120	11.24%	-0.64%	17.34%	3.45%	-6.09%	-2.78%
180	7.98%	-1.07%	12.91%	3.31%	-6.79%	-4.61%
240	5.96%	-0.82%	9.20%	2.23%	-5.98%	-5.75%
300	3.12%	0.77%	13.73%	-0.35%	-2.87%	-0.13%
360	1.91%	2.62%	14.67%	-2.34%	-0.09%	1.39%
720	2.68%	5.00%	6.99%	-3.14%	3.63%	-4.93%
1440	2.55%	4.71%	6.46%	-3.43%	3.28%	-4.37%

Forecast Skill (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	38.0%	51.5%	37.9%	37.2%	52.9%	48.2%
30	38.6%	52.6%	38.9%	38.1%	53.8%	49.2%
45	38.6%	52.4%	39.6%	37.9%	55.2%	49.6%
60	35.9%	52.1%	40.1%	39.6%	55.7%	50.4%
90	38.2%	53.5%	41.6%	37.7%	55.6%	51.5%
120	37.6%	52.6%	42.9%	38.6%	55.5%	52.0%
180	38.8%	52.5%	44.1%	38.7%	56.3%	52.6%
240	42.7%	51.6%	45.6%	43.2%	54.5%	53.6%
300	46.2%	48.8%	43.5%	47.6%	51.3%	52.3%
360	47.1%	46.9%	42.5%	49.6%	49.2%	50.4%
720	44.8%	45.0%	45.3%	48.2%	46.5%	53.4%
1440	44.9%	45.5%	45.7%	48.3%	47.0%	53.3%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	4.0%	-0.3%	30.5%	3.6%	-0.9%	0.2%
30	3.2%	-0.3%	20.5%	2.9%	-1.2%	-0.2%
45	8.2%	-0.4%	17.9%	10.6%	-2.2%	0.1%
60	16.6%	-0.5%	19.2%	2.0%	-2.7%	-0.4%
90	2.3%	-0.6%	12.7%	2.1%	-3.1%	-2.1%
120	10.2%	-0.7%	13.3%	2.2%	-4.2%	-2.7%
180	7.4%	-0.9%	10.1%	2.3%	-4.5%	-3.5%
240	5.8%	-1.0%	6.3%	2.1%	-3.9%	-4.7%
300	3.2%	-0.3%	9.0%	0.2%	-2.2%	-0.8%
360	0.9%	0.2%	8.3%	-1.7%	-1.0%	-1.1%
720	-2.3%	0.8%	0.2%	-4.5%	0.4%	-8.9%
1440	-2.5%	0.8%	0.2%	-4.8%	0.4%	-8.2%

5.2 PG&E Total Simulation Results

Figure 15 through Figure 19 presents the results for PG&E total across all seasons, and cloud cover conditions.

- **Forecast Horizons of 15 Minutes Ahead to Four Hours Ahead**: For forecast horizons of up to four hours ahead, the Model Direct approach consistently outperformed the baseline load forecast model with both a reduced MAPE and smaller dispersion of forecast errors. Further, the Model Direct approach performed better than the baseline forecast when using both Cloud Cover driven and CPR computed solar generation estimates. However, the Model Direct approach when combined with the CPR solar generation estimates outperformed the same approach combined with the Cloud Cover driven solar generation estimates.
- **Forecast Horizons of Five Hours Ahead to Six Hours Ahead**: For forecast horizons of five hours ahead to six hours ahead, the Error Correction approach combined with CPR solar generation estimates outperformed all other approaches.
- **Forecast Horizons of 12 Hours Ahead to 24 Hours Ahead**: For longer-term forecast horizons of 12 hours ahead to 24 hours ahead, the baseline model forecasts were on average more accurate, but the Error Correction approach combined with the CPR solar generation estimates led to a tighter distribution of forecast errors.
- **Seasonal Differences:** The conclusions do not change substantially when the forecast results are segmented between winter and summer seasons. The Model Direct approach utilizing the CPR solar generation estimates improves the load forecast performance for forecast horizons of 15 minutes ahead to five hours ahead. For longer forecast horizons the Reconstituted Load approach out performs the baseline load forecast. The main difference between the seasonal results and the overall results is the Model Direct approach using Cloud Cover driven solar generation estimates only perform well during the summer season while this approach performed will for forecast horizons from 15 minutes ahead to four hours ahead over the winter season.
- **Cloud Cover:** The alternative approaches appear to work best under varying cloud conditions. Most notably, the forecast error dispersion is reduced across most forecast horizons under the Model Direct and Reconstituted Load approach when combined with the CPR solar generation estimates.

Figure 15: PG&E Total, All Seasons, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	15.42%	-1.09%	24.14%	10.58%	-2.19%	1.63%
30	9.72%	-1.27%	18.98%	6.06%	-2.61%	1.32%
45	16.41%	-1.14%	16.84%	17.63%	-3.07%	1.44%
60	15.46%	-1.20%	19.68%	2.04%	-3.54%	1.27%
90	1.74%	-1.62%	13.79%	1.07%	-4.41%	-0.35%
120	7.34%	-1.48%	14.19%	0.87%	-4.84%	-0.58%
180	4.66%	-2.01%	11.00%	0.61%	-5.77%	-2.13%
240	2.18%	-1.17%	8.74%	-0.32%	-4.65%	-2.83%
300	0.78%	2.92%	15.91%	-1.41%	0.54%	4.75%
360	1.21%	7.55%	18.37%	-1.51%	5.81%	7.21%
720	5.16%	14.92%	15.54%	0.36%	13.90%	3.23%
1440	4.82%	13.73%	14.54%	0.19%	12.71%	2.74%

Forecast Skill (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	35.0%	51.9%	42.7%	36.5%	52.7%	49.0%
30	37.0%	52.3%	42.8%	38.9%	53.7%	49.7%
45	38.0%	52.8%	43.0%	38.2%	54.3%	49.7%
60	38.2%	52.8%	42.8%	42.3%	54.2%	49.7%
90	42.1%	53.6%	44.1%	42.9%	55.0%	50.4%
120	41.1%	52.6%	43.8%	43.8%	54.8%	50.6%
180	43.1%	53.5%	44.9%	44.9%	55.9%	51.5%
240	46.7%	51.1%	45.4%	48.6%	53.9%	51.6%
300	47.6%	46.6%	42.6%	50.3%	47.9%	49.2%
360	45.9%	43.0%	40.8%	49.6%	44.2%	47.5%
720	38.9%	40.0%	40.3%	43.2%	40.6%	49.4%
1440	39.0%	40.7%	40.8%	43.2%	41.3%	49.9%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	11.8%	-0.9%	21.5%	7.0%	-2.1%	0.2%
30	7.4%	-1.1%	14.9%	4.1%	-2.3%	-0.1%
45	23.8%	-0.8%	12.9%	25.1%	-2.5%	0.3%
60	13.6%	-0.8%	16.1%	1.7%	-2.9%	0.0%
90	1.5%	-1.3%	10.6%	0.6%	-3.7%	-1.3%
120	5.9%	-1.2%	10.9%	0.3%	-4.1%	-1.2%
180	3.4%	-1.6%	8.2%	0.1%	-4.6%	-2.2%
240	1.7%	-1.3%	6.1%	-0.4%	-3.9%	-2.7%
300	1.0%	0.9%	11.1%	-1.0%	-1.1%	3.0%
360	1.4%	3.3%	12.3%	-1.1%	1.7%	4.6%
720	3.9%	7.7%	8.2%	-0.2%	6.8%	0.3%
1440	3.7%	7.2%	7.8%	-0.3%	6.3%	0.0%

Figure 16: PG&E Total, Winter, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	13.68%	-1.44%	20.26%	10.60%	-2.57%	1.85%
30	9.82%	-1.45%	16.36%	7.30%	-3.18%	1.41%
45	7.16%	-1.43%	14.87%	5.78%	-3.54%	1.59%
60	12.57%	-1.38%	15.87%	3.09%	-4.27%	0.58%
90	2.97%	-1.87%	10.98%	2.11%	-5.29%	-0.99%
120	6.05%	-1.60%	11.22%	1.47%	-5.61%	-1.59%
180	4.25%	-2.14%	7.93%	1.16%	-6.76%	-3.35%
240	1.46%	-0.76%	7.05%	-0.52%	-5.66%	-3.69%
300	-0.30%	3.65%	16.95%	-2.17%	-0.41%	5.94%
360	0.31%	7.88%	20.04%	-2.11%	4.71%	8.96%
720	4.83%	13.45%	14.17%	0.58%	11.90%	3.56%
1440	4.23%	11.90%	12.91%	0.38%	10.32%	2.84%

Forecast Skill (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	30.9%	52.8%	43.7%	32.4%	53.4%	49.6%
30	31.9%	53.1%	43.5%	33.8%	53.7%	50.5%
45	32.7%	53.6%	43.6%	34.2%	54.2%	50.3%
60	34.1%	53.7%	44.1%	36.8%	54.7%	51.1%
90	36.3%	54.4%	45.6%	37.5%	54.9%	52.1%
120	37.5%	52.8%	45.5%	38.5%	54.2%	51.9%
180	39.7%	53.6%	47.0%	40.1%	55.5%	52.6%
240	45.3%	50.0%	46.2%	47.0%	53.8%	52.4%
300	45.6%	44.9%	41.9%	48.6%	48.8%	48.6%
360	44.2%	41.8%	38.3%	46.9%	44.7%	46.2%
720	35.5%	39.6%	36.7%	37.6%	40.8%	48.6%
1440	35.3%	40.6%	37.3%	37.4%	41.9%	49.2%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	10.8%	-1.2%	19.6%	7.5%	-2.4%	0.5%
30	8.6%	-1.4%	14.7%	5.8%	-3.0%	0.1%
45	6.8%	-1.2%	12.3%	5.4%	-3.2%	0.3%
60	12.0%	-1.0%	13.5%	3.3%	-3.4%	-0.1%
90	3.1%	-1.5%	9.3%	2.0%	-4.5%	-1.5%
120	6.0%	-1.4%	9.1%	1.7%	-4.9%	-1.6%
180	3.9%	-1.9%	6.0%	1.2%	-5.8%	-3.2%
240	1.6%	-1.6%	4.2%	-0.3%	-5.6%	-4.4%
300	0.0%	0.2%	11.3%	-1.9%	-3.0%	2.8%
360	0.2%	1.8%	12.2%	-2.1%	-0.8%	3.6%
720	2.6%	4.4%	4.7%	-0.7%	3.0%	-3.8%
1440	2.2%	3.8%	4.4%	-0.9%	2.4%	-4.1%

Figure 17: PG&E Total, Summer, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	17.33%	-0.71%	28.43%	10.55%	-1.77%	1.39%
30	9.60%	-1.08%	21.88%	4.68%	-1.97%	1.22%
45	26.78%	-0.82%	19.06%	30.93%	-2.54%	1.27%
60	18.81%	-1.00%	24.09%	0.82%	-2.70%	2.07%
90	0.36%	-1.34%	16.95%	-0.10%	-3.42%	0.36%
120	8.81%	-1.35%	17.55%	0.19%	-3.97%	0.56%
180	5.11%	-1.87%	14.39%	0.00%	-4.68%	-0.77%
240	2.98%	-1.61%	10.62%	-0.10%	-3.53%	-1.87%
300	2.09%	2.04%	14.65%	-0.49%	1.69%	3.30%
360	2.38%	7.13%	16.20%	-0.72%	7.25%	4.93%
720	5.65%	17.08%	17.57%	0.03%	16.84%	2.75%
1440	5.69%	16.43%	16.93%	-0.10%	16.21%	2.58%

Forecast Skill (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	39.0%	51.1%	41.6%	40.6%	52.1%	48.4%
30	42.0%	51.6%	42.1%	43.8%	53.8%	48.9%
45	43.2%	52.0%	42.3%	42.2%	54.4%	49.1%
60	42.1%	51.9%	41.6%	47.8%	53.6%	48.3%
90	47.8%	52.7%	42.7%	48.3%	55.1%	48.8%
120	44.7%	52.4%	42.2%	48.9%	55.4%	49.4%
180	46.4%	53.4%	42.9%	49.6%	56.3%	50.5%
240	48.2%	52.1%	44.6%	50.1%	54.0%	50.8%
300	49.5%	48.2%	43.2%	51.9%	47.0%	49.8%
360	47.6%	44.2%	43.3%	52.2%	43.7%	48.8%
720	42.2%	40.3%	43.7%	48.7%	40.4%	50.2%
1440	42.4%	40.7%	44.1%	48.7%	40.7%	50.6%

Change in Forecast Error Standard Deviation (MW)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	12.7%	-0.6%	23.1%	6.5%	-1.7%	-0.1%
30	6.4%	-0.9%	15.0%	2.6%	-1.6%	-0.3%
45	37.1%	-0.6%	13.3%	39.9%	-1.8%	0.2%
60	15.0%	-0.8%	18.3%	0.0%	-2.3%	0.2%
90	0.0%	-1.2%	11.4%	-0.6%	-2.8%	-1.0%
120	5.6%	-1.2%	11.8%	-1.0%	-3.3%	-0.9%
180	2.8%	-1.5%	9.2%	-0.9%	-3.6%	-1.5%
240	1.7%	-1.3%	6.7%	-0.5%	-2.6%	-1.7%
300	2.1%	1.2%	9.5%	-0.1%	0.7%	2.3%
360	2.9%	4.6%	11.3%	0.1%	4.3%	4.4%
720	6.2%	12.7%	13.5%	0.8%	12.4%	5.6%
1440	6.5%	12.5%	13.1%	0.8%	12.1%	5.5%

Figure 18: PG&E Total, All Seasons, Clear

Change in Forecast Mean Absolute Percentage Error (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	18.19%	-1.12%	20.57%	11.65%	-1.92%	1.80%
30	11.13%	-1.08%	16.71%	6.26%	-1.91%	1.85%
45	19.88%	-0.90%	15.24%	20.75%	-2.20%	1.77%
60	13.56%	-0.99%	18.30%	1.46%	-2.50%	1.62%
90	1.39%	-1.26%	13.39%	0.43%	-3.18%	0.57%
120	5.89%	-1.14%	14.18%	0.20%	-3.48%	0.35%
180	3.44%	-1.42%	11.34%	0.08%	-4.16%	-0.62%
240	1.38%	-0.58%	8.95%	-0.55%	-3.06%	-1.36%
300	0.31%	3.37%	15.82%	-1.30%	1.93%	5.17%
360	0.72%	7.91%	17.90%	-1.29%	6.92%	6.35%
720	4.74%	15.35%	15.26%	0.30%	14.70%	1.34%
1440	4.21%	13.92%	13.81%	0.07%	13.26%	0.67%

Forecast Skill (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	35.2%	51.3%	43.4%	37.1%	52.0%	48.8%
30	37.8%	51.7%	43.3%	40.0%	53.0%	49.5%
45	38.9%	52.1%	43.2%	39.5%	53.3%	49.6%
60	40.0%	52.3%	42.9%	44.1%	53.0%	49.6%
90	44.0%	52.6%	43.9%	45.0%	53.8%	49.9%
120	43.1%	52.0%	43.3%	46.0%	54.0%	50.0%
180	45.0%	52.8%	44.5%	47.0%	54.8%	50.8%
240	47.6%	50.4%	44.9%	49.3%	52.8%	50.7%
300	48.0%	47.0%	43.1%	50.2%	47.3%	49.0%
360	46.1%	43.8%	41.8%	49.4%	44.1%	48.2%
720	38.8%	41.4%	41.9%	43.5%	41.7%	50.5%
1440	38.9%	42.1%	42.5%	43.6%	42.5%	51.1%

Change in Forecast Error Standard Deviation (MW)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	13.8%	-0.9%	16.9%	7.9%	-1.9%	0.5%
30	8.4%	-0.9%	11.9%	4.2%	-1.8%	0.3%
45	28.5%	-0.5%	10.5%	29.5%	-1.8%	0.6%
60	11.2%	-0.5%	14.0%	1.3%	-2.1%	0.4%
90	1.2%	-0.9%	9.6%	0.2%	-2.7%	-0.4%
120	4.2%	-0.8%	10.4%	-0.2%	-2.8%	0.0%
180	2.0%	-1.0%	8.5%	-0.4%	-3.1%	-0.5%
240	0.8%	-0.4%	7.1%	-0.5%	-2.0%	-0.6%
300	0.9%	2.3%	12.9%	-0.5%	1.2%	5.0%
360	1.6%	5.4%	15.0%	-0.3%	4.5%	6.9%
720	4.5%	11.2%	11.8%	0.7%	10.6%	3.3%
1440	4.2%	10.6%	11.0%	0.6%	10.0%	2.8%

Figure 19: PG&E Total, All Seasons, Cloudy

Change in Forecast Mean Absolute Percentage Error (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	7.59%	-1.00%	34.20%	7.54%	-2.94%	1.16%
30	5.76%	-1.81%	25.31%	5.50%	-4.56%	-0.16%
45	6.65%	-1.82%	21.35%	8.87%	-5.51%	0.50%
60	20.87%	-1.80%	23.60%	3.69%	-6.52%	0.26%
90	2.74%	-2.62%	14.94%	2.87%	-7.91%	-2.98%
120	11.54%	-2.47%	14.20%	2.81%	-8.80%	-3.27%
180	8.23%	-3.73%	10.00%	2.16%	-10.49%	-6.51%
240	4.54%	-2.87%	8.14%	0.34%	-9.29%	-7.14%
300	2.10%	1.66%	16.17%	-1.71%	-3.34%	3.55%
360	2.55%	6.59%	19.66%	-2.09%	2.80%	9.55%
720	6.26%	13.80%	16.29%	0.50%	11.82%	8.13%
1440	6.39%	13.25%	16.40%	0.49%	11.29%	8.05%

Forecast Skill (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	34.4%	53.7%	40.4%	34.7%	54.9%	49.6%
30	34.4%	54.5%	41.1%	35.4%	56.0%	50.4%
45	35.2%	54.8%	42.1%	34.3%	57.4%	49.8%
60	32.5%	54.4%	42.6%	36.8%	57.7%	50.0%
90	36.1%	56.4%	44.9%	36.4%	58.7%	52.1%
120	35.0%	54.4%	45.5%	36.9%	57.4%	52.7%
180	37.0%	55.5%	46.2%	38.4%	59.3%	53.8%
240	44.0%	53.2%	46.9%	46.2%	57.3%	54.4%
300	46.2%	45.3%	41.0%	50.3%	49.7%	50.0%
360	45.3%	40.5%	37.6%	50.1%	44.6%	45.4%
720	39.3%	35.7%	35.2%	42.2%	37.2%	46.1%
1440	39.2%	36.2%	35.4%	42.0%	37.7%	46.3%

Change in Forecast Error Standard Deviation (MW)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	5.6%	-1.0%	33.9%	4.3%	-2.5%	-0.8%
30	4.4%	-1.8%	23.8%	3.7%	-3.6%	-1.3%
45	7.5%	-1.9%	19.9%	9.0%	-4.7%	-0.7%
60	20.6%	-2.0%	21.8%	2.8%	-5.6%	-1.2%
90	2.4%	-2.5%	13.0%	2.1%	-7.1%	-4.2%
120	11.3%	-2.7%	11.3%	2.0%	-8.5%	-5.2%
180	7.9%	-3.5%	6.4%	1.7%	-10.0%	-8.1%
240	4.5%	-3.8%	2.5%	0.0%	-9.9%	-9.3%
300	1.9%	-2.6%	6.2%	-1.9%	-7.0%	-2.0%
360	1.2%	-1.4%	6.3%	-2.4%	-4.6%	-0.8%
720	2.1%	0.8%	1.1%	-1.7%	-0.7%	-5.7%
1440	2.0%	0.7%	1.5%	-1.9%	-0.9%	-5.6%

5.3 PG&E Bay Area Simulation Results

Figure 20 through Figure 24 presents the results for PG&E Bay Area across all seasons, and cloud cover conditions.

- **Forecast Horizons of 15 Minutes Ahead to Four Hours Ahead**: For forecast horizons of up to four hours ahead, the Model Direct approach consistently outperformed the baseline load forecast model with both a reduced MAPE and smaller dispersion of forecast errors. Further, the Model Direct approach performed better than the baseline forecast when using both Cloud Cover driven and CPR computed solar generation estimates. However, the Model Direct approach when combined with the CPR solar generation estimates outperformed the same approach combined with the Cloud Cover driven solar generation estimates.
- **Forecast Horizons of Five Hours Ahead to Six Hours Ahead**: For forecast horizons of five hours ahead to six hours ahead, the Error Correction approach combined with CPR solar generation estimates outperformed all other approaches.
- **Forecast Horizons of 12 Hours Ahead to 24 Hours Ahead**: For longer-term forecast horizons of 12 hours ahead to 24 hours ahead, the baseline model forecasts were on average more accurate, but the Error Correction approach combined with the CPR solar generation estimates led to a tighter distribution of forecast errors.
- **Seasonal Differences:** The main difference between the winter and summer seasons is the Model Direct approach when combined with the CPR solar generation estimates reduce the forecast error dispersion during the winter months across all forecast horizons. This improvement is limited to the forecast horizons of 15 minutes ahead to four hours ahead during the summer season.
- **Cloud Cover:** The alternative approaches appear to work best under varying cloud conditions. Most notably, the forecast error dispersion is reduced across most forecast horizons under the Model Direct and Reconstituted Load approach when combined with the CPR solar generation estimates.

Figure 20: PG&E Bay Area, All Seasons, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	4.60%	-1.06%	24.00%	5.85%	-1.77%	1.66%
30	2.99%	-0.79%	19.55%	3.25%	-2.19%	1.72%
45	6.58%	-0.44%	16.96%	9.52%	-2.47%	1.96%
60	13.93%	-0.56%	21.48%	1.56%	-2.79%	1.31%
90	0.76%	-0.53%	15.96%	0.87%	-3.26%	0.55%
120	6.99%	-0.30%	16.51%	0.94%	-3.53%	-0.15%
180	4.67%	-0.68%	14.16%	0.92%	-4.29%	-1.53%
240	3.05%	-0.24%	11.90%	0.36%	-2.60%	-2.53%
300	1.45%	2.17%	18.48%	-0.72%	1.92%	4.23%
360	0.90%	5.63%	19.45%	-1.16%	6.14%	5.83%
720	1.74%	11.63%	13.54%	-0.22%	12.11%	0.37%
1440	1.56%	10.79%	13.01%	-0.36%	11.28%	0.15%

Forecast Skill (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	38.9%	51.7%	41.5%	37.6%	52.6%	49.0%
30	39.4%	51.9%	41.5%	39.5%	54.0%	49.7%
45	39.7%	51.9%	42.1%	38.4%	54.0%	49.8%
60	36.9%	52.0%	41.1%	41.2%	54.1%	50.6%
90	41.2%	52.4%	42.5%	41.0%	55.2%	50.2%
120	38.7%	51.4%	43.1%	41.3%	54.7%	51.1%
180	40.3%	52.3%	43.6%	41.8%	55.4%	52.2%
240	43.8%	50.3%	43.2%	44.9%	53.0%	52.3%
300	45.4%	46.0%	40.3%	47.7%	46.4%	48.9%
360	45.5%	42.6%	38.4%	48.1%	42.6%	46.7%
720	44.1%	39.2%	39.7%	44.7%	39.2%	48.0%
1440	44.3%	39.8%	40.1%	44.7%	39.7%	48.2%

Change in Forecast Error Standard Deviation (MW)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	3.1%	-0.9%	20.6%	3.5%	-1.3%	1.2%
30	2.0%	-0.6%	14.6%	1.9%	-1.4%	0.9%
45	4.9%	-0.2%	12.6%	7.5%	-1.6%	1.0%
60	11.5%	-0.2%	17.7%	0.7%	-1.8%	0.6%
90	0.4%	-0.2%	12.4%	0.3%	-2.4%	-0.1%
120	5.5%	0.0%	13.8%	0.2%	-2.7%	-0.4%
180	3.2%	-0.1%	11.7%	0.1%	-3.1%	-1.4%
240	1.8%	-0.4%	8.8%	-0.4%	-2.5%	-2.6%
300	0.8%	-0.1%	12.0%	-1.2%	-0.6%	1.3%
360	0.4%	0.7%	11.3%	-1.5%	1.0%	1.4%
720	0.7%	2.6%	3.0%	-1.2%	3.2%	-5.2%
1440	0.7%	2.5%	2.8%	-1.3%	3.1%	-5.2%

Figure 21: PG&E Bay Area, Winter, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon Minutes Ahead	Behind-the-Meter Solar Generation Source: Cloud Cover — Error Correction	Model Direct	Reconstituted Loads	Behind-the-Meter Solar Generation Source: Clean Power Research — Error Correction	Model Direct	Reconstituted Loads
15	4.49%	-1.55%	13.09%	5.37%	-2.39%	1.46%
30	3.16%	-1.24%	11.10%	3.18%	-3.00%	1.30%
45	2.59%	-1.13%	9.95%	2.22%	-3.23%	1.55%
60	7.01%	-1.06%	11.30%	1.51%	-3.78%	0.46%
90	1.13%	-1.28%	7.59%	1.00%	-4.28%	-0.80%
120	3.23%	-0.74%	7.70%	1.10%	-4.58%	-1.52%
180	2.93%	-1.30%	5.65%	1.25%	-5.49%	-3.15%
240	1.26%	-1.30%	5.49%	0.21%	-4.41%	-4.58%
300	-0.18%	0.43%	17.22%	-0.95%	-0.65%	3.24%
360	-0.29%	3.07%	20.56%	-1.05%	2.74%	4.81%
720	0.80%	7.51%	13.45%	0.36%	7.23%	-2.13%
1440	0.66%	6.40%	12.58%	0.31%	6.05%	-2.62%

Forecast Skill (%)

Forecast Horizon Minutes Ahead	Behind-the-Meter Solar Generation Source: Cloud Cover — Error Correction	Model Direct	Reconstituted Loads	Behind-the-Meter Solar Generation Source: Clean Power Research — Error Correction	Model Direct	Reconstituted Loads
15	34.5%	54.1%	44.0%	33.8%	54.0%	49.2%
30	34.0%	53.6%	44.4%	35.1%	54.1%	50.4%
45	34.3%	53.4%	44.6%	34.9%	53.5%	50.4%
60	33.7%	54.1%	44.1%	35.6%	54.5%	52.2%
90	34.7%	54.6%	45.7%	35.9%	54.7%	52.6%
120	34.9%	52.3%	45.9%	34.7%	53.9%	52.6%
180	36.5%	54.1%	46.6%	35.5%	55.4%	53.9%
240	41.9%	51.1%	45.8%	41.5%	53.7%	54.5%
300	43.2%	46.3%	41.3%	43.7%	48.7%	49.4%
360	43.4%	43.4%	36.1%	42.8%	45.5%	46.8%
720	41.5%	41.0%	34.7%	38.6%	41.7%	48.5%
1440	41.2%	42.1%	35.2%	38.2%	42.7%	48.7%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon Minutes Ahead	Behind-the-Meter Solar Generation Source: Cloud Cover — Error Correction	Model Direct	Reconstituted Loads	Behind-the-Meter Solar Generation Source: Clean Power Research — Error Correction	Model Direct	Reconstituted Loads
15	3.4%	-1.5%	10.8%	3.4%	-2.1%	1.1%
30	2.7%	-1.2%	8.4%	2.3%	-2.4%	0.9%
45	2.3%	-0.9%	7.1%	1.5%	-2.5%	0.8%
60	5.6%	-0.6%	8.5%	1.2%	-2.7%	0.2%
90	1.0%	-0.7%	5.8%	0.7%	-3.5%	-0.8%
120	2.8%	-0.4%	5.5%	0.8%	-3.9%	-1.4%
180	1.9%	-0.6%	3.4%	0.8%	-4.8%	-3.1%
240	0.8%	-1.7%	2.1%	-0.2%	-4.9%	-5.1%
300	-0.2%	-2.8%	9.9%	-1.3%	-4.0%	-0.8%
360	-0.4%	-2.8%	10.0%	-1.4%	-3.2%	-1.7%
720	0.2%	-1.9%	0.4%	-0.9%	-2.0%	-10.7%
1440	0.2%	-2.3%	0.0%	-0.9%	-2.5%	-10.9%

Figure 22: PG&E Bay Area, Summer, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	4.72%	-0.53%	35.72%	6.37%	-1.11%	1.87%
30	2.81%	-0.29%	28.95%	3.33%	-1.29%	2.20%
45	11.04%	0.33%	24.78%	17.67%	-1.62%	2.41%
60	21.88%	0.00%	33.16%	1.62%	-1.66%	2.27%
90	0.35%	0.32%	25.50%	0.72%	-2.10%	2.09%
120	11.22%	0.19%	26.40%	0.76%	-2.35%	1.40%
180	6.57%	0.00%	23.43%	0.55%	-3.00%	0.22%
240	5.04%	0.95%	19.01%	0.53%	-0.59%	-0.24%
300	3.46%	4.31%	20.04%	-0.43%	5.08%	5.45%
360	2.49%	9.02%	17.97%	-1.31%	10.64%	7.19%
720	3.14%	17.74%	13.68%	-1.09%	19.35%	4.08%
1440	2.91%	17.36%	13.65%	-1.36%	19.10%	4.30%

Forecast Skill (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	43.2%	49.5%	39.0%	41.3%	51.2%	48.8%
30	44.7%	50.3%	38.7%	43.7%	53.9%	49.1%
45	44.9%	50.5%	39.7%	41.9%	54.4%	49.2%
60	39.9%	50.0%	38.3%	46.6%	53.8%	48.9%
90	47.5%	50.3%	39.3%	46.0%	55.7%	47.9%
120	42.5%	50.5%	40.3%	47.7%	55.5%	49.6%
180	44.0%	50.5%	40.6%	47.9%	55.4%	50.6%
240	45.6%	49.4%	40.8%	48.2%	52.3%	50.2%
300	47.6%	45.7%	39.4%	51.7%	44.1%	48.4%
360	47.5%	41.8%	40.5%	53.2%	39.9%	46.7%
720	46.7%	37.4%	44.5%	50.7%	36.8%	47.5%
1440	47.3%	37.6%	44.7%	50.8%	36.9%	47.8%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	2.8%	-0.4%	29.2%	3.5%	-0.6%	1.3%
30	1.5%	-0.2%	20.0%	1.5%	-0.5%	0.8%
45	7.4%	0.3%	17.6%	12.8%	-0.8%	1.2%
60	16.9%	0.1%	26.2%	0.2%	-1.0%	1.1%
90	-0.2%	0.0%	18.5%	-0.2%	-1.5%	0.6%
120	7.7%	0.2%	21.0%	-0.4%	-1.7%	0.7%
180	4.2%	0.4%	18.4%	-0.5%	-1.8%	0.2%
240	2.5%	0.8%	14.2%	-0.6%	-0.7%	-0.6%
300	1.9%	2.9%	12.9%	-1.1%	2.6%	2.9%
360	1.6%	5.6%	11.2%	-1.4%	6.0%	4.6%
720	2.3%	12.0%	6.5%	-1.7%	12.7%	4.2%
1440	2.4%	12.1%	6.8%	-1.8%	12.9%	4.7%

Figure 23: PG&E Bay Area, All Seasons, Clear

Change in Forecast Mean Absolute Percentage Error (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	5.33%	-1.08%	25.97%	5.77%	-1.40%	0.94%
30	3.14%	-0.58%	21.34%	3.06%	-1.30%	1.64%
45	7.69%	-0.18%	18.95%	10.33%	-1.64%	2.02%
60	15.72%	-0.19%	24.80%	1.09%	-1.67%	1.60%
90	0.48%	-0.17%	18.50%	0.13%	-2.28%	1.05%
120	7.90%	0.15%	20.02%	0.23%	-2.17%	0.57%
180	5.17%	-0.04%	17.18%	0.34%	-2.87%	-0.21%
240	3.48%	0.69%	14.33%	-0.01%	-1.08%	-0.66%
300	1.61%	3.85%	20.57%	-0.80%	4.07%	6.57%
360	1.03%	7.80%	20.67%	-1.04%	8.81%	7.83%
720	1.86%	14.71%	13.87%	-0.26%	15.55%	2.06%
1440	1.58%	13.71%	12.96%	-0.49%	14.52%	1.68%

Forecast Skill (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	39.2%	50.7%	41.2%	38.2%	51.8%	49.7%
30	40.5%	51.0%	41.1%	40.2%	53.4%	50.0%
45	40.6%	50.9%	41.6%	40.0%	53.5%	50.0%
60	37.9%	50.9%	40.2%	43.0%	53.1%	50.6%
90	43.0%	51.2%	41.6%	43.1%	54.4%	50.1%
120	40.3%	50.2%	41.4%	43.9%	53.8%	50.3%
180	41.6%	51.1%	42.4%	44.2%	54.2%	51.4%
240	44.1%	49.1%	42.0%	46.5%	51.7%	51.2%
300	45.6%	45.8%	40.2%	48.5%	45.5%	47.9%
360	45.4%	42.5%	39.0%	48.0%	42.0%	46.3%
720	43.9%	39.4%	41.8%	44.2%	39.3%	47.8%
1440	44.0%	39.9%	42.4%	44.1%	39.8%	48.1%

Change in Forecast Error Standard Deviation (MW)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	3.7%	-1.0%	22.0%	3.6%	-1.2%	0.5%
30	2.3%	-0.5%	15.4%	1.8%	-1.0%	0.5%
45	6.0%	-0.1%	13.5%	8.5%	-1.0%	0.9%
60	13.0%	0.1%	19.9%	0.4%	-1.0%	0.5%
90	0.1%	0.0%	13.9%	-0.2%	-1.5%	0.2%
120	6.2%	0.4%	15.9%	-0.3%	-1.5%	0.2%
180	3.5%	0.5%	13.5%	-0.4%	-1.8%	-0.4%
240	1.8%	0.7%	11.0%	-0.7%	-0.9%	-0.9%
300	0.7%	2.5%	15.3%	-1.4%	2.1%	4.5%
360	0.2%	4.9%	15.7%	-1.7%	5.1%	6.3%
720	0.3%	10.0%	9.3%	-1.8%	10.6%	2.2%
1440	0.3%	9.7%	8.8%	-1.9%	10.3%	2.0%

Figure 24: PG&E Bay Area, All Seasons, Cloudy

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	2.50%	-0.99%	18.32%	6.09%	-2.86%	3.72%
30	2.58%	-1.39%	14.48%	3.77%	-4.69%	1.97%
45	3.50%	-1.15%	11.39%	7.25%	-4.78%	1.78%
60	8.99%	-1.61%	12.29%	2.84%	-5.89%	0.49%
90	1.56%	-1.55%	8.87%	2.93%	-5.99%	-0.84%
120	4.44%	-1.58%	6.65%	2.95%	-7.34%	-2.16%
180	3.26%	-2.49%	5.53%	2.55%	-8.36%	-5.32%
240	1.83%	-2.89%	4.91%	1.45%	-6.98%	-7.88%
300	1.03%	-2.43%	12.77%	-0.48%	-3.96%	-2.17%
360	0.57%	-0.14%	16.22%	-1.49%	-0.96%	0.52%
720	1.46%	3.87%	12.71%	-0.11%	3.46%	-3.89%
1440	1.54%	3.53%	13.14%	-0.04%	3.24%	-3.67%

Forecast Skill (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	37.8%	54.9%	42.3%	35.8%	55.1%	46.8%
30	36.2%	54.6%	42.9%	37.1%	55.8%	48.9%
45	36.7%	54.9%	43.6%	33.6%	55.5%	49.1%
60	33.5%	55.5%	43.9%	35.8%	57.3%	50.3%
90	35.5%	56.1%	45.2%	34.6%	57.6%	50.6%
120	33.9%	54.9%	48.2%	33.2%	57.5%	53.4%
180	36.1%	56.0%	47.4%	34.3%	59.1%	54.9%
240	42.8%	53.9%	47.2%	40.0%	56.9%	55.7%
300	44.9%	46.5%	40.8%	45.3%	49.1%	52.1%
360	45.8%	42.8%	36.3%	48.2%	44.6%	48.0%
720	45.0%	38.8%	32.9%	46.5%	39.0%	48.7%
1440	45.1%	39.4%	33.2%	46.5%	39.4%	48.5%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	1.4%	-0.7%	16.2%	3.2%	-1.7%	3.0%
30	1.4%	-1.0%	12.1%	2.2%	-2.8%	1.8%
45	1.6%	-0.9%	9.3%	4.3%	-3.5%	1.2%
60	6.9%	-1.2%	10.3%	1.5%	-4.3%	1.0%
90	1.0%	-1.4%	7.2%	1.8%	-5.3%	-1.0%
120	3.4%	-1.6%	5.9%	1.7%	-6.8%	-2.1%
180	2.6%	-2.0%	4.5%	1.7%	-7.7%	-4.5%
240	1.7%	-3.9%	0.4%	0.5%	-8.4%	-8.0%
300	0.4%	-7.2%	2.2%	-1.1%	-9.0%	-7.1%
360	-0.1%	-9.0%	0.6%	-1.6%	-9.5%	-9.5%
720	-0.1%	-10.7%	-8.3%	-1.4%	-10.6%	-18.2%
1440	-0.1%	-10.3%	-7.7%	-1.4%	-10.2%	-18.0%

5.4 PG&E Non-Bay Area Simulation Results

Figure 25 through Figure 29 presents the results for PG&E Non-Bay Area across all seasons, and cloud cover conditions.

- **Forecast Horizons of 15 Minutes Ahead to Four Hours Ahead**: For forecast horizons of up to four hours ahead, the Model Direct approach consistently outperformed the baseline load forecast model with both a reduced MAPE and smaller dispersion of forecast errors. Further, the Model Direct approach performed better than the baseline forecast when using both Cloud Cover driven and CPR computed solar generation estimates. However, the Model Direct approach when combined with the CPR solar generation estimates outperformed the same approach combined with the Cloud Cover driven solar generation estimates.
- **Forecast Horizons of Five Hours Ahead to Six Hours Ahead**: For forecast horizons of five hours ahead to six hours ahead, the Error Correction approach combined with CPR solar generation estimates outperformed all other approaches.
- **Forecast Horizons of 12 Hours Ahead to 24 Hours Ahead**: For longer-term forecast horizons of 12 hours ahead to 24 hours ahead, the baseline model forecasts were on average more accurate.
- **Seasonal Differences:** The main difference between the winter and summer seasons is the Reconstituted Load approach when combined with the CPR solar generation estimates performed better with the longer forecast horizons during the summer season than the winter season.
- **Cloud Cover:** The alternative approaches appear to work best under varying cloud conditions. Most notably, the forecast error dispersion is reduced across most forecast horizons under the Model Direct and Reconstituted Load approach when combined with the CPR solar generation estimates.

Figure 25: PG&E Non-Bay Area, All Seasons, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	26.52%	-1.12%	24.29%	15.42%	-2.61%	1.61%
30	16.65%	-1.77%	18.39%	8.95%	-3.04%	0.90%
45	26.37%	-1.85%	16.72%	25.86%	-3.68%	0.91%
60	16.95%	-1.82%	17.92%	2.51%	-4.28%	1.23%
90	2.71%	-2.69%	11.64%	1.26%	-5.55%	-1.26%
120	7.67%	-2.60%	11.98%	0.81%	-6.09%	-0.99%
180	4.65%	-3.23%	8.10%	0.33%	-7.12%	-2.67%
240	1.38%	-2.03%	5.83%	-0.96%	-6.55%	-3.11%
300	0.12%	3.66%	13.40%	-2.08%	-0.81%	5.25%
360	1.52%	9.52%	17.28%	-1.86%	5.49%	8.61%
720	8.83%	18.46%	17.69%	0.97%	15.82%	6.30%
1440	8.29%	16.88%	16.16%	0.77%	14.23%	5.50%

Forecast Skill (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	31.1%	52.0%	43.8%	35.5%	52.9%	48.9%
30	34.5%	52.8%	44.1%	38.3%	53.5%	49.7%
45	36.4%	53.7%	43.8%	38.1%	54.6%	49.6%
60	39.4%	53.6%	44.5%	43.5%	54.2%	48.8%
90	43.0%	54.7%	45.8%	44.8%	54.8%	50.6%
120	43.5%	53.8%	44.6%	46.3%	54.9%	50.2%
180	45.9%	54.7%	46.2%	48.0%	56.4%	50.8%
240	49.7%	51.9%	47.6%	52.3%	54.7%	50.9%
300	49.7%	47.1%	44.8%	52.8%	49.4%	49.5%
360	46.3%	43.5%	43.2%	51.0%	45.8%	48.3%
720	33.7%	40.7%	40.9%	41.7%	42.0%	50.9%
1440	33.7%	41.5%	41.4%	41.7%	42.9%	51.6%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	17.4%	-0.9%	22.1%	9.3%	-2.6%	-0.5%
30	11.1%	-1.4%	15.1%	5.6%	-2.9%	-0.8%
45	35.0%	-1.2%	13.1%	35.4%	-3.1%	-0.2%
60	14.9%	-1.2%	15.1%	2.3%	-3.6%	-0.4%
90	2.2%	-1.9%	9.3%	0.9%	-4.5%	-2.0%
120	6.1%	-1.9%	9.0%	0.4%	-5.0%	-1.8%
180	3.5%	-2.4%	6.2%	0.1%	-5.5%	-2.7%
240	1.6%	-1.8%	4.6%	-0.4%	-4.8%	-2.8%
300	1.2%	1.5%	10.5%	-0.9%	-1.3%	4.1%
360	2.1%	5.0%	13.0%	-0.8%	2.3%	6.7%
720	6.5%	11.6%	12.3%	0.7%	9.7%	4.6%
1440	6.1%	10.9%	11.6%	0.5%	8.8%	4.0%

Figure 26: PG&E Non-Bay Area, Winter, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	22.87%	-1.32%	27.42%	15.82%	-2.74%	2.24%
30	16.71%	-1.66%	21.81%	11.55%	-3.37%	1.52%
45	11.79%	-1.73%	19.83%	9.38%	-3.86%	1.62%
60	17.97%	-1.69%	20.32%	4.63%	-4.75%	0.69%
90	4.82%	-2.46%	14.38%	3.22%	-6.31%	-1.19%
120	8.69%	-2.40%	14.52%	1.83%	-6.58%	-1.65%
180	5.44%	-2.90%	9.99%	1.07%	-7.91%	-3.53%
240	1.65%	-0.27%	8.49%	-1.20%	-6.81%	-2.87%
300	-0.43%	6.83%	16.69%	-3.37%	-0.17%	8.61%
360	0.94%	12.87%	19.50%	-3.21%	6.75%	13.26%
720	9.19%	19.89%	14.94%	0.81%	16.95%	9.72%
1440	8.09%	17.86%	13.26%	0.46%	14.95%	8.76%

Forecast Skill (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	27.4%	51.4%	43.4%	31.0%	52.8%	49.9%
30	29.7%	52.6%	42.7%	32.5%	53.4%	50.6%
45	31.1%	53.8%	42.7%	33.6%	54.8%	50.2%
60	34.5%	53.4%	44.0%	38.0%	54.9%	50.1%
90	37.9%	54.2%	45.4%	39.0%	55.2%	51.5%
120	40.1%	53.2%	45.0%	42.4%	54.4%	51.1%
180	42.9%	53.1%	47.3%	44.7%	55.5%	51.3%
240	48.6%	48.9%	46.7%	52.5%	53.8%	50.3%
300	48.1%	43.6%	42.5%	53.5%	48.9%	47.8%
360	45.0%	40.1%	40.4%	50.9%	43.9%	45.6%
720	29.6%	38.2%	38.8%	36.5%	39.8%	48.8%
1440	29.5%	39.1%	39.3%	36.6%	41.0%	49.6%

Change in Forecast Error Standard Deviation (MW)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	15.7%	-1.1%	25.4%	10.3%	-2.6%	0.1%
30	12.9%	-1.6%	19.4%	8.4%	-3.5%	-0.5%
45	9.9%	-1.4%	15.9%	8.0%	-3.8%	0.0%
60	16.0%	-1.3%	16.7%	4.8%	-3.9%	-0.4%
90	4.6%	-2.0%	11.8%	2.9%	-5.3%	-2.1%
120	8.0%	-2.1%	11.2%	2.4%	-5.5%	-1.7%
180	5.1%	-2.6%	7.5%	1.5%	-6.5%	-3.3%
240	1.9%	-1.5%	5.6%	-0.4%	-6.0%	-3.8%
300	-0.1%	2.6%	12.8%	-2.4%	-2.2%	5.6%
360	0.2%	5.9%	14.6%	-2.8%	1.4%	8.3%
720	4.1%	10.7%	9.1%	-1.0%	8.2%	2.9%
1440	3.5%	9.8%	8.4%	-1.2%	7.2%	2.5%

Figure 27: PG&E Non-Bay Area, Summer, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	30.66%	-0.89%	20.72%	14.97%	-2.46%	0.89%
30	16.58%	-1.89%	14.61%	6.08%	-2.67%	0.22%
45	42.82%	-1.99%	13.22%	44.44%	-3.48%	0.11%
60	15.77%	-1.98%	15.13%	0.03%	-3.73%	1.86%
90	0.38%	-2.95%	8.59%	-0.91%	-4.71%	-1.32%
120	6.50%	-2.83%	9.06%	-0.36%	-5.52%	-0.24%
180	3.76%	-3.61%	5.99%	-0.50%	-6.24%	-1.69%
240	1.07%	-3.98%	2.87%	-0.69%	-6.26%	-3.38%
300	0.78%	-0.14%	9.48%	-0.55%	-1.57%	1.24%
360	2.27%	5.25%	14.44%	-0.14%	3.87%	2.68%
720	8.31%	16.38%	21.68%	1.21%	14.18%	1.35%
1440	8.59%	15.46%	20.37%	1.21%	13.19%	0.78%

Forecast Skill (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	34.8%	52.6%	44.3%	39.9%	52.9%	48.0%
30	39.2%	53.0%	45.4%	43.9%	53.6%	48.8%
45	41.5%	53.6%	44.9%	42.5%	54.3%	49.0%
60	44.3%	53.7%	45.0%	48.9%	53.5%	47.6%
90	48.0%	55.1%	46.1%	50.5%	54.4%	49.8%
120	46.8%	54.3%	44.2%	50.1%	55.4%	49.3%
180	48.9%	56.3%	45.2%	51.3%	57.2%	50.3%
240	50.7%	54.9%	48.4%	52.1%	55.6%	51.4%
300	51.3%	50.6%	47.0%	52.2%	49.8%	51.2%
360	47.6%	46.7%	46.0%	51.2%	47.6%	51.0%
720	37.7%	43.3%	42.9%	46.7%	44.0%	52.9%
1440	37.6%	43.9%	43.5%	46.6%	44.6%	53.4%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	18.8%	-0.8%	18.8%	8.5%	-2.4%	-1.1%
30	9.6%	-1.3%	11.5%	3.4%	-2.4%	-1.0%
45	52.6%	-1.2%	10.5%	54.2%	-2.5%	-0.4%
60	13.8%	-1.4%	13.0%	0.0%	-3.2%	-0.4%
90	0.1%	-2.0%	6.7%	-0.9%	-3.8%	-2.0%
120	4.4%	-2.1%	6.1%	-1.4%	-4.4%	-1.9%
180	2.1%	-2.6%	3.8%	-1.1%	-4.6%	-2.4%
240	1.3%	-2.3%	2.7%	-0.4%	-3.7%	-2.1%
300	2.5%	0.9%	8.2%	0.5%	-0.1%	2.6%
360	4.2%	5.1%	12.3%	1.2%	4.1%	5.5%
720	10.1%	15.3%	19.3%	2.9%	14.3%	8.8%
1440	10.4%	15.0%	18.7%	2.8%	13.8%	8.4%

Figure 28: PG&E Non-Bay Area, All Seasons, Clear

Change in Forecast Mean Absolute Percentage Error (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	31.54%	-1.16%	14.96%	17.75%	-2.47%	2.69%
30	19.42%	-1.59%	11.91%	9.57%	-2.53%	2.07%
45	32.19%	-1.62%	11.48%	31.26%	-2.77%	1.52%
60	11.47%	-1.76%	12.03%	1.81%	-3.29%	1.65%
90	2.29%	-2.34%	8.36%	0.73%	-4.07%	0.09%
120	4.01%	-2.35%	8.73%	0.18%	-4.69%	0.14%
180	1.87%	-2.67%	6.05%	-0.17%	-5.32%	-1.00%
240	-0.55%	-1.75%	4.02%	-1.04%	-4.88%	-1.99%
300	-0.95%	2.91%	11.23%	-1.78%	-0.14%	3.83%
360	0.40%	8.01%	15.12%	-1.54%	5.02%	4.86%
720	7.77%	16.02%	16.72%	0.90%	13.80%	0.58%
1440	6.96%	14.15%	14.70%	0.65%	11.94%	-0.39%

Forecast Skill (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	31.2%	51.9%	45.5%	36.1%	52.3%	47.8%
30	35.2%	52.3%	45.6%	39.7%	52.7%	49.0%
45	37.2%	53.4%	44.9%	39.0%	53.1%	49.3%
60	41.9%	53.7%	45.5%	45.3%	53.0%	48.6%
90	45.0%	54.1%	46.1%	46.9%	53.2%	49.7%
120	45.8%	53.8%	45.2%	48.1%	54.2%	49.6%
180	48.4%	54.6%	46.6%	49.8%	55.4%	50.3%
240	51.1%	51.8%	47.9%	52.1%	53.8%	50.2%
300	50.4%	48.1%	45.9%	52.0%	49.1%	50.0%
360	46.8%	45.1%	44.6%	50.7%	46.1%	50.1%
720	33.8%	43.3%	41.9%	42.9%	44.0%	53.2%
1440	33.8%	44.3%	42.7%	43.1%	45.1%	54.0%

Change in Forecast Error Standard Deviation (MW)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	20.1%	-0.8%	13.3%	10.7%	-2.4%	0.5%
30	12.5%	-1.1%	9.4%	5.9%	-2.5%	0.1%
45	41.0%	-0.8%	8.4%	41.2%	-2.4%	0.3%
60	10.1%	-0.9%	10.1%	1.9%	-2.8%	0.3%
90	1.9%	-1.5%	6.7%	0.4%	-3.4%	-0.8%
120	3.0%	-1.5%	7.0%	-0.1%	-3.6%	-0.2%
180	1.2%	-1.8%	5.6%	-0.3%	-3.8%	-0.5%
240	0.3%	-1.0%	4.9%	-0.3%	-2.7%	-0.4%
300	1.2%	2.3%	11.5%	0.1%	0.7%	5.4%
360	2.8%	5.9%	14.6%	0.7%	4.1%	7.5%
720	7.6%	12.2%	13.8%	2.6%	10.8%	4.2%
1440	7.2%	11.4%	12.8%	2.5%	9.9%	3.5%

Figure 29: PG&E Non-Bay Area, All Seasons, Cloudy

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	12.66%	-1.00%	49.98%	8.99%	-3.02%	-1.39%
30	8.99%	-2.24%	36.35%	7.26%	-4.44%	-2.34%
45	9.89%	-2.50%	31.57%	10.54%	-6.26%	-0.81%
60	32.98%	-2.01%	35.13%	4.56%	-7.17%	0.02%
90	3.94%	-3.73%	21.15%	2.80%	-9.87%	-5.17%
120	18.57%	-3.36%	21.68%	2.68%	-10.24%	-4.36%
180	12.92%	-4.90%	14.22%	1.80%	-12.50%	-7.62%
240	7.09%	-2.85%	11.19%	-0.71%	-11.47%	-6.45%
300	3.18%	5.79%	19.60%	-2.95%	-2.72%	9.33%
360	4.66%	13.74%	23.32%	-2.74%	6.80%	19.14%
720	11.68%	25.00%	20.31%	1.18%	21.23%	21.66%
1440	11.85%	24.16%	20.05%	1.09%	20.32%	21.20%

Forecast Skill (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	30.8%	52.5%	38.5%	33.4%	54.8%	52.5%
30	32.5%	54.3%	39.2%	33.8%	56.1%	51.9%
45	33.7%	54.7%	40.5%	35.0%	59.2%	50.5%
60	31.4%	53.1%	41.3%	37.8%	58.2%	49.6%
90	36.6%	56.7%	44.6%	38.2%	59.8%	53.5%
120	36.0%	53.9%	42.7%	40.6%	57.3%	52.0%
180	38.0%	55.0%	45.0%	42.5%	59.4%	52.6%
240	45.2%	52.5%	46.6%	52.7%	57.8%	52.9%
300	47.5%	44.0%	41.2%	55.5%	50.4%	47.9%
360	44.8%	38.2%	39.0%	52.0%	44.7%	42.7%
720	33.3%	32.4%	37.5%	37.9%	35.4%	43.4%
1440	33.1%	32.9%	37.6%	37.5%	35.9%	44.0%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	8.5%	-1.2%	45.4%	5.1%	-3.1%	-3.6%
30	6.6%	-2.3%	31.7%	4.7%	-4.2%	-3.6%
45	11.8%	-2.6%	27.2%	12.4%	-5.6%	-2.1%
60	29.6%	-2.6%	29.5%	3.8%	-6.6%	-2.8%
90	3.3%	-3.4%	17.1%	2.4%	-8.5%	-6.6%
120	16.3%	-3.6%	14.8%	2.2%	-9.8%	-7.4%
180	11.0%	-4.3%	7.5%	1.7%	-11.5%	-10.4%
240	6.4%	-3.5%	4.1%	-0.2%	-11.0%	-9.9%
300	3.2%	1.0%	9.5%	-2.5%	-5.6%	1.8%
360	2.7%	5.0%	11.4%	-3.1%	-0.5%	6.1%
720	5.1%	12.2%	10.4%	-1.9%	9.2%	5.5%
1440	5.0%	11.6%	10.4%	-2.2%	8.3%	5.3%

5.5 SCE Total Simulation Results

Figure 30 through Figure 34 presents the results for SCE Total across all seasons, and cloud cover conditions.

- **Forecast Horizons of 15 Minutes Ahead to Four Hours Ahead**. For forecast horizons of up to four hours ahead, the Model Direct approach consistently outperformed the baseline load forecast model with both a reduced MAPE and smaller dispersion of forecast errors. Further, the Model Direct approach performed better than the baseline forecast when using both Cloud Cover driven and CPR computed solar generation estimates. However, the Model Direct approach when combined with the CPR solar generation estimates outperformed the same approach combined with the Cloud Cover driven solar generation estimates.
- **Forecast Horizons of Five Hours Ahead to Six Hours Ahead**. For forecast horizons of five hours ahead to six hours ahead, the Error Correction approach combined with CPR solar generation estimates outperformed all other approaches.
- **Forecast Horizons of 12 Hours Ahead to 24 Hours Ahead**. For longer-term forecast horizons of 12 hours ahead to 24 hours ahead, the baseline model forecasts were on average more accurate.
- **Seasonal Differences.** The main difference between the winter and summer seasons is the Model Direct approach when combined with the CPR solar generation estimates performed during the winter season for forecast horizons of 15 minutes ahead to six-hours ahead. In contrast, the Model Direct approach outperformed the baseline model during the summer season for forecast horizons up to four-hours ahead.
- **Cloud Cover.** The alternative approaches appear to work best under varying cloud conditions. Most notably, the forecast error dispersion is reduced across most forecast horizons under the Model Direct and Reconstituted Load approach when combined with the CPR solar generation estimates.

Figure 30: SCE Total, All Seasons, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	9.29%	-0.03%	25.86%	7.24%	0.16%	1.28%
30	5.92%	0.04%	19.60%	4.39%	-0.39%	0.73%
45	13.36%	0.13%	17.22%	13.79%	-0.90%	1.01%
60	14.39%	0.17%	19.72%	2.43%	-1.25%	1.22%
90	2.99%	0.67%	14.01%	2.84%	-1.25%	0.39%
120	7.57%	0.77%	14.62%	2.43%	-1.51%	0.73%
180	5.13%	0.91%	11.37%	2.73%	-1.66%	0.76%
240	3.94%	0.52%	8.02%	2.75%	-1.44%	-0.33%
300	0.81%	0.62%	12.43%	0.09%	-0.43%	3.27%
360	-2.00%	0.93%	11.22%	-2.77%	0.29%	1.09%
720	-5.42%	1.15%	-1.10%	-6.58%	0.87%	-10.98%
1440	-5.81%	1.06%	-0.92%	-6.97%	0.77%	-9.83%

Forecast Skill (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	39.5%	50.2%	39.9%	41.0%	49.7%	48.3%
30	41.2%	49.9%	40.7%	43.0%	50.0%	48.8%
45	41.9%	50.5%	40.7%	43.7%	51.0%	48.9%
60	41.6%	50.1%	41.1%	45.7%	51.7%	49.3%
90	43.1%	48.7%	42.0%	43.8%	50.7%	49.7%
120	43.0%	48.5%	41.6%	44.4%	51.3%	49.2%
180	43.6%	48.0%	43.2%	43.7%	51.4%	49.0%
240	45.5%	49.0%	44.2%	45.3%	50.1%	50.2%
300	49.3%	48.9%	45.8%	49.9%	49.6%	51.8%
360	51.8%	48.6%	46.6%	52.4%	48.9%	52.7%
720	54.1%	47.5%	53.7%	54.6%	48.0%	58.8%
1440	54.5%	47.6%	53.6%	55.0%	48.1%	58.5%

Change in Forecast Error Standard Deviation (MW)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	4.6%	0.0%	17.4%	3.1%	0.0%	-0.1%
30	3.7%	0.1%	13.4%	2.7%	0.0%	0.3%
45	10.4%	0.1%	12.2%	11.2%	-0.4%	0.7%
60	10.6%	0.1%	15.0%	1.2%	-0.6%	0.9%
90	1.8%	0.4%	10.4%	1.5%	-0.6%	0.4%
120	5.3%	0.5%	11.6%	1.1%	-1.0%	0.8%
180	3.4%	0.5%	9.4%	1.4%	-1.1%	1.0%
240	3.2%	0.5%	6.7%	1.9%	-0.7%	0.0%
300	1.2%	0.9%	8.3%	0.1%	0.4%	1.7%
360	-1.5%	1.2%	6.0%	-2.5%	1.0%	-0.7%
720	-6.3%	1.2%	-4.5%	-7.3%	1.3%	-11.0%
1440	-6.5%	1.2%	-4.3%	-7.5%	1.2%	-10.1%

Figure 31: SCE Total, Winter, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon Minutes Ahead	Behind-the-Meter Solar Generation Source: Cloud Cover Error Correction	Model Direct	Reconstituted Loads	Behind-the-Meter Solar Generation Source: Clean Power Research Error Correction	Model Direct	Reconstituted Loads
15	10.35%	-0.26%	21.71%	8.71%	0.18%	2.13%
30	7.31%	-0.70%	16.47%	6.16%	-0.78%	0.99%
45	7.11%	-1.04%	14.41%	5.43%	-1.33%	0.97%
60	13.60%	-0.51%	15.44%	3.63%	-1.93%	1.39%
90	4.34%	0.06%	11.88%	4.01%	-1.52%	1.00%
120	7.92%	0.15%	11.52%	3.34%	-2.14%	1.10%
180	6.21%	0.31%	9.38%	3.37%	-2.50%	1.17%
240	4.96%	-0.42%	8.16%	3.30%	-2.72%	-0.11%
300	2.01%	-0.64%	15.98%	1.33%	-1.82%	4.36%
360	-0.19%	-0.17%	16.33%	-0.61%	-0.68%	2.88%
720	-2.66%	0.36%	5.25%	-3.58%	0.35%	-7.87%
1440	-3.21%	0.32%	5.46%	-4.06%	0.33%	-7.01%

Forecast Skill (%)

Forecast Horizon Minutes Ahead	Behind-the-Meter Solar Generation Source: Cloud Cover Error Correction	Model Direct	Reconstituted Loads	Behind-the-Meter Solar Generation Source: Clean Power Research Error Correction	Model Direct	Reconstituted Loads
15	38.5%	50.7%	40.4%	40.1%	49.6%	47.3%
30	39.4%	50.9%	41.5%	40.8%	50.1%	48.9%
45	41.0%	52.0%	41.5%	42.5%	51.4%	49.3%
60	39.8%	51.1%	42.3%	44.1%	52.8%	49.8%
90	40.9%	49.7%	42.4%	42.0%	51.4%	48.8%
120	41.1%	49.6%	43.1%	42.4%	51.7%	48.5%
180	41.8%	50.0%	44.2%	42.1%	52.4%	48.7%
240	43.8%	51.6%	44.0%	44.4%	52.5%	49.6%
300	47.8%	52.5%	43.5%	48.2%	52.1%	50.3%
360	50.2%	51.4%	43.4%	50.0%	51.3%	50.1%
720	52.3%	49.2%	49.7%	52.4%	49.0%	56.1%
1440	53.0%	49.3%	49.5%	52.9%	49.0%	56.0%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon Minutes Ahead	Behind-the-Meter Solar Generation Source: Cloud Cover Error Correction	Model Direct	Reconstituted Loads	Behind-the-Meter Solar Generation Source: Clean Power Research Error Correction	Model Direct	Reconstituted Loads
15	5.9%	-0.3%	15.9%	4.4%	-0.1%	1.1%
30	4.9%	-0.6%	11.6%	4.1%	-0.5%	0.4%
45	4.6%	-0.8%	10.1%	3.2%	-0.9%	0.7%
60	9.2%	-0.5%	11.1%	2.0%	-1.2%	1.2%
90	2.5%	-0.1%	8.6%	2.2%	-1.1%	0.5%
120	5.5%	0.1%	9.0%	1.8%	-1.7%	1.1%
180	4.6%	0.1%	7.6%	2.1%	-2.1%	1.1%
240	4.3%	-0.3%	6.7%	2.7%	-2.0%	0.2%
300	2.2%	-0.2%	13.4%	1.3%	-0.9%	3.4%
360	-0.4%	0.1%	12.5%	-0.9%	-0.1%	1.2%
720	-4.1%	0.4%	1.2%	-4.7%	0.5%	-9.8%
1440	-4.4%	0.4%	1.4%	-4.9%	0.5%	-9.0%

Figure 32: SCE Total, Summer, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon Minutes Ahead	Behind-the-Meter Solar Generation Source: Cloud Cover – Error Correction	Model Direct	Reconstituted Loads	Behind-the-Meter Solar Generation Source: Clean Power Research – Error Correction	Model Direct	Reconstituted Loads
15	8.25%	0.19%	29.91%	5.81%	0.14%	0.45%
30	4.57%	0.75%	22.64%	2.68%	-0.02%	0.47%
45	19.54%	1.29%	20.01%	22.08%	-0.48%	1.04%
60	15.18%	0.86%	23.96%	1.24%	-0.59%	1.05%
90	1.70%	1.24%	16.02%	1.74%	-1.00%	-0.18%
120	7.24%	1.36%	17.52%	1.58%	-0.91%	0.38%
180	4.15%	1.45%	13.17%	2.14%	-0.89%	0.39%
240	3.04%	1.34%	7.89%	2.27%	-0.31%	-0.52%
300	-0.22%	1.72%	9.35%	-0.98%	0.78%	2.32%
360	-3.56%	1.89%	6.79%	-4.64%	1.13%	-0.46%
720	-7.86%	1.85%	-6.70%	-9.23%	1.34%	-13.73%
1440	-8.06%	1.71%	-6.45%	-9.50%	1.14%	-12.29%

Forecast Skill (%)

Forecast Horizon Minutes Ahead	Behind-the-Meter Solar Generation Source: Cloud Cover – Error Correction	Model Direct	Reconstituted Loads	Behind-the-Meter Solar Generation Source: Clean Power Research – Error Correction	Model Direct	Reconstituted Loads
15	40.4%	49.6%	39.5%	41.9%	49.8%	49.4%
30	43.0%	49.0%	39.9%	45.2%	50.0%	48.8%
45	42.8%	49.0%	39.9%	44.8%	50.6%	48.5%
60	43.4%	49.1%	39.9%	47.3%	50.7%	48.8%
90	45.2%	47.7%	41.5%	45.6%	50.0%	50.6%
120	44.9%	47.6%	40.1%	46.4%	50.8%	49.9%
180	45.3%	46.1%	42.1%	45.3%	50.5%	49.3%
240	47.1%	46.4%	44.3%	46.2%	47.9%	50.8%
300	50.7%	45.3%	48.2%	51.5%	47.3%	53.2%
360	53.5%	45.8%	49.7%	54.8%	46.6%	55.2%
720	55.8%	45.9%	57.6%	56.8%	47.0%	61.5%
1440	56.0%	46.0%	57.4%	57.0%	47.3%	61.0%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon Minutes Ahead	Behind-the-Meter Solar Generation Source: Cloud Cover – Error Correction	Model Direct	Reconstituted Loads	Behind-the-Meter Solar Generation Source: Clean Power Research – Error Correction	Model Direct	Reconstituted Loads
15	3.7%	0.2%	18.4%	2.2%	0.1%	-0.9%
30	3.0%	0.6%	14.7%	1.7%	0.3%	0.2%
45	14.5%	0.8%	13.7%	16.5%	0.0%	0.7%
60	11.7%	0.5%	18.0%	0.6%	-0.2%	0.7%
90	1.2%	0.6%	11.6%	1.0%	-0.3%	0.3%
120	5.0%	0.7%	13.0%	0.6%	-0.5%	0.6%
180	2.7%	0.7%	10.2%	0.9%	-0.6%	0.8%
240	2.5%	0.9%	6.5%	1.4%	0.0%	-0.1%
300	0.6%	1.4%	5.5%	-0.5%	1.1%	0.7%
360	-2.2%	1.7%	2.2%	-3.4%	1.6%	-1.7%
720	-7.7%	1.7%	-8.4%	-9.0%	1.7%	-11.8%
1440	-7.9%	1.7%	-8.1%	-9.2%	1.7%	-10.8%

Figure 33: SCE Total, All Seasons, Clear

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon Minutes Ahead	Behind-the-Meter Solar Generation Source: Cloud Cover — Error Correction	Model Direct	Reconstituted Loads	Behind-the-Meter Solar Generation Source: Clean Power Research — Error Correction	Model Direct	Reconstituted Loads
15	10.88%	-0.18%	21.15%	7.72%	0.13%	1.29%
30	6.61%	-0.28%	16.53%	4.56%	-0.36%	0.80%
45	14.45%	-0.10%	14.67%	14.36%	-0.61%	1.14%
60	12.40%	0.00%	17.94%	2.20%	-1.01%	1.75%
90	2.71%	0.63%	12.80%	2.54%	-1.09%	1.18%
120	6.06%	0.70%	13.89%	2.05%	-1.31%	1.83%
180	3.79%	0.83%	10.99%	2.37%	-1.58%	2.05%
240	2.75%	0.27%	8.20%	2.57%	-1.63%	1.04%
300	-0.17%	0.33%	12.19%	-0.03%	-0.85%	4.30%
360	-2.93%	0.69%	10.39%	-2.89%	-0.07%	1.66%
720	-6.50%	1.02%	-2.54%	-7.02%	0.71%	-11.20%
1440	-6.89%	0.93%	-2.29%	-7.37%	0.62%	-10.01%

Forecast Skill (%)

Forecast Horizon Minutes Ahead	Behind-the-Meter Solar Generation Source: Cloud Cover — Error Correction	Model Direct	Reconstituted Loads	Behind-the-Meter Solar Generation Source: Clean Power Research — Error Correction	Model Direct	Reconstituted Loads
15	38.5%	50.3%	40.7%	40.9%	49.6%	48.4%
30	40.8%	49.8%	41.2%	43.2%	49.6%	48.8%
45	41.8%	50.5%	41.2%	43.9%	50.3%	48.5%
60	42.6%	50.2%	41.5%	46.2%	51.4%	48.7%
90	44.1%	48.1%	42.5%	44.9%	50.2%	49.2%
120	44.1%	48.1%	41.7%	45.4%	51.0%	48.6%
180	44.6%	47.8%	43.0%	44.5%	51.2%	48.1%
240	46.5%	49.1%	43.5%	46.0%	50.4%	49.1%
300	50.1%	49.1%	46.2%	50.4%	50.3%	51.0%
360	52.3%	48.8%	47.3%	52.5%	49.2%	52.6%
720	54.1%	47.9%	55.0%	54.3%	48.0%	59.3%
1440	54.6%	47.9%	54.8%	54.6%	48.1%	59.1%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon Minutes Ahead	Behind-the-Meter Solar Generation Source: Cloud Cover — Error Correction	Model Direct	Reconstituted Loads	Behind-the-Meter Solar Generation Source: Clean Power Research — Error Correction	Model Direct	Reconstituted Loads
15	5.1%	0.0%	13.6%	3.1%	0.0%	-0.2%
30	4.2%	0.0%	11.2%	2.8%	0.0%	0.4%
45	11.3%	-0.1%	10.3%	11.6%	-0.2%	0.9%
60	8.9%	0.0%	13.8%	1.1%	-0.5%	1.5%
90	1.6%	0.4%	9.5%	1.3%	-0.4%	1.1%
120	3.5%	0.4%	10.1%	0.7%	-0.8%	1.7%
180	2.0%	0.4%	8.0%	1.0%	-1.2%	1.7%
240	1.8%	0.4%	5.8%	1.4%	-0.9%	0.7%
300	0.1%	0.8%	7.3%	-0.3%	0.2%	2.1%
360	-2.4%	1.2%	4.8%	-2.9%	0.9%	-0.5%
720	-6.9%	1.4%	-6.1%	-7.6%	1.4%	-11.1%
1440	-7.1%	1.4%	-5.8%	-7.8%	1.4%	-10.3%

Figure 34: SCE Total, All Seasons, Cloudy

Change in Forecast Mean Absolute Percentage Error (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	5.21%	0.33%	37.90%	6.01%	0.24%	1.27%
30	4.20%	0.83%	27.21%	3.96%	-0.49%	0.54%
45	10.62%	0.70%	23.59%	12.38%	-1.63%	0.67%
60	19.37%	0.60%	24.16%	3.02%	-1.87%	-0.10%
90	3.68%	0.75%	17.00%	3.58%	-1.65%	-1.56%
120	11.38%	0.96%	16.46%	3.41%	-2.01%	-2.05%
180	8.52%	1.10%	12.35%	3.64%	-1.85%	-2.51%
240	6.99%	1.14%	7.54%	3.22%	-0.93%	-3.84%
300	3.39%	1.38%	13.07%	0.41%	0.66%	0.59%
360	0.43%	1.56%	13.37%	-2.48%	1.23%	-0.39%
720	-2.59%	1.49%	2.67%	-5.42%	1.31%	-10.42%
1440	-3.02%	1.41%	2.63%	-5.95%	1.15%	-9.37%

Forecast Skill (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	41.9%	49.7%	37.8%	41.1%	50.0%	48.1%
30	42.4%	50.2%	39.3%	42.5%	51.1%	48.9%
45	42.3%	50.3%	39.3%	43.0%	53.0%	49.8%
60	39.0%	49.8%	40.0%	44.2%	52.7%	51.1%
90	40.2%	50.3%	40.6%	40.9%	51.9%	51.1%
120	40.2%	49.7%	41.4%	41.9%	51.8%	51.1%
180	40.8%	48.8%	43.6%	41.6%	52.0%	51.4%
240	42.5%	48.6%	45.8%	43.5%	49.6%	53.1%
300	46.9%	48.2%	45.0%	48.5%	47.9%	53.8%
360	50.7%	47.8%	44.6%	52.4%	48.1%	53.0%
720	54.0%	46.6%	50.2%	55.4%	47.8%	57.5%
1440	54.5%	46.9%	50.2%	55.9%	48.1%	57.0%

Change in Forecast Error Standard Deviation (MW)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	3.2%	0.1%	27.1%	3.1%	0.0%	0.3%
30	2.7%	0.4%	17.8%	2.5%	-0.1%	0.0%
45	8.5%	0.3%	16.0%	10.3%	-0.8%	0.2%
60	14.3%	0.1%	16.8%	1.6%	-1.2%	-0.2%
90	2.3%	0.2%	11.7%	2.1%	-1.2%	-1.3%
120	9.7%	0.4%	13.5%	2.4%	-1.9%	-1.5%
180	7.4%	0.3%	11.4%	2.7%	-1.6%	-1.2%
240	6.6%	0.6%	7.9%	3.2%	-0.7%	-2.2%
300	3.9%	1.0%	10.7%	1.4%	0.7%	0.3%
360	0.6%	1.1%	9.4%	-1.3%	1.2%	-1.1%
720	-4.8%	0.8%	-0.6%	-6.0%	1.0%	-10.8%
1440	-5.1%	0.9%	-0.6%	-6.3%	1.1%	-9.7%

5.6 SCE Coastal Simulation Results

Figure 35 through Figure 39 presents the results for SCE Coastal across all seasons, and cloud cover conditions.

- **Forecast Horizons of 15 Minutes Ahead to Four Hours Ahead**. For forecast horizons of one-hour ahead up to four hours ahead, only the Model Direct approach combined with the CPR solar generation estimates outperformed the baseline load forecast model. For forecast horizons of less than one-hour ahead the baseline load forecast outperformed the alternative approaches.

- **Forecast Horizons of Five Hours Ahead to Six Hours Ahead**. For forecast horizons of five hours ahead to six hours ahead, the Model Direct approach combined with CPR solar generation estimates outperformed all other approaches.

- **Forecast Horizons of 12 Hours Ahead to 24 Hours Ahead**. For longer-term forecast horizons of 12 hours ahead to 24 hours ahead, the Error Correction and Reconstituted Load approaches were on average more accurate than the baseline load forecast.

- **Seasonal Differences.** The main difference between the winter and summer seasons is the Model Direct approach when combined with the CPR solar generation estimates performed during the winter season for forecast horizons of 30 minutes ahead to 24 hours ahead. In contrast, the Model Direct approach did not outperformed the baseline model during the summer season across all forecast horizons.

- **Cloud Cover.** In contrast to other load zones, the alternative approaches appear to work best under clear cloud conditions. Most notably, the Model Direct approach when combined with the CPR solar generation estimates outperformed the baseline load forecast over forecast horizons of 30 minutes ahead to 24 hours ahead.

Figure 35: SCE Coastal, All Seasons, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	11.40%	0.58%	24.66%	9.09%	0.97%	1.26%
30	7.53%	0.76%	19.49%	5.76%	0.41%	0.50%
45	11.98%	0.93%	17.80%	12.13%	0.16%	0.64%
60	15.10%	0.88%	22.95%	3.90%	-0.15%	0.97%
90	5.21%	1.74%	16.74%	5.09%	-0.29%	0.01%
120	10.20%	2.01%	19.29%	4.86%	-0.55%	0.76%
180	8.18%	2.27%	16.42%	5.62%	-0.61%	1.03%
240	6.25%	1.50%	11.34%	5.30%	-0.65%	-0.55%
300	0.61%	0.83%	13.75%	0.24%	-0.53%	4.20%
360	-3.80%	0.77%	11.00%	-4.35%	-0.34%	2.43%
720	-9.46%	0.76%	-3.11%	-10.61%	0.17%	-9.55%
1440	-9.55%	0.61%	-2.65%	-10.70%	0.01%	-6.89%

Forecast Skill (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	37.8%	48.9%	39.4%	39.1%	47.9%	48.2%
30	39.6%	48.9%	40.1%	41.0%	49.3%	48.8%
45	41.0%	49.2%	39.9%	42.2%	50.5%	48.5%
60	40.9%	49.5%	40.5%	43.8%	51.5%	49.8%
90	40.0%	47.2%	41.1%	40.0%	49.8%	50.1%
120	40.0%	47.1%	40.5%	40.6%	50.7%	49.8%
180	40.0%	46.2%	41.4%	39.2%	51.1%	49.0%
240	42.0%	46.8%	42.3%	41.0%	49.1%	50.1%
300	49.1%	48.1%	45.4%	49.8%	49.0%	51.8%
360	53.0%	48.7%	46.8%	53.6%	49.1%	52.3%
720	57.4%	48.6%	54.2%	57.5%	49.8%	57.9%
1440	57.7%	48.9%	53.7%	57.6%	50.2%	56.9%

Change in Forecast Error Standard Deviation (MW)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	5.8%	0.5%	16.4%	4.2%	0.5%	0.5%
30	4.9%	0.8%	12.4%	3.9%	0.7%	0.4%
45	8.1%	0.7%	11.4%	7.9%	0.5%	0.4%
60	10.6%	0.6%	16.7%	2.2%	0.1%	0.8%
90	3.1%	1.1%	12.0%	2.9%	0.2%	0.3%
120	6.4%	1.4%	14.5%	2.6%	-0.2%	1.0%
180	5.5%	1.7%	12.9%	3.6%	-0.1%	1.3%
240	5.8%	1.7%	10.0%	4.6%	0.5%	0.0%
300	1.9%	1.5%	11.4%	1.1%	1.0%	2.9%
360	-2.3%	1.3%	7.9%	-3.1%	1.0%	0.5%
720	-9.0%	0.9%	-4.7%	-10.0%	0.7%	-10.1%
1440	-9.2%	0.8%	-4.5%	-10.1%	0.6%	-8.3%

Figure 36: SCE Coastal, Winter, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	12.61%	-0.21%	17.42%	10.30%	0.67%	1.65%
30	9.20%	-0.95%	13.68%	7.74%	-0.37%	0.46%
45	8.67%	-1.14%	12.21%	6.97%	-0.74%	0.08%
60	13.80%	-0.38%	15.22%	4.94%	-1.51%	0.10%
90	6.57%	0.17%	11.87%	6.13%	-1.48%	0.13%
120	9.87%	0.61%	13.02%	5.39%	-2.18%	0.66%
180	9.26%	0.87%	11.88%	6.08%	-2.37%	1.46%
240	7.03%	-0.03%	9.90%	5.50%	-2.97%	0.02%
300	0.99%	-0.57%	16.72%	0.67%	-2.88%	6.55%
360	-4.08%	-0.39%	15.07%	-4.37%	-2.08%	5.25%
720	-10.87%	-0.08%	1.80%	-11.81%	-0.10%	-5.92%
1440	-11.29%	-0.30%	2.56%	-12.04%	-0.22%	-3.56%

Forecast Skill (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	36.7%	50.4%	41.0%	38.3%	48.5%	47.6%
30	37.5%	51.2%	41.8%	38.2%	49.2%	48.8%
45	39.1%	51.7%	41.9%	40.4%	50.9%	48.9%
60	38.8%	51.0%	43.1%	42.1%	53.3%	50.9%
90	38.1%	49.5%	43.3%	38.5%	51.9%	49.6%
120	38.7%	48.9%	43.9%	39.3%	52.8%	49.7%
180	38.4%	49.3%	44.4%	38.5%	53.5%	48.8%
240	40.9%	50.4%	43.2%	41.3%	53.2%	49.1%
300	47.9%	51.7%	42.8%	48.4%	53.4%	49.6%
360	52.4%	51.8%	43.6%	51.9%	53.5%	49.4%
720	56.9%	51.0%	50.2%	56.5%	50.8%	54.1%
1440	57.6%	51.7%	49.4%	56.7%	51.1%	53.2%

Change in Forecast Error Standard Deviation (MW)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	7.4%	0.0%	12.5%	5.6%	0.2%	0.9%
30	6.5%	-0.1%	9.2%	5.6%	0.0%	0.0%
45	6.2%	-0.4%	7.8%	4.5%	-0.4%	-0.4%
60	9.5%	-0.1%	10.8%	2.9%	-0.9%	0.0%
90	3.8%	0.2%	8.7%	3.5%	-1.2%	-0.1%
120	6.2%	0.6%	9.8%	3.0%	-1.8%	0.9%
180	6.4%	0.7%	9.3%	3.9%	-2.1%	1.6%
240	6.4%	0.2%	9.1%	5.0%	-1.9%	1.1%
300	2.0%	0.0%	15.6%	1.5%	-1.2%	5.9%
360	-2.5%	0.0%	12.8%	-2.9%	-0.8%	3.3%
720	-9.4%	-0.1%	-0.9%	-10.0%	-0.1%	-9.1%
1440	-9.8%	-0.2%	-0.5%	-10.2%	-0.1%	-7.1%

Figure 37: SCE Coastal, Summer, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	10.27%	1.33%	31.48%	7.95%	1.26%	0.89%
30	5.95%	2.38%	24.96%	3.89%	1.14%	0.55%
45	15.16%	2.91%	23.20%	17.10%	1.03%	1.19%
60	16.35%	2.09%	30.38%	2.91%	1.14%	1.82%
90	3.94%	3.19%	21.25%	4.12%	0.81%	-0.10%
120	10.51%	3.29%	25.04%	4.37%	0.94%	0.84%
180	7.22%	3.50%	20.44%	5.21%	0.95%	0.64%
240	5.59%	2.81%	12.57%	5.13%	1.35%	-1.04%
300	0.29%	2.00%	11.27%	-0.12%	1.42%	2.24%
360	-3.58%	1.74%	7.64%	-4.33%	1.09%	0.10%
720	-8.31%	1.45%	-7.13%	-9.63%	0.40%	-12.52%
1440	-8.15%	1.35%	-6.84%	-9.63%	0.20%	-9.56%

Forecast Skill (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	38.9%	47.4%	37.8%	39.8%	47.4%	48.7%
30	41.7%	46.5%	38.4%	43.7%	49.4%	48.9%
45	42.9%	46.7%	38.1%	44.0%	50.2%	48.1%
60	42.9%	48.1%	37.9%	45.4%	49.8%	48.8%
90	41.9%	44.9%	39.1%	41.6%	47.7%	50.6%
120	41.3%	45.3%	37.2%	41.8%	48.8%	49.9%
180	41.5%	43.2%	38.5%	39.8%	48.7%	49.1%
240	43.1%	43.2%	41.4%	40.7%	45.1%	51.0%
300	50.3%	44.6%	47.9%	51.2%	44.7%	53.9%
360	53.6%	45.7%	49.9%	55.2%	44.8%	55.1%
720	57.9%	46.2%	58.1%	58.5%	48.8%	61.6%
1440	57.8%	46.3%	57.8%	58.5%	49.3%	60.4%

Change in Forecast Error Standard Deviation (MW)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	4.6%	0.8%	19.1%	3.2%	0.7%	0.3%
30	3.7%	1.6%	14.8%	2.7%	1.2%	0.7%
45	9.1%	1.6%	14.2%	9.9%	1.1%	1.1%
60	11.4%	1.3%	21.4%	1.6%	1.0%	1.4%
90	2.5%	1.8%	14.4%	2.4%	1.1%	0.6%
120	6.5%	2.0%	17.6%	2.3%	1.0%	1.1%
180	5.0%	2.3%	15.2%	3.4%	1.1%	1.1%
240	5.4%	2.6%	10.8%	4.3%	1.9%	-0.5%
300	1.7%	2.5%	9.0%	0.7%	2.4%	1.3%
360	-2.5%	2.1%	4.8%	-3.6%	2.2%	-1.1%
720	-9.2%	1.6%	-7.6%	-10.4%	1.3%	-10.8%
1440	-9.4%	1.5%	-7.5%	-10.6%	1.3%	-9.1%

Figure 38: SCE Coastal, All Seasons, Clear

Change in Forecast Mean Absolute Percentage Error (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	13.28%	0.34%	21.79%	9.80%	0.71%	0.82%
30	8.23%	0.15%	17.35%	5.98%	-0.09%	-0.21%
45	13.27%	0.43%	15.98%	12.57%	-0.15%	-0.17%
60	14.70%	0.47%	21.71%	4.00%	-0.49%	0.80%
90	5.19%	1.55%	16.20%	5.02%	-0.69%	0.19%
120	9.63%	1.75%	18.87%	4.63%	-1.06%	0.85%
180	7.54%	1.92%	16.10%	5.37%	-1.19%	1.16%
240	5.63%	0.89%	11.45%	5.21%	-1.49%	0.04%
300	-0.25%	0.24%	13.52%	0.07%	-1.48%	4.63%
360	-4.98%	0.30%	10.65%	-4.64%	-1.14%	2.27%
720	-11.14%	0.48%	-3.48%	-11.29%	-0.20%	-10.66%
1440	-11.12%	0.32%	-2.94%	-11.27%	-0.35%	-7.94%

Forecast Skill (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	36.9%	48.7%	40.1%	39.0%	48.0%	48.6%
30	39.6%	49.0%	40.7%	41.5%	49.6%	49.5%
45	41.3%	49.3%	40.5%	42.5%	50.9%	48.6%
60	41.0%	49.8%	40.5%	43.8%	51.7%	49.7%
90	40.9%	46.9%	41.1%	40.8%	49.9%	49.8%
120	40.7%	47.1%	40.3%	41.2%	51.3%	49.7%
180	40.4%	46.0%	41.5%	39.5%	51.7%	48.6%
240	42.6%	47.0%	41.8%	41.7%	49.9%	49.4%
300	50.1%	48.7%	45.6%	50.3%	50.0%	51.2%
360	53.8%	49.2%	46.9%	53.8%	49.9%	52.2%
720	58.0%	48.7%	54.2%	57.3%	49.5%	58.4%
1440	58.2%	49.1%	53.6%	57.4%	49.9%	57.4%

Change in Forecast Error Standard Deviation (MW)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	6.3%	0.3%	15.0%	4.3%	0.4%	0.5%
30	5.3%	0.5%	11.7%	4.0%	0.5%	0.3%
45	9.0%	0.3%	11.0%	8.1%	0.3%	0.4%
60	10.6%	0.3%	16.8%	2.4%	-0.1%	1.0%
90	3.1%	0.8%	11.7%	2.9%	-0.1%	0.5%
120	5.7%	1.0%	13.8%	2.3%	-0.7%	1.0%
180	4.7%	1.2%	12.0%	3.0%	-1.0%	1.1%
240	4.8%	1.4%	9.5%	3.9%	-0.4%	0.0%
300	1.1%	1.5%	11.4%	0.4%	0.6%	3.2%
360	-2.9%	1.4%	7.9%	-3.8%	0.9%	0.8%
720	-9.4%	1.1%	-5.3%	-10.5%	0.8%	-10.4%
1440	-9.5%	1.0%	-5.0%	-10.5%	0.7%	-8.6%

Figure 39: SCE Coastal, All Seasons, Cloudy

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	6.43%	1.21%	32.28%	7.19%	1.68%	2.41%
30	5.67%	2.38%	25.16%	5.19%	1.73%	2.40%
45	8.51%	2.26%	22.74%	10.96%	1.01%	2.83%
60	16.19%	1.98%	26.29%	3.64%	0.75%	1.44%
90	5.27%	2.23%	18.12%	5.26%	0.75%	-0.47%
120	11.76%	2.71%	20.43%	5.49%	0.83%	0.50%
180	9.88%	3.18%	17.28%	6.28%	0.94%	0.66%
240	7.88%	3.08%	11.04%	5.55%	1.55%	-2.10%
300	2.88%	2.40%	14.34%	0.69%	1.96%	3.05%
360	-0.65%	2.05%	11.95%	-3.57%	1.79%	2.84%
720	-4.88%	1.52%	-2.10%	-8.77%	1.20%	-6.50%
1440	-5.34%	1.40%	-1.87%	-9.16%	0.99%	-4.09%

Forecast Skill (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	40.4%	49.6%	37.6%	39.3%	47.6%	47.0%
30	39.6%	48.4%	38.2%	39.5%	48.4%	46.9%
45	40.2%	48.7%	38.2%	41.6%	49.5%	48.2%
60	40.4%	48.6%	40.3%	43.6%	51.0%	50.1%
90	37.5%	47.9%	41.2%	37.7%	49.4%	51.1%
120	38.0%	47.1%	41.0%	38.9%	49.2%	50.2%
180	38.6%	46.7%	41.2%	38.2%	49.3%	49.9%
240	40.4%	45.9%	43.6%	39.1%	46.9%	52.0%
300	46.1%	46.3%	44.7%	48.3%	46.0%	53.5%
360	50.7%	47.4%	46.4%	52.9%	46.7%	52.4%
720	55.9%	48.1%	54.2%	58.2%	50.5%	56.4%
1440	56.4%	48.4%	53.8%	58.3%	51.1%	55.4%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	4.4%	0.8%	20.1%	3.8%	1.1%	0.5%
30	3.8%	1.6%	14.2%	3.5%	1.4%	0.8%
45	5.4%	1.5%	12.1%	7.1%	0.9%	0.5%
60	10.3%	1.1%	15.7%	1.8%	0.5%	0.3%
90	3.1%	1.6%	12.1%	2.9%	0.9%	-0.2%
120	8.4%	2.1%	14.9%	3.9%	0.9%	1.2%
180	8.1%	2.3%	13.9%	5.4%	1.7%	2.0%
240	8.3%	2.7%	10.7%	6.2%	3.0%	0.2%
300	4.7%	2.4%	12.7%	3.0%	3.2%	3.3%
360	0.7%	1.9%	9.7%	-0.9%	2.7%	1.7%
720	-5.9%	1.1%	-1.9%	-7.5%	1.3%	-7.2%
1440	-6.3%	1.1%	-1.9%	-8.0%	1.4%	-5.3%

5.7 SCE Inland Simulation Results

Figure 40 through Figure 44 presents the results for SCE Inland across all seasons, and cloud cover conditions.

- **Forecast Horizons of 15 Minutes Ahead to Four Hours Ahead**: For forecast horizons of one-hour ahead up to four hours ahead, only the Model Direct approach combined with CPR's and the Cloud Cover driven estimates of solar generation outperformed the baseline load forecast model.
- **Forecast Horizons of Five Hours Ahead to Six Hours Ahead**: For forecast horizons of five hours ahead to six hours ahead, the Model Direct approach combined with CPR solar generation estimates outperformed all other approaches.
- **Forecast Horizons of 12 Hours Ahead to 24 Hours Ahead**: For longer-term forecast horizons of 12 hours ahead to 24 hours ahead, the Error Correction and Reconstituted Load approaches were on average more accurate than the baseline load forecast.
- **Seasonal Differences:** The main difference between the winter and summer seasons is the Error Correction approach when combined with the CPR solar generation estimates performed well during the summer season, but not so in the winter season.
- **Cloud Cover:** In general, the alternative approaches combined with the CPR solar generation estimates worked better under Cloudy conditions.

Figure 40: SCE Inland, All Seasons, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	7.39%	-0.58%	26.94%	5.58%	-0.57%	1.30%
30	4.46%	-0.62%	19.70%	3.14%	-1.12%	0.93%
45	14.59%	-0.58%	16.69%	15.29%	-1.86%	1.33%
60	13.75%	-0.46%	16.80%	1.11%	-2.24%	1.44%
90	1.02%	-0.28%	11.59%	0.86%	-2.10%	0.73%
120	5.30%	-0.29%	10.59%	0.34%	-2.33%	0.71%
180	2.59%	-0.22%	7.17%	0.32%	-2.53%	0.54%
240	1.92%	-0.34%	5.12%	0.52%	-2.12%	-0.13%
300	1.01%	0.42%	11.16%	-0.05%	-0.33%	2.37%
360	-0.15%	1.10%	11.44%	-1.17%	0.94%	-0.28%
720	-1.17%	1.56%	1.01%	-2.34%	1.61%	-12.49%
1440	-1.91%	1.54%	0.89%	-3.08%	1.55%	-12.90%

Forecast Skill (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	41.1%	51.4%	40.4%	42.9%	51.5%	48.5%
30	42.9%	51.0%	41.3%	45.0%	50.7%	48.8%
45	42.8%	51.8%	41.4%	45.1%	51.5%	49.3%
60	42.3%	50.7%	41.7%	47.6%	52.0%	48.8%
90	46.1%	50.2%	42.8%	47.6%	51.6%	49.3%
120	46.1%	50.0%	42.7%	48.3%	51.8%	48.7%
180	47.2%	49.9%	44.9%	48.3%	51.8%	49.0%
240	48.9%	51.2%	46.0%	49.6%	51.2%	50.3%
300	49.4%	49.6%	46.3%	49.9%	50.3%	51.8%
360	50.7%	48.4%	46.4%	51.3%	48.7%	53.1%
720	50.8%	46.5%	53.2%	51.7%	46.2%	59.7%
1440	51.4%	46.3%	53.4%	52.4%	46.1%	60.2%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	3.6%	-0.3%	18.2%	2.1%	-0.4%	-0.6%
30	2.7%	-0.5%	14.3%	1.6%	-0.7%	0.2%
45	12.4%	-0.4%	12.8%	13.8%	-1.1%	0.9%
60	10.7%	-0.4%	13.6%	0.4%	-1.3%	1.1%
90	0.8%	-0.1%	9.3%	0.4%	-1.2%	0.4%
120	4.4%	-0.2%	9.4%	0.0%	-1.6%	0.6%
180	2.1%	-0.2%	7.2%	0.0%	-1.8%	0.7%
240	1.5%	-0.2%	4.6%	0.1%	-1.4%	0.0%
300	0.6%	0.4%	5.7%	-0.7%	-0.1%	0.7%
360	-0.8%	1.1%	4.2%	-2.0%	1.0%	-1.8%
720	-3.4%	1.5%	-4.2%	-4.4%	1.9%	-12.0%
1440	-3.6%	1.7%	-4.0%	-4.6%	2.0%	-12.2%

Figure 41: SCE Inland, Winter, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	8.40%	-0.30%	25.43%	7.33%	-0.25%	2.55%
30	5.63%	-0.47%	18.94%	4.75%	-1.13%	1.46%
45	5.75%	-0.96%	16.34%	4.08%	-1.86%	1.75%
60	13.42%	-0.63%	15.63%	2.49%	-2.29%	2.52%
90	2.41%	-0.04%	11.89%	2.18%	-1.56%	1.75%
120	6.28%	-0.23%	10.27%	1.61%	-2.11%	1.48%
180	3.73%	-0.14%	7.36%	1.18%	-2.60%	0.94%
240	3.19%	-0.74%	6.68%	1.42%	-2.50%	-0.22%
300	2.95%	-0.70%	15.30%	1.94%	-0.83%	2.33%
360	3.59%	0.04%	17.56%	3.04%	0.68%	0.58%
720	5.29%	0.78%	8.58%	4.38%	0.79%	-9.76%
1440	4.52%	0.91%	8.23%	3.58%	0.86%	-10.30%

Forecast Skill (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	40.3%	51.0%	39.7%	41.8%	50.7%	47.0%
30	41.3%	50.6%	41.2%	43.4%	50.9%	49.0%
45	42.9%	52.3%	41.1%	44.7%	52.0%	49.8%
60	40.7%	51.3%	41.5%	46.0%	52.4%	48.7%
90	43.6%	49.9%	41.6%	45.5%	50.8%	48.0%
120	43.5%	50.2%	42.4%	45.5%	50.6%	47.4%
180	45.3%	50.8%	44.1%	45.8%	51.3%	48.6%
240	46.7%	52.8%	44.8%	47.4%	51.8%	50.1%
300	47.6%	53.4%	44.2%	48.0%	50.8%	51.0%
360	48.0%	51.0%	43.2%	48.1%	49.0%	50.8%
720	47.6%	47.5%	49.2%	48.3%	47.2%	58.0%
1440	48.4%	46.9%	49.6%	49.1%	46.9%	58.7%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	4.6%	-0.6%	18.9%	3.3%	-0.4%	1.3%
30	3.4%	-1.0%	13.7%	2.7%	-1.0%	0.8%
45	3.0%	-1.3%	12.1%	1.9%	-1.5%	1.7%
60	8.8%	-0.9%	11.4%	1.2%	-1.4%	2.2%
90	1.5%	-0.4%	8.6%	1.1%	-1.1%	1.1%
120	4.8%	-0.4%	8.4%	0.9%	-1.7%	1.2%
180	3.2%	-0.4%	6.4%	0.8%	-2.2%	0.8%
240	2.5%	-0.7%	5.1%	0.7%	-2.1%	-0.2%
300	1.8%	-0.4%	11.2%	0.6%	-0.7%	1.3%
360	1.3%	0.3%	12.1%	0.5%	0.6%	-0.9%
720	0.9%	1.0%	3.5%	0.2%	1.2%	-10.6%
1440	0.6%	1.2%	3.3%	-0.1%	1.3%	-11.0%

Figure 42: SCE Inland, Summer, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	6.38%	-0.86%	28.46%	3.83%	-0.89%	0.05%
30	3.29%	-0.77%	20.46%	1.54%	-1.11%	0.40%
45	23.58%	-0.21%	17.06%	26.68%	-1.87%	0.91%
60	14.09%	-0.30%	18.00%	-0.31%	-2.19%	0.33%
90	-0.32%	-0.52%	11.30%	-0.41%	-2.62%	-0.25%
120	4.36%	-0.34%	10.90%	-0.87%	-2.54%	-0.03%
180	1.54%	-0.30%	6.99%	-0.47%	-2.46%	0.18%
240	0.78%	0.03%	3.73%	-0.28%	-1.78%	-0.05%
300	-0.73%	1.43%	7.43%	-1.84%	0.13%	2.39%
360	-3.54%	2.05%	5.89%	-4.97%	1.18%	-1.06%
720	-7.35%	2.31%	-6.22%	-8.77%	2.39%	-15.10%
1440	-7.96%	2.13%	-6.02%	-9.35%	2.20%	-15.35%

Forecast Skill (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	42.0%	51.9%	41.1%	44.0%	52.3%	50.1%
30	44.3%	51.4%	41.3%	46.6%	50.5%	48.7%
45	42.8%	51.3%	41.8%	45.6%	51.0%	48.8%
60	43.9%	50.0%	42.0%	49.1%	51.5%	48.9%
90	48.5%	50.5%	44.0%	49.7%	52.3%	50.6%
120	48.5%	49.8%	43.0%	51.0%	52.9%	50.0%
180	49.1%	49.0%	45.7%	50.7%	52.2%	49.5%
240	51.0%	49.6%	47.2%	51.8%	50.6%	50.6%
300	51.2%	46.0%	48.4%	51.7%	49.9%	52.5%
360	53.3%	45.9%	49.6%	54.5%	48.4%	55.4%
720	53.8%	45.6%	57.0%	55.1%	45.2%	61.3%
1440	54.2%	45.7%	57.0%	55.5%	45.3%	61.6%

Change in Forecast Error Standard Deviation (MW)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	3.1%	-0.2%	17.8%	1.4%	-0.4%	-1.7%
30	2.3%	-0.3%	14.6%	0.9%	-0.5%	-0.1%
45	18.6%	0.1%	13.2%	21.4%	-0.8%	0.4%
60	11.9%	-0.1%	15.2%	-0.3%	-1.2%	0.2%
90	0.3%	-0.2%	9.6%	-0.1%	-1.3%	0.1%
120	4.1%	-0.2%	9.9%	-0.6%	-1.5%	0.3%
180	1.5%	-0.3%	7.3%	-0.5%	-1.6%	0.7%
240	0.8%	-0.1%	4.0%	-0.3%	-1.2%	0.1%
300	-0.4%	0.7%	2.8%	-1.7%	0.1%	0.4%
360	-2.5%	1.5%	-0.2%	-3.8%	1.2%	-2.1%
720	-6.9%	2.0%	-9.4%	-8.1%	2.3%	-12.8%
1440	-7.1%	2.0%	-8.9%	-8.2%	2.3%	-12.8%

Figure 43: SCE Inland, All Seasons, Clear

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	8.70%	-0.65%	20.57%	5.82%	-0.40%	1.71%
30	5.09%	-0.68%	15.76%	3.23%	-0.61%	1.76%
45	15.56%	-0.59%	13.44%	16.04%	-1.04%	2.37%
60	10.26%	-0.44%	14.42%	0.51%	-1.48%	2.63%
90	0.46%	-0.20%	9.71%	0.30%	-1.46%	2.08%
120	2.87%	-0.24%	9.43%	-0.26%	-1.53%	2.71%
180	0.61%	-0.09%	6.64%	-0.18%	-1.91%	2.80%
240	0.22%	-0.27%	5.35%	0.25%	-1.76%	1.92%
300	-0.10%	0.42%	10.89%	-0.12%	-0.23%	3.97%
360	-0.80%	1.10%	10.13%	-1.07%	1.04%	1.01%
720	-1.51%	1.60%	-1.53%	-2.43%	1.68%	-11.78%
1440	-2.38%	1.59%	-1.60%	-3.20%	1.65%	-12.23%

Forecast Skill (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	40.3%	52.1%	41.4%	43.0%	51.2%	48.3%
30	42.0%	50.7%	41.6%	44.9%	49.6%	48.1%
45	42.2%	51.7%	41.9%	45.4%	49.6%	48.5%
60	44.2%	50.6%	42.5%	48.7%	51.1%	47.5%
90	47.4%	49.3%	43.9%	49.1%	50.6%	48.6%
120	47.6%	49.2%	43.1%	49.7%	50.8%	47.4%
180	48.9%	49.5%	44.6%	49.7%	50.7%	47.6%
240	50.6%	51.2%	45.3%	50.4%	50.9%	48.8%
300	50.1%	49.5%	46.7%	50.4%	50.6%	50.9%
360	50.7%	48.5%	47.7%	51.1%	48.5%	53.0%
720	50.1%	47.0%	55.8%	51.3%	46.5%	60.2%
1440	50.8%	46.6%	56.0%	51.8%	46.4%	60.8%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	4.1%	-0.3%	12.5%	2.1%	-0.3%	-0.7%
30	3.2%	-0.5%	10.7%	1.7%	-0.5%	0.6%
45	13.2%	-0.4%	9.6%	14.4%	-0.6%	1.4%
60	7.5%	-0.3%	11.2%	0.0%	-0.8%	1.8%
90	0.4%	0.0%	7.7%	0.0%	-0.6%	1.6%
120	1.9%	0.0%	7.4%	-0.4%	-0.9%	2.2%
180	0.3%	0.0%	5.4%	-0.3%	-1.3%	2.1%
240	0.0%	-0.1%	3.5%	-0.2%	-1.1%	1.2%
300	-0.8%	0.4%	4.4%	-1.0%	0.0%	1.5%
360	-2.1%	1.1%	2.3%	-2.3%	1.1%	-1.3%
720	-4.6%	1.7%	-6.6%	-4.9%	2.1%	-11.5%
1440	-4.8%	1.8%	-6.4%	-5.1%	2.2%	-11.8%

Figure 44: SCE Inland, All Seasons, Cloudy

Change in Forecast Mean Absolute Percentage Error (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	4.17%	-0.41%	42.68%	5.00%	-0.99%	0.29%
30	2.98%	-0.47%	28.93%	2.94%	-2.33%	-1.02%
45	12.34%	-0.56%	24.27%	13.53%	-3.78%	-1.08%
60	21.98%	-0.53%	22.41%	2.51%	-4.02%	-1.37%
90	2.37%	-0.48%	16.06%	2.19%	-3.64%	-2.48%
120	11.07%	-0.40%	13.35%	1.78%	-4.23%	-4.04%
180	7.46%	-0.54%	8.47%	1.56%	-4.04%	-5.01%
240	6.22%	-0.50%	4.56%	1.23%	-3.04%	-5.33%
300	3.88%	0.42%	11.85%	0.14%	-0.58%	-1.76%
360	1.48%	1.08%	14.77%	-1.41%	0.68%	-3.57%
720	-0.33%	1.47%	7.36%	-2.12%	1.42%	-14.27%
1440	-0.73%	1.41%	7.06%	-2.78%	1.32%	-14.58%

Forecast Skill (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	43.4%	49.8%	38.0%	42.8%	52.2%	49.1%
30	45.0%	51.8%	40.3%	45.2%	53.5%	50.7%
45	44.3%	51.9%	40.3%	44.4%	56.3%	51.3%
60	37.6%	50.9%	39.8%	44.8%	54.2%	52.0%
90	42.7%	52.5%	40.0%	43.8%	54.2%	51.1%
120	42.2%	52.2%	41.7%	44.7%	54.3%	51.9%
180	42.8%	50.8%	45.7%	44.8%	54.5%	52.7%
240	44.5%	51.1%	47.9%	47.6%	52.1%	54.1%
300	47.7%	49.9%	45.2%	48.6%	49.7%	54.1%
360	50.6%	48.2%	43.0%	52.0%	49.4%	53.6%
720	52.3%	45.3%	46.6%	52.9%	45.4%	58.4%
1440	52.8%	45.5%	46.8%	53.7%	45.4%	58.5%

Change in Forecast Error Standard Deviation (MW)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	2.5%	-0.4%	32.5%	2.5%	-0.7%	0.2%
30	1.9%	-0.4%	20.3%	1.7%	-1.1%	-0.5%
45	10.7%	-0.5%	18.9%	12.5%	-2.1%	0.0%
60	17.1%	-0.6%	17.6%	1.3%	-2.6%	-0.6%
90	1.7%	-0.7%	11.4%	1.4%	-2.6%	-2.0%
120	10.3%	-0.7%	12.6%	1.2%	-3.6%	-3.3%
180	6.6%	-0.8%	10.0%	1.0%	-3.5%	-3.1%
240	4.9%	-0.6%	6.2%	1.0%	-3.0%	-3.5%
300	2.6%	0.2%	9.8%	-0.4%	-1.2%	-1.4%
360	0.0%	0.8%	10.9%	-2.0%	0.2%	-2.4%
720	-3.9%	1.0%	3.0%	-4.5%	1.2%	-13.0%
1440	-4.0%	1.0%	3.2%	-4.7%	1.3%	-12.8%

5.8 SDG&E Total Simulation Results

Figure 45 through Figure 49 presents the results for SDG&E across all seasons, and cloud cover conditions.

- **Forecast Horizons of 15 Minutes Ahead to Four Hours Ahead**: For forecast horizons of up to four hours ahead, the Model Direct approach consistently outperformed the baseline load forecast model with both a reduced MAPE and smaller dispersion of forecast errors. Further, the Model Direct approach performed better than the baseline forecast when using both Cloud Cover driven and CPR computed solar generation estimates. However, the Model Direct approach when combined with the CPR solar generation estimates outperformed the same approach combined with the Cloud Cover driven solar generation estimates.
- **Forecast Horizons of Five Hours Ahead to Six Hours Ahead**: For forecast horizons of five hours ahead to six hours ahead, the Model Direct approach combined with both Cloud Cover driven and CPR solar generation estimates outperformed the baseline load forecast in terms of both accuracy and reduction of forecast error dispersion.
- **Forecast Horizons of 12 Hours Ahead to 24 Hours Ahead**: For longer-term forecast horizons of 12 hours ahead to 24 hours ahead, again the Model Direct approach combined with both Cloud Cover driven and CPR solar generation estimates outperformed the baseline load forecast in terms of both accuracy and reduction of forecast error dispersion.
- **Seasonal Differences:** The main difference between the winter and summer seasons is that the performance of the Reconstituted Loads approach degrades during the summer season.
- **Cloud Cover:** There is no substantial differences between the alternative approaches performance under cloudy versus sunny conditions.

Figure 45: SDG&E Total, All Seasons, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	17.83%	-0.83%	48.70%	14.05%	-3.10%	4.52%
30	8.51%	-0.82%	36.03%	6.25%	-3.97%	2.42%
45	16.97%	-0.47%	29.75%	25.13%	-5.43%	1.99%
60	21.53%	-0.78%	31.77%	2.51%	-6.03%	0.88%
90	0.79%	-0.85%	25.08%	1.34%	-7.28%	-2.33%
120	8.82%	-0.60%	22.01%	1.57%	-8.36%	-2.44%
180	4.26%	-0.85%	16.55%	1.39%	-10.00%	-4.21%
240	3.18%	-1.40%	12.95%	1.04%	-10.48%	-5.35%
300	2.85%	-2.30%	10.81%	-0.27%	-11.02%	-7.08%
360	4.37%	-2.91%	8.24%	-1.23%	-10.96%	-9.42%
720	17.67%	-4.46%	2.35%	0.96%	-8.72%	-14.51%
1440	18.91%	-4.75%	-4.64%	1.70%	-9.32%	-14.59%

Forecast Skill (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	34.1%	52.2%	36.1%	33.9%	54.9%	48.0%
30	38.3%	52.3%	37.4%	36.7%	55.6%	49.0%
45	38.7%	51.6%	38.8%	37.7%	56.3%	49.9%
60	38.8%	51.9%	39.3%	40.4%	57.3%	50.2%
90	42.3%	51.4%	40.0%	39.7%	56.9%	51.8%
120	42.1%	50.7%	42.3%	40.7%	57.9%	52.2%
180	43.8%	51.0%	43.6%	41.3%	58.8%	52.9%
240	45.4%	50.9%	44.5%	42.6%	58.3%	52.8%
300	45.2%	52.2%	44.6%	44.0%	58.3%	52.8%
360	43.3%	52.9%	45.9%	44.4%	57.7%	53.8%
720	36.3%	55.0%	50.1%	42.0%	55.8%	55.2%
1440	35.9%	55.4%	51.6%	41.2%	56.4%	55.2%

Change in Forecast Error Standard Deviation (MW)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	10.5%	-0.4%	41.9%	7.6%	-1.8%	3.0%
30	6.3%	-0.4%	31.4%	4.0%	-2.5%	2.3%
45	15.1%	-0.1%	26.0%	29.0%	-3.6%	3.0%
60	20.5%	-0.4%	29.5%	1.6%	-4.1%	2.4%
90	0.8%	-0.4%	23.0%	0.6%	-5.6%	-1.2%
120	8.1%	-0.3%	21.1%	0.3%	-6.4%	-1.0%
180	3.1%	-0.3%	15.6%	0.2%	-7.4%	-2.3%
240	1.9%	-0.4%	12.1%	-0.3%	-7.6%	-3.5%
300	2.0%	-0.9%	10.1%	-1.4%	-7.8%	-5.0%
360	3.9%	-1.5%	9.0%	-2.1%	-7.8%	-7.2%
720	16.2%	-3.8%	10.7%	0.1%	-7.2%	-12.9%
1440	17.2%	-4.1%	-4.8%	0.6%	-7.7%	-13.3%

Figure 46: SDG&E Total, Winter, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	18.25%	-1.36%	31.54%	14.96%	-4.46%	3.77%
30	9.29%	-1.65%	22.11%	7.39%	-5.28%	0.34%
45	9.62%	-1.71%	19.40%	10.54%	-6.96%	-0.31%
60	13.33%	-1.87%	19.85%	2.62%	-8.06%	-1.93%
90	1.50%	-2.27%	13.85%	1.71%	-9.15%	-6.02%
120	4.16%	-2.20%	11.03%	1.18%	-10.62%	-6.15%
180	1.85%	-2.90%	6.82%	0.68%	-11.81%	-7.33%
240	0.70%	-3.48%	4.30%	-0.16%	-12.47%	-8.67%
300	-1.07%	-4.35%	5.21%	-2.10%	-13.21%	-9.34%
360	-0.56%	-5.41%	5.35%	-3.22%	-13.75%	-10.43%
720	12.64%	-7.91%	2.44%	0.95%	-11.30%	-12.48%
1440	13.79%	-7.95%	-4.93%	2.42%	-11.56%	-12.17%

Forecast Skill (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	29.2%	54.1%	39.7%	30.5%	56.1%	48.6%
30	33.0%	54.3%	41.3%	33.1%	56.9%	50.5%
45	35.6%	53.8%	41.1%	36.0%	57.8%	51.8%
60	35.9%	54.7%	42.9%	37.2%	59.2%	51.8%
90	37.6%	53.5%	43.3%	36.3%	59.1%	53.6%
120	39.3%	53.1%	46.7%	38.2%	59.9%	54.6%
180	41.0%	54.8%	47.3%	39.9%	60.5%	54.9%
240	43.8%	55.0%	48.6%	41.7%	59.8%	55.2%
300	44.1%	56.1%	47.6%	42.9%	59.1%	54.0%
360	43.0%	58.3%	47.3%	43.3%	60.1%	54.4%
720	34.8%	60.9%	50.6%	37.5%	60.3%	55.4%
1440	34.1%	61.1%	52.3%	36.6%	60.8%	55.4%

Change in Forecast Error Standard Deviation (MW)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	11.7%	-0.6%	27.2%	8.5%	-2.8%	2.4%
30	7.5%	-0.7%	19.7%	4.8%	-3.7%	1.2%
45	9.0%	-0.9%	18.0%	11.1%	-4.9%	2.7%
60	12.1%	-1.1%	19.3%	1.9%	-6.0%	2.0%
90	1.4%	-1.5%	13.1%	1.0%	-7.5%	-3.4%
120	3.4%	-1.5%	10.6%	0.3%	-8.4%	-2.6%
180	1.4%	-1.7%	6.5%	0.0%	-9.6%	-4.4%
240	-0.1%	-2.0%	3.9%	-1.2%	-10.3%	-6.7%
300	-1.5%	-2.7%	4.2%	-3.4%	-10.9%	-8.9%
360	-1.3%	-3.4%	5.5%	-4.9%	-11.1%	-10.7%
720	10.4%	-6.2%	8.4%	-0.8%	-9.1%	-13.3%
1440	11.3%	-6.2%	-6.0%	0.6%	-9.3%	-12.9%

Figure 47: SDG&E Total, Summer, All Cloud Cover Conditions

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon Minutes Ahead	Behind-the-Meter Solar Generation Source: Cloud Cover — Error Correction	Model Direct	Reconstituted Loads	Behind-the-Meter Solar Generation Source: Clean Power Research — Error Correction	Model Direct	Reconstituted Loads
15	17.42%	-0.32%	65.32%	13.18%	-1.79%	5.26%
30	7.75%	0.00%	49.66%	5.13%	-2.68%	4.47%
45	24.29%	0.77%	40.07%	39.69%	-3.90%	4.28%
60	29.59%	0.29%	43.50%	2.41%	-4.03%	3.65%
90	0.11%	0.52%	35.97%	0.97%	-5.47%	1.26%
120	13.37%	0.96%	32.74%	1.96%	-6.15%	1.20%
180	6.61%	1.14%	26.03%	2.07%	-8.24%	-1.18%
240	5.56%	0.60%	21.25%	2.19%	-8.58%	-2.16%
300	6.59%	-0.34%	16.15%	1.47%	-8.93%	-4.92%
360	9.09%	-0.52%	11.00%	0.68%	-8.29%	-8.45%
720	22.56%	-1.09%	2.26%	0.98%	-6.21%	-16.49%
1440	23.75%	-1.74%	-4.38%	1.02%	-7.20%	-16.87%

Forecast Skill (%)

Forecast Horizon Minutes Ahead	Behind-the-Meter Solar Generation Source: Cloud Cover — Error Correction	Model Direct	Reconstituted Loads	Behind-the-Meter Solar Generation Source: Clean Power Research — Error Correction	Model Direct	Reconstituted Loads
15	38.9%	50.3%	32.6%	37.3%	53.8%	47.5%
30	43.4%	50.5%	33.6%	40.3%	54.4%	47.5%
45	41.9%	49.5%	36.5%	39.3%	54.9%	48.0%
60	41.7%	49.1%	35.8%	43.5%	55.4%	48.5%
90	46.8%	49.4%	36.8%	43.0%	54.8%	50.0%
120	44.8%	48.3%	38.0%	43.2%	55.9%	49.9%
180	46.6%	47.2%	39.9%	42.7%	57.2%	50.9%
240	47.0%	46.9%	40.4%	43.5%	56.9%	50.5%
300	46.3%	48.3%	41.6%	45.1%	57.4%	51.6%
360	43.6%	47.7%	44.5%	45.4%	55.3%	53.2%
720	37.7%	49.3%	49.6%	46.4%	51.5%	55.0%
1440	37.6%	49.9%	50.8%	45.7%	52.2%	55.1%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon Minutes Ahead	Behind-the-Meter Solar Generation Source: Cloud Cover — Error Correction	Model Direct	Reconstituted Loads	Behind-the-Meter Solar Generation Source: Clean Power Research — Error Correction	Model Direct	Reconstituted Loads
15	9.6%	-0.4%	52.2%	7.0%	-1.0%	3.5%
30	5.3%	-0.4%	39.9%	3.3%	-1.5%	3.2%
45	20.0%	0.2%	32.2%	42.1%	-2.4%	3.3%
60	26.5%	-0.1%	36.8%	1.4%	-2.5%	2.7%
90	0.3%	0.0%	30.0%	0.3%	-4.0%	0.5%
120	11.4%	0.2%	28.6%	0.4%	-4.8%	0.3%
180	4.1%	0.4%	21.8%	0.4%	-5.6%	-0.6%
240	3.2%	0.5%	17.0%	0.4%	-5.6%	-1.1%
300	4.7%	0.2%	13.1%	0.3%	-5.5%	-2.4%
360	7.8%	-0.2%	10.1%	0.1%	-5.5%	-4.9%
720	20.7%	-1.9%	11.5%	0.8%	-5.7%	-13.1%
1440	21.5%	-2.5%	-4.5%	0.5%	-6.7%	-14.1%

Figure 48: SDG&E Total, All Seasons, Clear

Change in Forecast Mean Absolute Percentage Error (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	22.81%	-0.92%	42.26%	14.99%	-2.63%	2.84%
30	10.64%	-0.66%	31.87%	5.90%	-3.21%	1.12%
45	19.63%	-0.45%	26.37%	25.82%	-4.64%	0.71%
60	20.48%	-0.75%	29.87%	0.99%	-4.78%	0.69%
90	-0.25%	-0.56%	23.10%	-0.34%	-6.16%	-2.46%
120	7.88%	-0.15%	21.10%	-0.01%	-6.96%	-1.78%
180	3.08%	-0.24%	15.56%	-0.18%	-8.78%	-2.99%
240	1.83%	-0.91%	11.93%	0.09%	-9.16%	-3.85%
300	2.05%	-1.97%	10.77%	-0.45%	-10.09%	-5.69%
360	3.40%	-2.85%	8.67%	-0.60%	-10.17%	-8.16%
720	15.33%	-4.23%	3.41%	2.64%	-7.34%	-12.72%
1440	16.45%	-4.29%	-4.10%	3.64%	-7.62%	-12.64%

Forecast Skill (%)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	32.7%	52.6%	37.1%	33.8%	55.1%	48.9%
30	38.2%	51.7%	38.5%	37.7%	55.8%	49.6%
45	39.4%	51.5%	39.8%	39.0%	56.6%	50.5%
60	40.2%	51.5%	40.6%	42.5%	57.0%	50.4%
90	44.2%	49.9%	40.9%	42.2%	56.8%	52.0%
120	44.4%	48.8%	42.8%	43.2%	57.5%	52.1%
180	46.7%	49.4%	44.4%	44.6%	58.8%	52.8%
240	47.4%	49.3%	45.1%	44.8%	58.3%	52.6%
300	45.5%	50.8%	44.4%	45.0%	57.7%	52.6%
360	42.9%	52.0%	45.8%	44.4%	57.5%	54.0%
720	35.7%	54.4%	49.1%	40.5%	54.8%	54.1%
1440	35.2%	54.5%	50.6%	39.4%	55.1%	54.0%

Change in Forecast Error Standard Deviation (MW)

Forecast Horizon	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	13.6%	-0.6%	36.0%	8.3%	-1.5%	1.7%
30	8.1%	-0.5%	27.4%	4.0%	-1.9%	1.5%
45	19.5%	-0.1%	22.9%	32.1%	-2.9%	2.3%
60	19.5%	-0.5%	27.4%	0.6%	-3.2%	2.3%
90	0.2%	-0.3%	20.7%	-0.5%	-4.2%	-0.4%
120	7.0%	-0.1%	19.6%	-0.8%	-5.2%	-0.1%
180	1.9%	0.1%	14.1%	-1.0%	-6.5%	-0.9%
240	0.3%	0.0%	11.1%	-1.3%	-6.8%	-1.9%
300	-0.2%	-0.6%	10.1%	-2.0%	-7.1%	-3.8%
360	0.4%	-1.3%	10.0%	-2.4%	-7.0%	-5.7%
720	8.1%	-3.7%	13.6%	-0.4%	-5.8%	-11.5%
1440	7.7%	-3.9%	-4.5%	-0.2%	-6.3%	-11.9%

Figure 49: SDG&E Total, All Seasons, Cloudy

Change in Forecast Mean Absolute Percentage Error (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	8.84%	-0.67%	60.30%	12.36%	-3.95%	7.56%
30	4.73%	-1.10%	43.42%	6.87%	-5.32%	4.74%
45	12.19%	-0.50%	35.80%	23.89%	-6.85%	4.28%
60	23.38%	-0.83%	35.14%	5.20%	-8.24%	1.23%
90	2.68%	-1.38%	28.66%	4.37%	-9.32%	-2.08%
120	10.52%	-1.42%	23.65%	4.44%	-10.90%	-3.63%
180	6.43%	-1.97%	18.38%	4.26%	-12.26%	-6.47%
240	5.72%	-2.32%	14.89%	2.83%	-12.97%	-8.16%
300	4.35%	-2.92%	10.87%	0.05%	-12.79%	-9.69%
360	6.20%	-3.02%	7.44%	-2.41%	-12.45%	-11.79%
720	22.03%	-4.88%	0.38%	-2.16%	-11.30%	-17.85%
1440	23.45%	-5.61%	-5.65%	-1.89%	-12.45%	-18.18%

Forecast Skill (%)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	37.0%	51.2%	34.1%	34.3%	54.6%	46.3%
30	38.5%	53.6%	35.0%	34.6%	55.3%	47.7%
45	37.4%	52.0%	36.5%	34.9%	55.7%	48.8%
60	36.0%	52.5%	36.5%	36.0%	57.9%	49.8%
90	38.2%	54.6%	38.2%	34.3%	57.1%	51.3%
120	37.3%	54.6%	41.3%	35.7%	58.8%	52.5%
180	38.0%	54.3%	41.9%	34.4%	58.9%	53.1%
240	41.3%	54.2%	43.3%	38.1%	58.4%	53.3%
300	44.8%	55.0%	45.0%	42.0%	59.3%	53.1%
360	44.0%	54.9%	46.1%	44.2%	58.0%	53.3%
720	37.5%	56.3%	52.1%	45.0%	58.0%	57.5%
1440	37.4%	57.2%	53.5%	45.0%	59.2%	57.6%

Change in Forecast Error Standard Deviation (MW)

	Behind-the-Meter Solar Generation Source: Cloud Cover			Behind-the-Meter Solar Generation Source: Clean Power Research		
Forecast Horizon Minutes Ahead	Error Correction	Model Direct	Reconstituted Loads	Error Correction	Model Direct	Reconstituted Loads
15	4.5%	-0.3%	51.2%	6.5%	-2.3%	5.5%
30	2.5%	-0.6%	37.4%	4.1%	-3.5%	4.1%
45	7.0%	-0.5%	30.6%	23.8%	-4.7%	4.7%
60	21.5%	-0.5%	31.3%	3.3%	-5.8%	2.9%
90	1.6%	-1.0%	25.3%	2.7%	-8.3%	-2.2%
120	9.5%	-1.0%	21.7%	2.4%	-8.9%	-2.4%
180	4.8%	-1.2%	15.6%	2.3%	-9.6%	-4.5%
240	3.6%	-1.4%	10.7%	1.1%	-10.0%	-6.6%
300	3.4%	-1.7%	7.3%	-0.8%	-9.6%	-8.1%
360	5.4%	-1.8%	5.1%	-2.2%	-9.5%	-10.7%
720	18.7%	-2.9%	6.0%	-0.2%	-8.5%	-15.9%
1440	19.7%	-3.5%	-4.6%	0.3%	-9.5%	-16.5%

CHAPTER 6:
Statistical Estimates of Solar PV Load Impacts

A benefit of the Model Direct approach is that it allows the statistical models through the process of model estimation to determine the forecasted load impact of a MW of Solar PV generation. Engineering principles suggest that every 1 MW of Solar PV generation directly offsets 1 MW of load. Based on these principles, the estimated coefficients on the Solar PV variables are expected to be equal to or very close to -1.0. In fact, the coefficients on the Solar PV variables in the Error Correction and Reconstituted Load approaches are explicitly set equal to -1.0 for just this very reason. Engineering principles, however, do not account for behavioral changes that may have taken place with the penetration of Solar PV. A plausible behavioral change is the increased use of air conditioning equipment post installation of Solar PV. Prior to installing Solar PV, consumers may not have run their air conditioners when they were at work to save money. Post Solar PV installation, the idea that they now have "free" electricity might lead consumers to leave their air conditioners on all the time regardless of whether they are home or not. In this example, 1 MW of Solar PV generation still offsets 1 MW of load, but that reduction may be masked by a load increase driven by the behavioral change. As a result, an engineering-based *a priori* value of -1.0 for the estimated coefficient on the Solar PV variable may not be realized.

Other confounding factors include prevailing weather conditions and the mix of space heating and space conditioning that exists in the load zone. A hot, cloudy day may lead to the lower Solar PV generation value being offset by higher air conditioning loads especially in load zones that have high penetrations of air conditioning. That same hot, cloudy day in an area with low air conditioning saturations may have the full impact of the Solar PV generation because of the lack of offsetting air conditioning loads. In a similar fashion, a cold, cloudy morning might lead to the load increase associated with lower Solar PV generation being compounded by an increase in electric space heating loads.

In general, the observed load impact of Solar PV generation will be complicated by weather and behavioral driven utilization of space conditioning equipment. Without detailed measurement of end-use equipment loads, it is difficult for a statistical model to isolate the impact of Solar PV generation on measured loads. Unfortunately, the challenge of isolating the impact of Solar PV on measured loads will only become more complex with saturation of electric vehicle charging and behind-the-meter storage, which will provide consumers flexibility with when they will use the electricity generated by their solar panels. In this soon-to-be-here world, the 1 MW of solar generation at Noon may offset 1 MW of vehicle charging at midnight. This type of behavioral change will further mask the load impact of Solar PV generation.

Presented in Figure 50 through Figure 53 are the statistically estimated load impacts under average solar and maximum solar conditions for the California ISO total and each of the load zones. In the figures, the dashed yellow line represents CPR's estimate of maximum Solar PV generation over the 2014-2015 period. The blue dashed line represents CPR's estimate of average Solar PV Generation over the same period. The solid gold line is the statistically adjusted maximum Solar PV generation impact that is computed as the product the CPR's maximum Solar PV generation and the estimated coefficient on the Solar PV variable from each of the 96 Day-Ahead models. The solid blue line is the statistically adjusted average Solar PV generation impact that is computed as the product the CPR's average Solar PV generation and the estimated coefficient on the Solar PV variable from each of the 96 Day-Ahead models.

Observations about these data are outlined below.

- On average, the estimated coefficients place less weight on the Solar PV generation in the mid-morning hours (08:00 to Noon) than the mid-afternoon hours (Noon to 16:00). During the mid-morning hours, the load forecast is adjusted down by approximately 50% of the Solar PV generation estimate. In the mid-afternoon hours, the load forecast is adjusted down by approximately 77% of the Solar PV estimate.

- The estimated coefficients on the early morning (pre 08:00) and late afternoon (post 16:45) potentially indicate a behavioral change associated with the trend in Solar PV installations that is leading to higher forecasted loads in both these periods. This impact is most pronounced under maximum solar conditions with an estimated impact of a little over 840 MW at 19:00. Under average solar conditions, the late afternoon pick up in loads is estimated to be about 60 MW. This leads to the potential swing in forecasts of late afternoon loads of about 780 MW.

- All three IOUs display a bump up in loads post 16:45 that is associated with the penetration of Solar PV. At 19:00, SCE estimated impact under maximum solar conditions is a little over 540 MW. Under average solar conditions the average load impact at 19:00 is about 30 MW. This implies a potential swing in forecasted loads between a maximum solar condition day and an average solar condition day of about 510 MW.

- At 19:00, PG&E estimated impact under maximum solar conditions is a little over 170 MW. Under average solar conditions, the average load impact at 19:00 is about 15 MW. This implies a potential swing in forecasted loads between a maximum solar condition day and an average solar condition day of about 160 MW.

- At 19:00, PG&E estimated impact under maximum solar conditions is a little over 120 MW. Under average solar conditions, the average load impact at 19:00 is about 5 MW. This implies a potential swing in forecasted loads between a maximum solar condition day and an average solar condition day of about 115 MW.

- In the early morning hours (pre-08:00) there is a similar forecasted rise in loads associated with penetration in Solar PV. This impact is most pronounced with PG&E with an estimated load impact of about 400 MW under maximum solar conditions. The impact on SCE early morning hours is estimated to be a little over 200 MW under maximum solar conditions. SDG&E does not have this type impact.

The results highlight another operational challenge in that the impact of Solar PV generation varies not only in magnitude across the three IOUs, but also the timing of the maximum impact.

This reflects the fact that the time at which the sun is at its zenith depends on where the loads are located. The geographic distance between the PG&E, SCE and SDG&E is sufficient to lead to differences in when the solar generation impact will be at its highest. This in turn implies the timing and order of magnitude of the late afternoon ramp-up in loads associated with a ramping down of Solar PV generation will vary across the year and across the three IOU loads.

The analysis of the statistically adjusted load impact of Solar PV generation reflects the challenge with the Model Direct approach. In all cases, the engineering-based *a priori* value for the estimated coefficient on the Solar PV generation variable of -1.0 is rejected. This does not mean that one (1) MW of Solar PV generation does not reduce load by one (1) MW. Rather models of measured load are challenged in isolating the impact of Solar PV generation from other potentially highly correlated factors that drive weather sensitive loads. Further, to the extent penetration of Solar PV leads to behavioral changes whereby people are taking advantage of "free" electricity, then the estimated coefficients on the Solar PV generation variables will be skewed to account for these behavioral changes. While it would be nice to have all of the estimated coefficients with a value close to -1.0, the goal is to improve the load forecast. To that end, the statistical models optimize the coefficient values to reduce load forecast errors. By not imposing *a priori* constraints on the estimated coefficients, the models are able to capture the net impact of a growing penetration of Solar PV.

Figure 50: Estimated Load Impact of Solar PV Generation: California ISO Total



Figure 51: Estimated Load Impact of Solar PV Generation: PG&E Total



Figure 52: Estimated Load Impact of Solar PV Generation: SCE Total



Figure 53: Estimated Load Impact of Solar PV Generation: SDG&E Total



CHAPTER 7: Conclusions

This interim study investigated if there was a way of improving the load forecast accuracy of the California ISO's existing load forecast models by incorporating forecasts of solar PV generation. The three alternative modeling approaches were subject to a forecast simulation using solar PV generation driven by hourly cloud cover for a handful of weather stations and solar PV generation estimates developed by CPR using a detailed database of solar PV installations combined with satellite imagery. The conclusions from this interim study include:

- Not adjusting the California ISO baseline forecast models will only lead to further erosion of forecast accuracy and a greater dispersion of forecast errors.
- For forecast horizons of 15 minutes ahead to four hours ahead, the Model Direct approach, when combined with the CPR estimates of solar generation, provides improved forecast accuracy and reduced forecast error dispersion over the baseline load forecast model. This finding indicates the benefit of relaxing the assumption that 1 MW of BTM solar PV generation leads to a 1 MW reduction in measured load which is a key assumption of both the Reconstituted Load and Error Correction approaches. These approaches assume both: (1) no underlying behavioral changes take place as a result of the installation of solar PV and (2) the BTM solar PV estimates are correct. In contrast, the Direct Model through the process of model estimation is able to capture the influence of behavioral changes on the estimated BTM solar PV generation impact, as well as make statistical adjustments for incorrect BTM solar PV estimates. This finding also provides evidence of the benefit of CPR's more granular approach to developing BTM solar PV generation over the use of a cloud cover driven forecast for a handful of weather stations.
- For longer term forecast horizons of six hours ahead to 24 hours ahead, the Reconstituted Load approach, combined with the CPR estimates of solar generation, provide improvements in both forecast accuracy and reduced forecast error dispersion over the baseline load forecast model.
- This suggests a hybrid forecast framework that leverages the forecasts from the Model Direct approach for forecast horizons of 15 minutes ahead to four hours ahead and then switches to the Reconstituted Load approach for forecasts horizons of fours-ahead and longer.
- Hourly cloud cover driven estimates of solar generation can provide benefit over doing nothing, however the detail bottom-up approach implemented by CPR yields superior results.
- The fact the results vary by season and cloud cover conditions suggest introducing seasonal and cloud cover interaction terms in the Model Direct approach. This would

allow the load impact of the solar generation variable to vary by season and cloud cover conditions.

- Other interaction terms including Day-of-the-Week and possibly temperature conditions may also prove useful in improving the accuracy of the Model Direct approach.
- The estimated coefficients of the Model Direct models provide evidence for the potential of long-run behavioral changes associated with the increased penetration of solar PV. If true, then the Error Correction and Reconstituted Load approaches will lose forecast skill over time as the assumption that the coefficient on the solar PV generation variable should be -1.0 becomes invalid.

Further research is required to determine the extent to which penetration of solar PV is leading to behavioral changes. If the answer is yes, then the load forecasting problem will only become more complicated with further penetration of solar PV combined with growth in electric vehicle charging, on-site electricity storage, and integration into emerging models such as microgrids.

GLOSSARY

Term	Definition
Azimuth	The horizontal angular distance between the vertical plane containing a point in the sky and true north.
Behind the Meter (BTM)	Generation connected on the customer side of the meter that impacts net load
CAISO	California Independent System Operator – the organization that manages the three IOU's electricity grid in California
CC	Cloud Cover, for the interim report, a cloud cover based model of BTM PV solar forecasts and generation
CPR	Clean Power Research, Itron's partner on this grant that s refining detailed and granular BTM PV solar forecasts
Direct Normal Irradiance (DNI)	The amount of solar radiation received per unit area by a surface that is always held perpendicular (or normal) to the rays that come in a straight line from the direction of the sun at its current position in the sky. Typically, you can maximize the amount of irradiance annually received by a surface by keeping it normal to incoming radiation.[1] Irradiance is usually measured in W/m2.
EPIC	Electric Program Investment Charge
Global Horizontal Irradiance (GHI)	Global Horizontal Irradiance is the total amount of shortwave radiation received from above by a horizontal surface.
Insolation	A measure of solar radiation energy received on a given surface area in a given time. It is commonly expressed as kilowatt-hours per square meter per day (kWh/(m2·day)).
Inverter	An electric conversion device that converts direct current (DC) electricity into alternating current (AC) electricity.
Inverter Efficiency	The AC power output of the inverter divided by the DC power input.
IOU	Investor Owned Utility; in California there are three; PG&E, SCE, and SDG&E
Net Load	The load seen at the customer meter, or the actual load minus any generation. For this interim report, this refers to the aggregate of al customer net load at either the California

	ISO zone, IOU, or California ISO level
Orientation	The azimuth and tilt of a PV system.
PG&E	Pacific Gas and Electric; the IOU that provides natural gas and electricity to much of Northern California
SCE	Southern California Edison; the IOU that provides electricity to much of Southern California outside of San Diego
SDG&E	San Diego Gas and Electric; the IOU that provides natural gas and electricity to San Diego and the surrounding area
Solar Irradiance	Radiant energy emitted by the sun, particularly electromagnetic energy.
Solar Noon	The moment when the sun appears highest in the sky (nearest zenith), compared to its positions during the rest of the day. It occurs when the sun is transiting the celestial meridian.
Solar PV	Solar Photovoltaic; a technology that uses semiconductors to convert solar irradiance into DC electrical power. This DC electrical power is usually converted to AC electrical power uses inverter(s).

REFERENCES

ITRON White Paper, Forecast Practitioner's Handbook: Incorporating the Impact of Embedded Solar Generation into a Short-Term Load Forecasting Model", (101376WP-01) 2014.

Monforte, F. and McMenamin J.S., "Short-Term Energy Forecasting with Neural Networks," with, The Energy Journal, Volume 19, Number 4, 1998.

MacDonald e. al 'Demand Response Providing Ancillary Services a Comparison of Opportunities and Challenges in the US Wholesale Markets', Grid-Interop Forum 2012